



Amendments to the
2014 Oregon Residential Specialty Code

Code Amendment Summary:

These modifications align the underground residential gas piping requirements of the Oregon Residential Specialty Code (ORSC) more closely with the Oregon Mechanical Specialty Code (OMSC) Sections C404.13, gas burial requirements for separation to other services.

These amendments have been formatted as insert pages for the 2014 ORSC. When inserted into the code, amendments will face the page containing the existing code language. Pages have been left blank for this purpose.

Instructions:

1. Print these pages **double-sided** in “book” format.
2. Insert the pages facing the page number in the bottom corner.
3. The amended language is depicted as follows:

~~Strikethrough~~ text represents deleted language.

Underlined text represents added language.

For questions regarding the 2014 *Oregon Residential Specialty Code*, please contact:

Tony Rocco
Senior Building Code Specialist
(503) 373-7529
Anthony.J.Rocco@oregon.gov

Rex Turner
Structural Program Chief
(503) 373-7755
Rex.L.Turner@oregon.gov



Effective February 1, 2016

G2415.11 Trenches. The trench shall be graded so that the pipe has a firm, substantially continuous bearing on the bottom of the trench.



~~**G2415.11.1 Underground gas pipe separation.** Underground gas piping shall be separated vertically or horizontally from other underground piping as follows:~~

- ~~1. Sewer pipe — not less than 18 inches (457 mm) from any underground sewer line.~~
- ~~2. Water pipe — not less than 12 inches (305 mm) from any underground water line.~~
- ~~3. Drainage pipe — not less than 12 inches (305 mm) from any underground drainage line.~~