

FACILITY		PR #:
PROJECT		
ADDRESS		

MORGUE AND AUTOPSY

OAR 333-535-0160

Effective October 1, 2009

_____ Schematic Design (SD) Review _____ Construction Document (CD) Review

REF OAR RULE SECTION	COMPLIED?		COMMENT
	YES	NO	
(1) These facilities shall be directly accessible to an outside entrance and shall be located to avoid transfer of cadavers through public areas.			
(2) The following elements shall be provided when autopsies are performed within the hospital:			
(a) Refrigerated facilities for body-holding equipped with temperature monitoring and alarms.			
(b) Autopsy room. This room shall contain:			
(A) Work counter with a hand-washing station;			
(B) Storage space for supplies, equipment, and specimens;			
(C) Autopsy table;			
(D) Clothing change area with shower, toilet and lockers within the area; and			
(E) Housekeeping service sink or receptacle.			
(3) If autopsies are performed outside the facility, only a well-ventilated body-holding room need be provided within the hospital.			