

OAR 333-061 - Public Water Systems - Detailed Index
Effective date: 5-18-2009

	Page
333-061-0005 Purpose	1
333-061-0010 Scope	1
1. Piped water, exclusion criteria	
a. Distribution and storage only	
b. Purchases water from another PWS	
c. Does not sell water directly	
d. Not an interstate commerce carrier	
e. Special irrigation districts	
2. Constructed conveyances, exclusion criteria	
a. Non human consumption	2
b. Alternative water	
c. Treated water	
333-061-0015 Adoption by Reference	2
333-061-0020 Definitions	2
333-061-0025 Responsibilities of Water Suppliers	19
1. Sampling	
2. Corrective action for MCL violations	
3. Reporting	
4. Public notice, MCL violations	
5. Public notice, monitoring violations, variance	
6. Maintain records	
7. Maintain min. 20 lbs. psi	
8. Complaint investigations	
9. Cross connection program	
10. Submit engineered plans	
11. Compliance with certification rules	20
12. Compliance with special training for non-community systems with surface water sources	
333-061-0030 Maximum Contaminant Levels	20
1. Inorganic Chemicals (Table 1)	
a. Compliance	
b. Fluoride SMCL (2.0 mg/l)	
c. Lead/copper action levels	
A. 90th percentile calculation	21
B. 90th percentile calculation(< 100 population)	
2. Organic Chemicals	21
a. Organics (Table 2)	
A. Compliance	22
b. Disinfection byproducts (Table 3)	22

	A.	Compliance with the MCL for TTHM and HAA5	22
	B.	Compliance with the MCL for bromate (Table 4)	23
	C.	Compliance with the MCL for chlorite	
c.		Volatile organic chemicals (Table 5)	23
	A.	Compliance	24
d.		Public health hazard determination	
e.		Department may set MCLs for additional organics	
f.		Pesticide application	
3.		Turbidity	24
	a.	MCLs for non-filtered systems, 01/01/92	
		A. 5 NTU in source water	
		i. Unusual and unpredictable events	
		ii. 2 events in 12 months; 5 in 120 months	
	b.	MCLs for filtered systems, 06/29/93	
		A. Conventional and direct filtration	25
		i. 0.3 NTU 95% of the time	
		ii. Never exceed 1 NTU	
		B. Slow sand filtration	
		i. 1 NTU 95% of the time	
		ii. Never to exceed 5 NTU	
		C. Diatomaceous earth filtration	
		i. 1 NTU 95% of the time	
		ii. Never to exceed 5 NTU	
		D. Other filtration technologies	
4.		Microbiological	26
	a.	Total Coliform	
		A. 40 or more samples per month	
		B. Fewer than 40 samples per month	
	b.	Fecal Coliform/ <i>E. coli</i>	
	c.	Compliance determination	
	d.	Non-pathogenic violations(Biofilm)	
		A. Absence of <i>E. coli</i>	
		B. Absence of coliform at entry point	
		C. Treatment requirements met	
		D. Turbidity MCL met	27
		E. Disinfectant residual	
		F. No waterborne disease history	
		G. Addressed sanitary survey	
		H. Cross connection control program	
5.		Radionuclides (Table 6)	27
	a.	Average annual concentrations	
		A. Tritium	
		B. Strontium-90	

b.	MCL compliance	
6.	Secondary Contaminants (Table 7)	27
a.	Fluoride SMCL (2.0 mg/l) public notice	28
b.	Fluoride MCL (4.0 mg/l) public notice	
7.	Acrylamide and Epichlorohydrin	28
a.	Certification of no exceedance	
A.	Acrylamide: .05% dose	
B.	Epichlorohydrin: .01% dose	
	333-061-0031 Maximum Residual Disinfectant Levels	28
1.	MRDLs (Table 8)	
2.	Compliance Dates	
a.	CWS and NTNCWS	
b.	TNCWS	
3.	Enforceability	29
	333-061-0032 Treatment Requirements and Performance Standards For Surface water, GWUDI and Groundwater	29
1.	General requirements	29
a.	Treatment and inactivation levels	
A.	<i>Giardia Lamblia</i> (3 log)	
B.	Viruses (4 log)	
C.	<i>Cryptosporidium</i> (2 log)	
D.	Disinfection profiling	
E.	<i>Cryptosporidium</i> sampling and bin classification	
i.	Source water monitoring	
ii.	Bin classification	30
iii.	Microbial toolbox options	
F.	Schedule for <i>Cryptosporidium</i> treatment compliance	
i.	Filtered water systems	
ii.	Unfiltered water systems	
iii.	<i>Cryptosporidium</i> treatment compliance dates	
I.	At least 100,000 people	
II.	50,000 to 99,999 people	
III.	10,000 to 49,999 people	
IV.	Less than 10,000 people	
V.	State regulated water systems	
iv.	Bin classification change	31
v.	Change in mean <i>Cryptosporidium</i> level	
b.	Compliance	
A.	Avoiding filtration treatment	
B.	Installing and operating filtration treatment	
c.	GWUDI, 18 months to meet requirements, interim standards	
A.	Turbidity never to exceed 5 NTU	
B.	1.0 log inactivation of <i>Giardia</i>	

	C.	Reporting requirements	
	D.	PN if system fails to meet standards	
2.		Unfiltered requirements	31
	a.	General	32
	b.	Source water quality conditions	
	A.	Fecal and/or total coliform	
	B.	Turbidity	
	c.	Site specific conditions	
	A.	Adequate disinfection	
	B.	Watershed control program	
	i.	Hydrology and land ownership	33
	ii.	Characteristics and activities	
	iii.	Adverse effects	
	C.	On-site inspection of program	
	i.	Effectiveness of program	
	ii.	Condition of intake	
	iii.	Maintenance program	
	iv.	Disinfection equipment	
	v.	Operating procedures	
	vi.	Data records	
	vii.	Improvements to program	
	D.	Waterborne disease outbreaks	
	E.	Compliance with microbiological MCL	
	F.	Compliance with the MCL for disinfection byproducts	
	d.	Determination of mean <i>Cryptosporidium</i> level	34
	A.	Calculation	
	B.	Sampling frequency	
	C.	Report	
	D.	Failure to comply	
	e.	Failure to comply	
3.		Disinfection unfiltered sources	34
	a.	General requirements for	
	b.	Disinfection equipment	
	A.	Redundant components	
	B.	Automatic shut-off	35
	c.	Residual entering distribution system	
	d.	Residual in distribution system	
	e.	<i>Cryptosporidium</i> level inactivation requirements	
	A.	2-log	
	B.	3-log	
	f.	Inactivation treatment technology requirements	
	A.	Chlorine dioxide or ozone	
	B.	UV	

g.	Use of two disinfectants	
4.	Filtered requirements	36
a.	General	
b.	Conventional or direct filtration	
c.	Slow sand filtration	
d.	Diatomaceous earth filtration	
e.	Other filtration technologies	
	A. Bank filtration	
	B. Membrane filtration	
f.	<i>Cryptosporidium</i> bin classification for filtered water systems	
	A. Systems collecting 48 or more samples	
	B. Systems collecting 24 to 47 samples	37
	C. Systems serving less than 10,000 people	
	D. Seasonal water systems	
	E. Variations in monthly sampling frequency	
	F. Bin classification table, initial bin classification (Table 9)	
	i. Second round of source water monitoring	
	G. Reporting bin classification	
	H. Bin classification report	38
g.	Additional <i>Cryptosporidium</i> treatment requirements	
	A. Additional filtration for bin classification (Table 10)	
	B. Use of more than one treatment	
	C. Systems classified in Bin 3 or Bin 4	
	i. Failure to achieve treatment credit	
	ii. Changes in watershed	39
5.	Disinfection requirements for filtered sources	39
a.	General	
b.	Residual entering distribution systems	
c.	Residual in distribution systems	
6.	Disinfection requirements for groundwater sources	39
a.	Treatment Technique requirements	
b.	<i>E. coli</i> -positive groundwater source samples	
c.	Systems using both groundwater and surface water	
d.	Corrective action	
e.	Notification of a significant deficiency	40
	A. Completing corrective action	
	B. Corrective action plan	
	i. Modifications	
	ii. Interim Measures	
f.	Corrective action alternatives	
	A. Correct all significant deficiencies	
	B. Provide alternate source of water	
	C. Eliminate the source of contamination	

	D.	Provide treatment		
	g.	Groundwater systems with a significant deficiency		
		A.	Failure to complete corrective action	
		B.	Failure to meet corrective action plan	
	h.	Notification of an <i>E. coli</i> -positive groundwater source sample	41	
		A.	Failure to complete corrective action	
		B.	Failure to meet corrective action plan	
	i.	Failure to maintain 4-log treatment of viruses		
	j.	Continuous disinfection requirements		
		A.	Violations of the total coliform rule	
		B.	Potential health hazard	
7.		Compliance monitoring requirements for groundwater systems	41	
	a.	System eligibility		
		A.	Department notification	
		B.	Required to comply	
		C.	Discontinuing 4-log treatment of viruses	
	b.	Monitoring requirements		
		A.	Chemical Disinfection	
			i.	Systems serving more than 3,300 people
			ii.	Systems serving 3,300 people or less
		B.	Membrane filtration	
			i.	Molecular weight cut-off
			ii.	Department-specified compliance requirements
			iii.	Membrane integrity
		C.	Alternative treatment	
			i.	Treatment monitoring
			ii.	Treatment operation
	c.	Discontinuing treatment		
8.		Determination of GWUDI, criteria	43	
	a.	PWS with GW GWUDI evaluation		
		A.	Distance/hydrogeologic setting criteria	
			i.	500 feet, fractured bedrock or layered volcanic aquifer
			ii.	200 feet, coarse sand, gravel and boulder aquifer
			iii.	100 feet, sand and gravel aquifer
			iv.	75 feet, sand aquifer
			v.	Greater distances
		B.	Confirmed coliform history	
		C.	“Highly Sensitive” determination	
	b.	Hand pump exclusion		
	c.	Raw water sampling		
	d.	Raw water sampling frequency		
	e.	Special samples		
	f.	Additional raw water sampling		

g.	Confirmed Fecal/ <i>E. coli</i> positive samples	
h.	Violation exemption	
i.	No additional sampling	
j.	Source re-evaluation	
k.	Ground water designation	45
l.	Hydrogeological assessment	
	A. Well characteristics	
	B. Aquifer characteristics	
	C. Hydraulic gradient	
	D. Groundwater flow	
	E. Oregon registered geologist	
m.	Emergency sources/public notice	
n.	Confined Aquifers/well construction	
o.	Microscopic Particulate Analyses (MPA)	
p.	MPA scoring	46
q.	Source classification determinations	
	A. MPA risk score <10	
	B. MPA risk score >19	
	C. MPA risk score between 10 and 19	
	i. MPA risk scores <15	
	ii. MPA risk scores >14	
	iii. Additional MPAs	
r.	Infiltration gallery, Ranney or dug well turbidity	
s.	Shifts in groundwater characteristics	
t.	Source re-evaluation	
u.	Alternative methods (Table 11)	
9.	GWUDI systems seeking credit through bank filtration	47
	a. Qualifying systems	
	A. Bank filtration study	
	b. System using credit violating the MCL for turbidity	48
10.	Disinfection by-product control	48
	a. Compliance criteria for chemical disinfectants	
	b. Compliance dates	
	A. CWS and NTNCWS	
	B. TNCWS using chlorine dioxide	
	c. Increasing residual disinfectant levels temporarily	49
	d. Treatment technique for control of DBPs	
	A. Alternative compliance criteria	
	i. Source water TOC <2.0	
	ii. Treated water TOC <2.0	
	iii. Source water TOC <4.0	
	iv. TTHM ≤ 0.040 mg/l /HAA5 ≤ 0.030 mg/l	50
	v. Source water SUVA ≤ 2.0 L/mg-m	

	vi.	Finished water SUVA ≤ 2.0 L/mg-m	
	B.	Alternative compliance criteria for softening	
	i.	Alkalinity	
	ii.	Magnesium hardness	
e.		Enhanced coagulation and softening performance requirements	
	A.	Specified TOC reduction	
	B.	Required Step 1 TOC reduction (Table 12)	
	C.	Waiver from Step 1 requirements (Step 2)	51
	D.	Step 2 TOC reduction requirements	
	i.	Alternate enhanced coagulation level defined	
	ii.	Bench/pilot-scale testing (Table 13)	52
	iii.	Alkalinities <60 mg/l	
	iv.	Coagulant dose and pH	
	v.	TOC removal less than 0.3 mg/l	
f.		Compliance calculations	
	A.	Compliance calculations required	
	i.	Actual monthly TOC percent removal equation	
	ii.	Required TOC percent removal (sources)	
	iii.	Divide actual by required	53
	iv.	Annual calculation	
	v.	Compliance determination	
	B.	Alternate compliance determination	
	i.	Treated/source water TOC level <2.0 mg/l	
	ii.	Softening and magnesium hardness	
	iii.	Source water SUVA <2.0 L/mg-m	
	iv.	Finished water SUVA <2.0 L/mg-m	
	v.	Alkalinity <60 mg/l	
	C.	Conventional treatment compliance	
	g.	Treatment technique requirements for DBP precursors	54
11.		WTP Recycled Water	54
	a.	Surface WS and GWUDI WS	
	b.	Notification to Department	
		A. Flow origin schematics	
		B. Recycle flows	
	c.	Return flow location	
12.		Uncovered finished water storage	54
	a.	Requirement to cover	55
	b.	Treatment	
	c.	Failure to comply	
13.		Microbial toolbox options summary (Table 14)	55
14.		Source toolbox options	56
	a.	Watershed control program	
		A. Department notification	

	B.	Plan submittal	57
		i.	Area of influence
		ii.	Potential and actual <i>Cryptosporidium</i> sources
		iii.	Effectiveness analysis
		iv.	Water system statement
	C.	Existing programs	
	D.	Department response	
	E.	Log credit maintenance	
		i.	Annual status report
		ii.	Watershed sanitary survey
		I.	Survey criteria
		II.	Significant changes
		iii.	Public availability
	F.	Failure to implement an approved plan	
	G.	Significant change to an approved plan	
	b.	Alternative source	59
		A.	Alternative source monitoring
		B.	Monitoring requirements
		C.	Bin classification using alternative source monitoring
15.		Pre-filtration toolbox options	59
	a.	Presedimentation	
		A.	Continuous operation
		B.	Continuous addition of coagulant
		C.	Performance criteria requirements
		i.	Influent turbidity reduction
		ii.	Performance criteria
	b.	Two-stage lime softening	60
	c.	Bank filtration	
		A.	Groundwater flow path
		B.	Granular aquifers
		i.	Core demonstration
		C.	Well types
		D.	Flow path measurement
		E.	Turbidity requirements
		F.	Springs and infiltration galleries
		G.	Demonstration of performance
		i.	Department-approved protocol
		ii.	Sampling study protocol
16.		Treatment performance toolbox components	61
	a.	Combined filter performance	
	b.	Individual filter performance	
		A.	Filtered water turbidity
		B.	Measured turbidity limit

C.	Failure to meet individual filter performance	
i.	Unusual circumstances	62
ii.	Failure limit in any calendar year.	
c.	Demonstration of performance	
A.	Treatment credit exclusions	
B.	Department-approved protocol	
C.	Department Approval	
17.	Additional filtration toolbox components	62
a.	Bag and cartridge filters	
b.	Membrane filtration	
c.	Second stage filtration	63
d.	Slow sand filtration (as secondary filter)	
18.	Inactivation toolbox components	63
a.	Chlorine Dioxide	
b.	Ozone	
c.	UV	

333-061-0034 Treatment Requirements and Performance Standards for Corrosion Control 63

1.	General Requirements	
a.	Community, NTNC; optimal treatment	
b.	Compliance with corrosion control treatment	
c.	Source water treatment when Pb/Cu exceeded	64
d.	Public education requirements when Pb exceeded	
e.	Monitoring as prescribed in OAR 333-061-0036(2)(e)	
f.	Reporting and record keeping	
g.	Failure to comply	
2.	Corrosion control treatment steps, completion schedule	64
a.	Large systems (>50,000), requirements	
A.	Initial tap monitoring	
B.	Corrosion control studies	
C.	Optimal corrosion control treatment	
D.	Corrosion control treatment installation	
E.	Follow-up sampling	
F.	Optimal water quality control parameters	
G.	Compliance with parameters	
b.	Medium systems (3301-50,000), requirements	
A.	Initial tap monitoring	
B.	Corrosion control studies	65
i.	Medium systems	
ii.	Small systems	
C.	Corrosion control studies completion	
D.	Optimal corrosion control	
E.	Corrosion control treatment installation	

	F.	Follow-up sampling	
	G.	Optimal water quality control parameters	
	H.	Compliance with parameters	
c.		Small systems ($\leq 3,300$), requirements	
d.		Compliance criteria for optimal corrosion control	
	A.	Small/medium systems, Pb/Cu action levels	66
	B.	Equivalent treatment steps, compliance	
	i.	Water quality parameter results	
	ii.	Test method explanation	
	iii.	Installation/maintenance report	
	iv.	Follow-up tap water monitoring	
	C.	Optimized corrosion control	
	i.	Source lead below MDL/90th %tile \leq PQL	67
	ii.	Minimum monitoring every 3 years	
	iii.	Change in source or treatment notification	
	iv.	Optimized corrosion control and copper AL	
	v.	Corrosion control trigger	
e.		Small/med systems; treatment cessation	
3.		Corrosion control treatment requirements	68
	a.	Small/medium systems, exceeding Pb/Cu, treatment	
	b.	Small/medium systems, exceeding Pb/Cu, studies	
	c.	All systems, treatment effectiveness evaluation	
	A.	Alkalinity, pH adjustment	
	B.	Calcium hardness adjustment	
	C.	Phosphate or silicate corrosion inhibitors	
	d.	Water quality parameters	
	A.	Lead	
	B.	Copper	69
	C.	pH	
	D.	Alkalinity	
	E.	Calcium	
	F.	Conductivity	
	G.	Orthophosphate	
	H.	Silicate	
	I.	Temperature	
	e.	Alternative treatment approaches, studies	
	f.	Treatment limitation, documentation	
	A.	Treatment adverse affects, other system	
	B.	Treatment adverse affects, prior evaluation	
	g.	Treatment chemical effects on other processes	
	h.	Recommendation of treatment process to Department	
	i.	Department approval of treatment method	
	j.	Notification of Department approval	

k.	Proper installation and operation	70
l.	Department evaluation of proper installation/operation	
A.	pH value at distribution entry points	
B.	pH value at tap sample points (≥ 7.0)	
C.	Inhibitor concentrations at tap/entry points	
D.	Alkalinity concentrations at tap/entry points	
E.	Calcium carbonate concentrations at tap	
m.	Maintain optimal corrosion control/compliance	
A.	Daily average (multiple measurements)	71
B.	Daily average (single measurement)	
C.	Daily average (no measurement)	
n.	Department modification of treatment/parameters	
4.	Source water treatment requirements	71
a.	Monitoring requirements, deadlines	
A.	When Pb/Cu exceeded, recommendation	
B.	Department determination of source treatment	
C.	Treatment installation	72
D.	Follow-up tap/source monitoring	
E.	Maximum permissible source water levels	
F.	Compliance with specified source Pb/Cu levels	
b.	Source water treatment description	
A.	Treatment recommendation to Department	
B.	Treatment determination, treatment methods	
C.	Proper installation/operation by system	73
D.	Department approval of installation/operation	
E.	Compliance with Pb/Cu levels	
F.	Department modification of treatment/levels	
5.	Public education (consumer notice and lead exceedance)	73
a.	Content of written materials, CWS	74
A.	Important Information	
B.	Health effects of lead	
C.	Lead sources	
i.	What is lead	
ii.	Sources of DW lead	
iii.	Other lead sources	
D.	Steps to reduce lead exposure	
i.	Flushing	
ii.	Hot water	
iii.	Boiling	
iv.	Other consumer options	
v.	Blood level testing	
E.	Why and what system is doing	75
F.	For more information	

b.	Community system additional info	
	A. Water testing	
	B. Plumbing components/lead-free	
c.	Delivery	
	A. Non-English Speakers	
	B. 60-day notification	
	i. Bill paying customers	
	ii. Public health agencies	
	iii. Schools, WIC, headstart, etc.	76
	iv. Childcare, preschools, OBGYN, midwives	
	v. Water bills	
	vi. Posting	
	vii. Press release	77
	viii. Three additional activities	
	ix. September 30	
	C. CWS repeat activities	
	i. Every 12 months	
	ii. Billing cycle	
	iii. Web site	
	iv. Every 6 months	
	D. NTNCWS	
	i. Posting	
	ii. Pamphlets/brochures	
	iii. September 30	78
	E. NTNCWS repeat every 12 months	
	F. Discontinue Delivery	
	G. Modified text/activities	
	i. Prison, hospital, etc	
	ii. Cost of Services	
	H. ≤3,300	
	i. At lease one activity	
	ii. Pregnant women/children	
	iii. Every household	
d.	Supplemental monitoring/notification	79
e.	Consumer notification of results	
	A. Individual tap results for sampling sites	
	B. Notification within 30 days	
	C. Contents of notice	
	D. Method of delivery	

333-061-0036 Sampling and Analytical Requirements 79

1. General 79

a.	Approved EPA methods	
	A. <i>Cryptosporidium</i> analysis	80

b.	Alternate analytical methods	80
A.	Written Department permission	
B.	No reduction of sampling frequency	
c.	Approved laboratories	
A.	Certified laboratories	
B.	Sampling by the Department	
C.	<i>Cryptosporidium</i> analysis	
d.	Purchasing water systems	
A.	Modified monitoring requirements	
B.	Department approved schedule	81
e.	Individual source monitoring	
A.	Combined sources, entry point monitoring	
B.	Uncombined ground sources, wellfields	
f.	MCL compliance, sampling point designation	
g.	Additional sampling for SDWA contaminants or others	
h.	Approved sample collection/location/submittal/type	
A.	Routine	
B.	Repeat	82
C.	Special	
2.	Inorganic chemicals	82
a.	List: Antimony-Thallium (regulated)	
A.	Sampling requirements	
i.	Community, NTNC: surface sources	
ii.	Community, NTNC: ground sources	
iii.	Transient Non-community/sources	83
iv.	Combined sources	
B.	Compositing of samples	
C.	Waivers from monitoring frequencies	
i.	Minimum previous monitoring	
ii.	Department granted, in writing	84
D.	MCL exceedance	
E.	New system/source compliance	
b.	Sulfate	
A.	Sampling requirements	
i.	Community, NTNC; surface/ground	
ii.	Combined sources	85
B.	Waivers, previous analyses	
C.	Confirmation samples	
D.	Compositing	
c.	Asbestos	
A.	Sampling requirements; Community, NTNC	
B.	Waiver, not vulnerable to source/pipe	
C.	Monitoring for pipe vulnerability, Pb/Cu	

D.	Monitoring for source vulnerability, Pb/Cu	
E.	Monitoring for pipe/source vulnerability	
F.	MCL exceedance, minimum monitoring	86
G.	Grandparenting data	
d.	Lead and Copper	
A.	Monitoring tap water: site location	
i.	Materials evaluation, site selection	
ii.	Source review for site selection	
I.	Plumbing codes, permits etc.	
II.	Water quality information	
iii.	Tier 1 sample sites, CWS	87
iv.	Tier 2 sample sites, CWS	
v.	Tier 3 sample sites, CWS	
vi.	Tier 1 sample sites, NTNC	
vii.	Tier 3 sample sites, NTNC	
viii.	Site selection justification	
B.	Monitoring tap: sample collection methods	88
i.	First draw samples	
ii.	Sampling requirements	
iii.	Sample site substitution	
C.	Monitoring tap, number of samples, table	
D.	Monitoring tap water, sampling dates	89
i.	Initial sampling dates, table	
I.	Large systems	
II.	Small/medium systems	
ii.	After corrosion/source treatment	
I.	Large systems, treatment	90
II.	S/M systems, treatment	
III.	All systems, source treatment	
iii.	After water quality parameters set	
iv.	Reduced Monitoring	
I.	Small/medium systems: Pb/Cu levels	
II.	All systems: maintain parameters	
III.	Small/medium systems: meet Pb/Cu/parameters	
IV.	Site selection, designated months	91
V.	Small/medium systems, resumption	92
VI.	≤ .005 (pb)/≤ .65 (cu), every 3 yrs	94
VII.	New source/treatment notification	
E.	Monitoring tap water, additional monitoring, invalidation	
i.	Sample invalidation conditions	
I.	Lab error	
II.	Unrepresentative sampling	
III.	Damaged sample container	

	IV. Sample tampering	
	ii. Sample reporting/documentation	
	iii. Invalidation not allowed by Department	95
	iv. Replacement samples	
F.	Monitoring water quality parameters	
	i. Sample collection methods	
	I. Tap samples	
	II. Distribution entry point samples	
	ii. Number of samples	
	I. Tap samples, table	
	II. Distribution entry point samples	96
	iii. Initial sampling	
	I. Tap parameters	
	II. Distribution entry point parameters	
	iv. Monitoring after treatment installation	
	I. Tap parameters	97
	II. Entry point parameters	
	III. Groundwater systems EP sampling	
	v. Monitoring after parameter values set	
	vi. Reduced monitoring	98
	I. Sample sites, table	
	II. Sampling: annual, then every 3 years	
	III. Sampling: directly to every 3 years	99
	IV. Annual sampling throughout year	
	V. Resumption of normal sampling	
	vii. Additional monitoring	100
G.	Monitoring for source water Pb/Cu	
	i. Sample location, number, etc.	
	I. Groundwater systems	
	II. Surface water systems	
	III. Multiple sources	
	ii. Confirmation sampling	
H.	Monitoring for source Pb/Cu, tap exceedance	101
	i. Monitoring frequency after source treatment	
	ii. Monitoring frequency after Pb/Cu source levels	
	I. Required monitoring frequencies	
	II. Exclusion from monitoring	102
	iii. Reduced source water monitoring	
	I. Ground sources	
	II. Surface sources	
	III. New sources	
e.	Nitrate	103
	A. Sampling requirements, C and NTNC; surface	

	B.	Sampling requirements, C and NTNC; ground	
	C.	Sampling requirements, NC	
	D.	Community, NTNC; annual, designated quarter	
f.		Nitrite	
	A.	Sampling requirements, all systems, $\geq 50\%$ MCL	
	B.	Repeat monitoring where $< 50\%$ of MCL	
	C.	All systems, annual, designated quarters	
g.		Sodium	104
	A.	Sampling requirements	
		i. Community, NTNC; surface sources	
		ii. Community, NTNC; ground sources	
	B.	Reporting	
h.		Confirmation samples	
	A.	MCL exceedance, asbestos, barium, etc.	
	B.	MCL exceedance, nitrate or nitrite	
	C.	Averaging initial and confirmation samples	
i.		Additional sampling	
j.		Compliance with MCLs	
	A.	Monitoring $>$ annually	
	B.	Monitoring \leq annually	105
	C.	Nitrate and nitrite	
	D.	All contaminants, MCL exceedance	
k.		Monitoring schedule	
3.		Organic Chemicals	106
	a.	List: Alachlor-2,4,5-TP Silvex (regulated)	
		A. Sampling requirements	
		i. C, NTNC; sw/gw, new wells	
		ii. Multiple sources	
		iii. Reduced monitoring	
		I. $> 3,300$ population, 2 per 3 yrs	107
		II. $\leq 3,300$ population, 1 per 3 yrs	
		III. State certified DWPP, 1 per 6 yrs	
		IV. Use and Susceptibility, 1 per 9 yrs	
		iv. Wellfield	
	B.	Waiver application	
		i. DWPA, source water assessment	
		ii. Use waiver criteria	
		iii. Susceptibility waiver criteria	108
		iv. Monitoring requirements	
		v. Guidance document made part of rules	
		vi. Area wide waivers	
	C.	Detections, detection limits (Table 15)	
		i. Sampling reduction, annual	109

	ii.	Waiver application	
	iii.	Related contaminant monitoring	
	D.	MCL exceedance	
	E.	Confirmation samples	
	F.	Compositing samples	
	G.	Compliance	110
	H.	Grandfathering data	
	I.	Monitoring schedule/table	
	J.	New systems or sources	111
b.		VOCs: List: Benzene--1,2,4-Trichlorobenzene (regulated)	
	A.	Sampling requirements	
	i.	Community, NTNC; sw/gw, new wells	
	ii.	Additional sampling points	
	iii.	Multiple sources	
	iv.	Wellfield	112
	B.	Detection limit	
	C.	Reduced monitoring	
	i.	SW/GW, annual	
	ii.	GW, 1 per 3 yrs	
	iii.	State certified DWPP, 1 per 6 yrs	
	iv.	Use and Susceptibility, 1 per 9 yrs	
	v.	Area wide waivers	
	D.	Waivers	
	E.	Waiver conditions	113
	F.	Monitoring reduction, surface water	
	G.	Detections and quarterly monitoring	
	i.	Return to annual monitoring	
	ii.	Waiver application	
	iii.	Vinyl chloride monitoring	
	H.	MCL exceedance	
	I.	Confirmation samples	114
	J.	Compositing	
	K.	Compliance	
	L.	Grandfathering data	115
	M.	Monitoring schedule	
	N.	New systems or sources	
4.		Disinfectant Residuals, Disinfection Byproducts, and Precursors	115
	a.	General sampling and analytical requirements	
	A.	Normal operating conditions	
	B.	Multiple wells/single aquifer	
	C.	Failure to monitor	
	D.	Failure to monitor/running annual average	
	E.	Qualifying for reduced monitoring	116

b.	Initial Distribution System Evaluation	
A.	Submittal schedule (Table 16)	
i.	Combined distribution system	117
ii.	IDSE results not for compliance	
B.	Standard monitoring plan	
i.	Distribution system schematic	
ii.	Monitoring location selection	
iii.	System population/classification	
iv.	Standard monitoring (Table 17)	
v.	Sample location	118
vi.	Excess entry point samples	
vii.	Monitoring may not be reduced	119
viii.	IDSE Report	
I.	Analytical results included	
II.	Explanation of deviations	
III.	Compliance monitoring recommendations	
C.	System Specific Study Plans	
i.	Existing Monitoring Results	
I.	Acceptable samples	
II.	Monitoring locations/frequency (Table 18)	
III.	Previously collected results	120
IV.	Sample certification	
V.	Distribution system schematic	
VI.	Population/System classification	
VII.	Sample rejection	121
ii.	Modeling	
I.	24-hour variation	
II.	Model criteria	
III.	Model calibration	
IV.	Reporting	
V.	Model deficiencies	122
iii.	IDSE Report	
I.	Monitoring results	
II.	Modeling elements	123
III.	Monitoring locations	
IV.	Deviations	
V.	Location justification	
VI.	Report submittal	
D.	Monitoring location recommendations	
i.	Recommendation	
ii.	Sample collection	
	Table 20	124
iii.	Recommended locations	

	I.	Highest TTHM LRAA	125
	II.	Highest HAA5 LRAA	
	III.	Highest TTHM RAA	
	IV.	Highest TTHM LRAA	
	V.	Highest TTHM LRAA	
	VI.	Highest HAA5 LRAA	
	VII.	Highest TTHM RAA	
	VIII.	Highest HAA5 LRAA	
	iv.	Alternate locations	
	v.	Seasonal variation	
c.		Routine monitoring for TTHM and HAA5	
	A.	Frequency	
		Table 21	126
	B.	Increased monitoring	127
	C.	Monitoring Plan	
		i. Specific locations and schedules	
		ii. Compliance determination	
		iii. Combined distribution system	
d.		Revised monitoring for TTHM and HAA5	
	A.	Compliance schedule (Table 22)	
		i. Systems monitoring quarterly	128
		ii. Systems monitoring less than quarterly	
	B.	Compliance determination	
		i. Systems monitoring quarterly	
		ii. Systems monitoring less than quarterly	129
		iii. Single sample violations	
	C.	Monitoring Frequency	
		i. Table 23	
		ii. New systems	130
	D.	Monitoring Plan	
		i. Elements	
		I. Locations	
		II. Dates	
		III. Compliance determination	
		ii. Monitoring Locations	
		iii. Surface water or GWUDI	
		iv. Revisions	
e.		Reduced monitoring (Table 24)	131
	A.	Qualifications	132
	B.	Transition to revised monitoring	
	C.	Source water TOC	
	D.	Department discretion	133
f.		Revised reduced monitoring (Table 25)	

	A.	Qualifications	134
	B.	Remaining on reduced monitoring	
		i. Systems monitoring quarterly	
		ii. Systems monitoring less than quarterly	
	C.	Resumption of routine monitoring	135
		i. LRAA sample results	
		ii. Sample results for single sample	
		iii. Source water TOC	
	D.	Monitoring results for source water TOC	
	E.	Department discretion	
g.		Disinfection profiling	
	A.	Parameters	
		i. Water temperature	
		ii. pH	136
		iii. Contact time	
		iv. Residual concentration	
	B.	Water systems serving at least 10,000 people	
	C.	Water systems serving less than 10,000 people	
	D.	Inactivation ratio for <i>Giardia</i>	
		i. Disinfectant application, single point	
		I. Inactivation ratio	
		II. Sequential inactivation ratio	
		ii. Disinfectant application, multiple points	
		iii. Calculations	137
	E.	New monitoring avoidance	
		i. Existing data	
		ii. Existing profile	
	F.	Inactivation ratio	
	G.	Disinfection benchmark	
		i. Annual results	
		ii. Calculation	
	H.	Record maintenance	138
h.		Increased monitoring	
	A.	Qualifying systems	
	B.	Monitoring locations	
	C.	Return to routine monitoring	
i.		Operational evaluation level	
	A.	Calculation	
	B.	Evaluation and report	
		i. Report submittal	
		ii. Required elements	
		I. Limiting scope	
		II. Request	139

j.	Additional requirements for purchasing systems	
k.	Chlorite	
	A. Routine monitoring	
	i. Daily monitoring	
	ii. Monthly monitoring	
	B. Additional monitoring	
	C. Reduced monitoring	
	i. Entry point	140
	ii. Distribution	
l.	Bromate	
	A. Routine Monitoring	
	B. Reduced Monitoring	
m.	Monitoring requirements for residuals	
	A. Chlorine and chloramines	
	i. Routine monitoring/compliance	
	ii. Reduced monitoring	141
	B. Chlorine dioxide	
	i. Routine monitoring/compliance	
	ii. Additional monitoring	
	iii. No reduced monitoring	142
n.	Monitoring requirements for DBP precursors	
	A. Routine monitoring	
	B. Reduced monitoring	
o.	Bromide	
p.	General compliance requirements	
	A. Monitoring violations	
	B. All samples must be reported	143
	C. Quarterly averages, early MCL exceedance	
q.	Compliance requirements for TTHM and HAA5	
	A. Systems monitoring quarterly	
	B. Systems monitoring less frequently	
	C. MCL exceedance and PN	
	D. Failure to complete quarterly monitoring	
	E. Revised monitoring requirements	
r.	Compliance requirements for bromate	144
s.	Compliance requirements for chlorite	
t.	Compliance requirements for chlorine/chloramines	
	A. Running annual arithmetic average	
	B. Alternating use of chlorine and chloramines	
u.	Compliance requirements for chlorine dioxide	
	A. Acute violations	
	B. Non-acute violations	145
v.	Compliance requirements for DBP precursors	

5.	Surface Water Treatment	146
a.	Sampling requirements, unfiltered sources, 1/1/92	
	A. Fecal/ total coliform in source water, (Table 26)	
	B. Source water turbidity	
	C. Inactivation ratio parameters	147
	i. Temperature	
	ii. pH	
	iii. Contact time	
	iv. Residual disinfection concentration	
	v. Other disinfectants (CT Tables 27-34)	
	Tables 28-30	148
	Tables 31-32	149
	Tables 33-34	150
	D. Inactivation ratio calculation	
	i. One point of disinfectant application	
	I. Sole inactivation values	
	II. Successive inactivation values (Steps 1-3)	
	ii. Multiple points of disinfectant application	151
	E. Disinfectant con'c POE monitoring (Table 35)	
	F. Disinfectant con'c in distribution (sampling points)	
b.	General sampling requirements, filtered sources, 6/29/93	152
	A. Treated water turbidity	
	B. Actual CT value calculation	
	i. Temperature	
	ii. pH	
	iii. Contact time	
	iv. Concentration	
	v. Challenge studies	
	C. Inactivation ratio calculations	153
	D. Disinfectant con'c entering distribution	
	E. Disinfectant con'c in distribution	
	F. Membrane filter direct integrity testing	
c.	Inactivation credit for systems using disinfectants other than chlorine	
	A. Calculation of CT values	
	i. Multiple disinfection segments	
	B. CT values for chlorine dioxide and ozone	
	i. Treatment credit for chlorine dioxide (Table 36)	
	ii. Treatment credit for ozone (Table 37)	154
	C. Site specific study	
	D. Ultraviolet light	
	i. UV dose table (Table 38)	
	ii. Reactor monitoring	155
	iii. 95% of water must be treated	

d.	Surface water systems using conventional or direct filtration	
e.	Source water monitoring	156
	A. Initial round	
	i. Filtered water systems serving at least 10,000	
	ii. Unfiltered water systems serving at least 10,000	
	iii. Filtered water systems serving less than 10,000	
	I. <i>E. coli</i> monitoring avoidance	
	iv. Twice monthly sampling for filtered systems	
	I. Lake/reservoir sources	
	II. Flowing stream sources	157
	III. <i>E. coli</i> monitoring not conducted	
	IV. GWUDI systems	
	v. Unfiltered water systems serving less than 10,000	
	vi. Sampling more frequently	
	B. Second round	
	C. Monitoring schedule (Table 39)	
	D. Monitoring avoidance	158
	i. Filtered water systems providing 5.5-log	
	ii. Unfiltered water systems providing 3-log	
	iii. Providing treatment rather than monitoring	
	E. Seasonal plants	
	i. Sampling during operational period	
	ii. Plants that operate less than six months	
	F. New sources	
	i. Applicability	159
	ii. Second round start date	
	G. Failure to collect sample appropriately	
	H. Grandfathering monitoring data	
f.	Source water sampling schedules	
	A. Sampling schedule	
	i. Submittal schedule	
	ii. Department response	
	B. Sample collection period	
	i. Extreme conditions	
	ii. Inability to report a valid analytical result	160
	I. Replacement samples	
	II. Sample schedule revision	
g.	Source water sampling locations	
	A. Samples required for each treatment plant	
	B. Samples must be collected prior to chemical treatment	
	i. Approval for sample collection after treatment	
	C. Systems that recycle filter backwash	161
	D. Bank filtration	

	i.	Samples must be collected prior to bank filtration	
	ii.	Sample collection locations	
	E.	Multiple sources	
	i.	Combined sample tap availability before treatment	
	ii.	Combined sample tap before treatment unavailable	
	I.	Composite samples	
	II.	Separate sample analysis	
	F.	Additional requirements	162
h.		Grandfathering previously collected data	
	A.	Sample criteria	
	i.	Filtered water systems	
	B.	Sample analysis	
	C.	Sampling location	
	D.	Sampling frequency	
	i.	Time gaps	
	ii.	Sampling frequency variation	163
	E.	Reporting grandfathered results	
	i.	Intent to report grandfathered samples	
	ii.	Reporting schedule	
	I.	Data elements	
	II.	Certification	
	III.	Samples must be representative	
	IV.	Sample analysis	164
	F.	Abnormal source water conditions	
	G.	Sample rejection	
	i.	Test data	
6.		Microbiological contaminants	164
	a.	Monitoring for pathogens	
	b.	Coliform sampling	
	A.	Sample locations	
	B.	Sample volume	
	C.	Sampling frequency, Community	165
	D.	Sampling frequency, NC, NTNC, state regulated	
	E.	Sampling frequency, ground sources (Table 40)	
	F.	Sampling frequency, ground sources, less than 1,000 people	
	G.	Sampling plan	166
	H.	Sampling when turbidity exceeds 1 NTU	
	c.	Number of repeat sampling	
	A.	>1 sample/month	
	B.	.1 sample/month	
	d.	Location of repeat sampling	
	e.	Single service connection repeat sampling	
	f.	24-hour limit extension for repeat sampling	167

g.	Samples used for compliance	
h.	Coliform-positive repeat sampling	
i.	Additional 5 routine samples next compliance period	
	A. Waiver: Department makes site visit	
	B. Waiver: Department determines problem fixed	
j.	MCL exceedance, reporting and PN	168
k.	Invalidation of total coliform-positive samples	
	A. Improper lab analysis	
	B. Domestic or non-distribution system event	
	C. Not reflective of distribution water quality	
l.	Certified laboratory invalidation	169
m.	Minimum sample requirements	
n.	Routine repeat coliform-positive sample requirements	
o.	Waivers for repeat monitoring	
p.	Sanitary surveys, systems < five samples/month	
q.	Triggered source water monitoring	170
	A. Systems that do not provide 4-log treatment	
	B. Samples that are not invalidated	
r.	Triggered source water monitoring	
	A. The Department may extend the 24-hour limit	
	B. Source water monitoring plan	
	C. Use of repeat source samples	
	D. Samples must be collected prior to any treatment	
s.	Collection of five additional source water samples	171
t.	Purchasing water systems	
u.	Wholesale water systems	
	A. Notice from purchasing system	
	B. Notification to purchasing systems	
v.	Systems not required to conduct source water monitoring	
	A. Positive sample due to distribution system deficiency	
	B. Sample collected at location that will cause positive samples	
w.	Compliance monitoring for systems that provide 4-log treatment	
	A. Requirements	
	i. Collection of annual sample	172
	ii. Collection of samples from each groundwater source	
	B. Use of samples for GWUDI analysis	
	C. Additional source water assessment monitoring	
	i. Conditions	
	I. At least one positive groundwater source sample	
	II. Source susceptible to fecal contamination	
	III. Fecally contaminated aquifer	
	IV. Highly sensitive groundwater source	
	ii. Requirements	

	I.	12 consecutive monthly samples	
	II.	Standard sample volume	173
	III.	Analysis for <i>E. coli</i>	
	IV.	Collection of samples prior to treatment	
	V.	Collection of samples at the source	
	D.	Re-evaluation of a groundwater source	
x.		Invalidation of an <i>E. coli</i> -positive source sample	
	A.	Improper sample analysis	
	B.	Not related to source water quality	
y.		Response to Department invalidation	
z.		New groundwater sources	
7.		Radionuclides	173
a.		Gross alpha activity	
	A.	Initial monitoring	
	i.	Monitoring schedule	174
	ii.	New systems/sources	
	iii.	Departmental waiver	
	iv.	Grandparenting	
	v.	MCL exceedance	
	B.	Reduced monitoring	
	i.	Below detection limit	
	ii.	At or above detection limit	
	iii.	Above the MCL	
	iv.	Samples collected	175
	v.	MCL exceedance	
	C.	Compositing	
	D.	Substitution	
	i.	Not exceeding 5 pCi/L	
	ii.	Not exceeding 15 pCi/L	
	iii.	Confidence interval	
	iv.	Gross alpha in lieu of Radium-226/Uranium	
b.		Beta Particle/Photon radioactivity	
	A.	Vulnerable water systems	
	i.	Initial samples	
	ii.	Quarterly samples	
	iii.	≤ 50 pCi/L running annual average	
	B.	Contaminated water systems	176
	i.	Quarterly samples: beta emitters, etc	
	ii.	Quarterly samples: beta particle activity	
	iii.	5 sample composite: iodine-131	
	iv.	Annual monitoring: strontium-90	
	v.	Running average 15pCi/L	
	C.	Surveillance data substitution	

	D.	Potassium-40 beta particle	
	E.	Screening level exceedance	177
	F.	MCL exceedance	
c.		General monitoring requirements	
	A.	Departmental discretion	
	B.	Designated schedules	
	C.	Compliance	
	i.	MCL exceedance, running annual average	
	ii.	MCL exceedance, any one sample	
	iii.	All samples included	
	iv.	Compliance on samples collected	
	v.	< detection limit	
	D.	Invalidation	178
	E.	MCL exceedance, reporting, PN	
8.		Secondary contaminants	178
	a.	Routine monitoring not required	
	b.	When monitoring is required	
	A.	User complaints	
	B.	Proposed treatment	
	C.	Unreasonable risk to health	
	c.	Resampling	
	d.	SMCL Exceedance, follow-up measures	
	e.	Variances and permits	
9.		Monitoring of disinfectant residuals (record daily)	178
	a.	Sampling requirements	
	A.	Twice per week	179
	B.	At one or more representative points	
	C.	Frequency sufficient to detect variations	
	b.	Chlorination for other purposes	
	c.	DPD method	
	d.	Record keeping	
333-061-0040		Reporting and Record Keeping	179
1.		Reporting requirements	
	a.	Reporting potential contamination	
	b.	Reporting to Department	
	c.	Public notification	
	d.	Pathogens in water	
	e.	Filtered water supplier reporting	
	A.	Report the following	180
	i.	Turbidity >5 NTU	
	ii.	Waterborne disease outbreak	
	iii.	Disinfection residual concentration < 0.2 mg/l	
	B.	Conventional/direct; and other treatments	

i.	Turbidity measurements	
I.	Total filtered water measurements	
II.	Measurements ≤ limits	
III.	Measurements > 1.0 NTU	
IV.	Data and Value	
ii.	Maintain records for individual filters	
I.	> 1.0 NTU	181
II.	> 0.5 NTU, backwash/offline	
III.	> 1.0 NTU, 3 consecutive months	
IV.	> 2.0 NTU 2 consecutive months	182
iii.	Exceeds 1 NTU	
iv.	Exceeds maximum levels	
C.	Additional reporting	
i.	Individual filter monitoring	183
I.	Turb. > 1 NTU, 30 minutes	
II.	Turb. > 1 NTU, 3 months	
III.	Turb. > 2 NTU	184
f.	Unfiltered water supplier reporting on-site analyses	
A.	Monthly reporting to the Department	185
i.	Raw source water fecal/total coliform tests	
ii.	Daily "CT" calculations and parameters	
iii.	Daily "CT" determinations, Giardia	
B.	Annual reporting to the Department	
i.	Watershed control program	
ii.	On-site inspection summary	
g.	Special reporting for groundwater systems	
A.	Treatment failure for systems providing 4-log treatment	
B.	Corrective action	
C.	Total coliform-positive samples	
D.	Compliance monitoring for systems providing 4-log treatment	
h.	Lead/copper reporting requirements	
A.	Tap water: Pb/Cu, 90th percentile, parameters	
i.	Pb/Cu tap samples, site location etc.	186
ii.	Sampling certification	
iii.	WQP tap samples	
iv.	Documentation for sampling reduction	
v.	Documentation for sample invalidation	
vi.	90th percentiles for Pb and Cu tap samples	
vii.	Follow-up WQP monitoring	187
B.	Source water: lead/copper	
i.	Alternate sample site justification	
C.	Corrosion treatment reporting requirements	
D.	Source treatment reporting requirements	

E.	Public education program reporting requirements	
i.	Department notification	
I.	Delivery documentation	188
II.	List of notified entities	
ii.	Resubmittal of information	
iii.	Consumer notification	
F.	Additional sampling reporting requirements	
G.	New source/treatment notification	
H.	Entry Point subsets	
i.	Water supplier reporting on-site analyses	
j.	Public Notice submission to Department	189
k.	Reporting schedule	
A.	Disinfection byproducts (Table 41)	
B.	and Disinfectants (Table 42)	190
C.	DBP precursors/coagulation or softening (Table 43)	191
D.	Department discretion to determine compliance or monitoring	
l.	Notification to Department or County (sanitary survey report)	192
m.	Source water monitoring results for <i>Cryptosporidium</i> and <i>E. coli</i>	
A.	Data elements for <i>Cryptosporidium</i> analysis	
i.	Matrix spike samples	193
ii.	Samples with less than 10L filtered	
iii.	Samples with less than 100% examined	
B.	Data elements for <i>E. coli</i> analysis	
n.	<i>Cryptosporidium</i> protection	
A.	Sampling schedules	
B.	Bin classification	
C.	Mean <i>Cryptosporidium</i> level	
D.	Disinfection profiles and benchmarks	
E.	Microbial toolbox options	
o.	Uncovered reservoirs, reporting for microbial toolbox	
	Table 44	194
2.	Record maintenance	196
a.	Retention of records	
b.	Retention duration	
A.	Date, place, time, collector	
B.	Sample type	
C.	Laboratory analysis information	197
D.	Analytical method	
c.	Non-compliance actions	
d.	Sanitary survey information	
e.	Variances/permits	
f.	Disinfectant residual records	
g.	Lead/copper records	

h.	PN/certifications	
i.	Filter backwash water	
	A.	Recycle notification
	B.	Recycle flows and frequencies
	C.	Flow rates
	D.	Filter run lengths
	E.	Treatment
	F.	Operational data
j.	Special requirements for groundwater systems	198
	A.	Corrective actions
	B.	Public notice
	C.	Invalidation of <i>E. coli</i> -positive groundwater samples
	D.	Purchasing water systems with total coliform-positive
	E.	Compliance monitoring
	i.	Minimum disinfectant residual
	ii.	Lowest daily disinfectant residual
	iii.	Membrane filtration and alternative treatment
k.	Disinfection profiles	
l.	<i>Cryptosporidium</i> protection	
	A.	Source water monitoring results
	B.	Notification that a system will not conduct monitoring
	C.	Treatment associated with microbial toolbox options
m.	Records relating to an IDSE	199
3.	Records kept by the Department	199
	a.	Turbidity
	b.	Disinfectant residuals
	c.	Consultation decisions
	d.	Alternative filtration technologies
	e.	Filter self-assessments or CPEs
	f.	Determinations on control of disinfectants and DBPs
	A.	GAC or membrane technology
	B.	Alternative minimum TOC removal requirements
	C.	Conventional treatment/alternative compliance criteria
	D.	IDSE and operational evaluations
	i.	IDSE monitoring plans
	ii.	IDSE reports
	iii.	Operational evaluations
	g.	Monitoring plans
	h.	Specific decisions by Department
	A.	Records kept for 40 yrs
	i.	Decisions on modifications
	i.	<i>Cryptosporidium</i> protection
	A.	Source water monitoring results

	B.	Bin classification	
	C.	Change in treatment requirements	
	D.	Mean <i>Cryptosporidium</i> level	
	E.	Treatment processes and control measures	201
	j.	Systems with uncovered finished water storage facilities	
333-061-0042		Public Notice	201
1.		PN Requirements for violations/situations	201
	a.	Purchasing systems	
	b.	Limiting distribution of PN	
	c.	Department notification	
2.		PN tiers, requirements	201
	a.	Tier 1, acute exposure violations/situations	
		A. Fecal/ <i>E. coli</i> MCL/MR	
		B. Nitrate/Nitrite MCL	
		C. Chlorine dioxide MRDL/MR	
		D. Turbidity MCL	202
		E. SWTR/IESWTR treatment technique	
		F. Waterborne disease outbreak	
		G. <i>E. coli</i> in groundwater source samples	
		H. Other violations/situations	
	b.	Tier 2, chronic exposure, violations/situations	
		A. MCL, MRDL, TT not under Tier 1	
		B. Monitoring/testing procedure not under tier 3	
		C. Variance/permit conditions	
		D. Sanitary survey, CPE reports	
		E. Emergency GW sources	203
	c.	Tier 3, other violations/conditions	
		A. Monitoring violations not Tier 1 or 2	
		B. Testing procedures not Tier 1 or 2	
		C. Operation under variance/permit	
		D. Availability of UCMR results	
		E. SMCL for fluoride	
		F. Disinfection profiling/benchmarking	
	d.	Department discretion	
3.		PN form, manner and frequency	203
	a.	Tier 1, requirements	
		A. 24 hours	
		B. Department consultation	
		C. Additional notification	
		D. Form and manner	
		i. Broadcast media	
		ii. Posting	
		iii. Hand delivery	

	iv. Other methods	
b.	Tier 2, requirements	204
	A. 30 days	
	B. Posting	
	C. Repeat notification	
	D. Turbidity	
	i. MCL for turbidity	
	ii. SWTR/IESWTR TT	
	E. Form and manner	
	i. CWS	
	I. Mail/direct delivery	
	II. Other methods	
	ii. NCWS	205
	I. Posting	
	II. Other methods	
c.	Tier 3, requirements	
	A. 1 year	
	B. CCR	
	C. Form and manner	
	i. CWS	
	I. Mail/direct delivery	
	II. Other methods	
	ii. NCWS	206
	I. Posting	
	II. Other methods	
4.	Content of Public Notice	206
a.	PN inclusions for violation/situation	
	A. Description	
	B. When	
	C. Adverse health affects	
	D. Population at risk	
	E. Alternative water supplies	
	F. Consumer actions	
	G. Corrective action	
	H. Return to compliance	
	I. Water system contact	
	J. Distribution encouragement	
b.	Under variance/permit	
	A. PN Contents	
	i. Explanation of reason	
	ii. Date	
	iii. Status report	207
	iv. Public input	

	B.	Violation of condition of variance/permit	
c.		Public notice presentation	
	A.	Requirements	
		i. Conspicuous display	
		ii. Technical language	
		iii. Formatting	
		iv. Misleading language	
	B.	Multilingual requirements	
		i. Determined non English speaking	
		ii. Undetermined non English speaking	
d.		Standard language	
	A.	Health effects	
	B.	M/R special language	
	C.	Language to encourage	208
5.		New billing units/customers	208
	a.	CWS	
	b.	NCWS	
6.		Unregulated contaminants	208
	a.	CWS, NTNCWS, 12 months	
	b.	Form and manner	
7.		SMCL for fluoride	208
	a.	CWS	
	b.	New billing units/customers	
	c.	Form and manner	209
	d.	Specific language	
8.		Special notice for groundwater systems	209
	a.	Significant deficiency or <i>E. coli</i> -positive source samples	
	b.	Non-community systems	210
		A. Nature of the significant deficiency	
		B. Corrective action plan	
		C. Non-English speaking consumers	
	c.	Corrected deficiencies	
9.		Special notice relating to <i>Cryptosporidium</i> monitoring	
	a.	Repeated failure to monitor	
	b.	Failure to determine bin classification/mean level	
		A. Repeating the notice	211
		B. Department approved schedules	
	c.	Form and manner	
	d.	Specific language	
		A. Repeated failure to monitor	
		B. Failure to determine bin classification/mean level	
		C. Actions taken by the water system	
10.		Public notice by Department	212

333-061-0043 Consumer Confidence Reports	212
1. Delivery Deadlines	
a. Existing Community PWSs	
b. New Community PWSs	
c. Purchasing PWSs	
A. Deadlines	
B. Mutually agreed upon date	
2. Content of the Reports	212
a. Mandatory information	
b. Water source	
A. Type of water source	
B. Common source name and location	
c. Source water assessment report	
d. Mandatory definitions	
A. MCLGs	213
B. MCLs	
C. Variances	
D. Treatment techniques/action levels	
i. Treatment technique	
ii. Action level	
E. MRDLGs	
F. MRDLs	
3. Detected Contaminants:	213
a. Mandatory information	
A. Regulated contaminants (MCL, AL, MRDL, TT)	
B. Unregulated contaminants	
b. Data tables	
c. Data collected from previous year	
A. Current sampling data	214
d. Detected regulated contaminants report contents	
A. MCL	
B. MCLG	
C. AL/TT	
D. MCL- highest contaminant level/range	
i. Frequency annually or less	
ii. Running annual average-all samples	
iii. Running annual average-system wide	
iv. Rounding, conversion table (Table 45)	215
e. Turbidity	219
A. Highest monthly value	
B. Highest single measurement/lowest monthly %	
f. Lead and Copper	
g. Total coliform	

	A.	Highest monthly # positives <40 samples	
	B.	Highest monthly % positives ≥ 40 samples	
h.		Fecal coliform	
i.		Possible contaminant sources	
j.		Hydraulically independent distribution systems	
k.		Violation explanations/health effects	
l.		Unregulated contaminants	220
m.		Cryptosporidium, radon, etc.	
	A.	Crypto: ICR etc.	
		i. Results	
		ii. Explanation	
	B.	Radon:	
		i. Results	
		ii. Explanation	
	C.	Other contaminants:	
		i. Results	
		ii. Explanation, contaminant info (Table 46)	220
n.		Compliance with OAR 333-061 203	238
	A.	Monitoring and reporting	
	B.	Filtration and disinfection	
	C.	Lead and copper	
	D.	Acrylamide and epichlorohydrin	239
	E.	Record keeping	
	F.	Special monitoring	
	G.	Variance, administrative/judicial orders	
o.		Variances	
	A.	Explanation	
	B.	Issue date	
	C.	Status report	
	D.	Public input	
p.		Additional Information	
	A.	Brief explanation in report	
		i. Drinking water sources	
		ii. Possible source contaminants	
		I. Microbial	
		II. Inorganic	
		III. Pesticides	
		IV. Organic	240
		V. Radioactive	
	iii.	EPA/FDA regulations	
	iv.	EPA-SDW-hotline	
	B.	Water system phone number	
	C.	Non-English speaking residents	

	D.	Public participation	
	E.	Public education inclusion	
4.		Required additional health information	240
	a.	Mandatory language	
	b.	Nitrate	241
		A.	EPA statement
		B.	Optional statement
	c.	Lead	
		A.	EPA statement
		B.	Optional statement
5.		Special requirements for groundwater systems	241
	a.	Notice of significant deficiency or <i>E. coli</i> -positive source sample	
		A.	Nature of the significant deficiency
		B.	Source fecal contamination
		C.	Corrective action plan
		D.	Required health effects language
	b.	Corrected deficiencies	
6.		Report delivery and recordkeeping	242
	a.	Direct delivery or mail	
	b.	Good faith effort to reach consumers	
	c.	Reporting to the Department	
	d.	Reporting to other agencies	243
	e.	Report is public information	
	f.	≥ 100,000 population-Internet posting	
	g.	Governor Waiver	
		A.	Waiver conditions
			i.
			Local newspaper
			ii.
			Customer notification
			iii.
			Public availability
		B.	≤ 500 population waiver
	h.	Records kept for 5 yrs	
333-061-0045		Variations	243
1.		MCL and treatment variance conditions	
	a.	Alternative sources	
	b.	No unreasonable risk to health	
	c.	Best available technology	
	d.	Quarterly user notification	
	e.	Compliance schedule	
	f.	Interim control measure plan	244
2.		Documentation of findings (Department)	244
	a.	Rationale	
	b.	Rationale discussion	
	c.	Time schedule	

3.	Denial by Department	244
4.	Public hearing	244
5.	Non-compliance with variance	244
6.	VOC variance	244
	a. Best available technology	
	b. Other treatment technologies	
	c. Compliance schedule for feasible treatment	245
	d. Bottled water/point-of-use/entry devices	
7.	Fluoride variance	245
	a. Available and effective treatment	
	b. Seven treatment methods	
	c. Department required treatment	
8.	Bottled water	246
	a. Department approved monitoring program	
	b. Approved source	
	c. Sufficient quantities	
9.	Point-of-use devices	246
	a. Operation and maintenance	
	b. Department approved plan	
	c. Bacteriological safety	
	d. Adequate evidence of performance	
	e. Control of heterotrophic bacteria	
	f. Every building protected	247
10.	Bottled water/point-of-use devices	247
11.	Microbiological "Biofilm" variance	247
	a. Compliance with SWTR	
	b. No coliform history at entry to distribution	
	c. Compliance with turbidity MCL	
	d. Detectable chlorine residual in distribution	
	e. No disease outbreak history	
	f. Regular contact with Department	
	g. Compliance with Coliform rule	
	h. Compliance with last sanitary survey	
	i. Compliance with cross connection control requirements	
	j. Biofilm control program	
	k. HPC monitoring	
	l. Approved microbiological sampling plan	248
12.	Surface/GW under surface water influence variance	248
13	Variances for treatment techniques	248
	a. Raw water quality	
	b. Monitoring and other requirements	
333-061-0046 Permits		248
1.	Issuance	248

a.	Water system existing and operational	
b.	Water system unable to comply with MCLs	
c.	No previous variance	
2.	Conditional permits	248
a.	Alternative sources	
b.	Management/restructuring changes	
c.	Capital improvements	
d.	Financial assistance	
e.	Regional water system	
f.	No health risk	
g.	Quarterly notice	
h.	Compliance schedule	249
3.	Processing procedures	
4.	Permit requirements	
5.	Alternate microbiological and treatment requirements	
6.	Department documentation	
a.	Funding alternatives	
A.	Rate structure/accounting change, etc.	
B.	Department capacity development strategy	
C.	Consolidation	
b.	Alternative water sources	
7.	Population \leq 3300 with financial assistance	249
	333-061-0050 Construction Standards	250
1.	General	250
a.	Application	
b.	Pre-existing systems	
A.	Built prior to 8/21/81	
B.	Continual use as PWS	
c.	Private water system conversion	
d.	Exclusion of contamination	
e.	NSF Standard 61	
f.	New and used materials	
g.	Plan review	251
h.	Waivers from standards	
i.	Wellhead protection program	
j.	New GW sources (GWUDI)	
2.	Groundwater (Wells):	251
a.	Wells	
A.	Wells defined	
B.	100 ft. radius	
C.	Public easements	
D.	Reduction of radius to 50 ft.	
E.	Public/private roadways within 100 ft.	

F.	Contamination sources	252
G.	Flooding	
H.	WRD well construction standards	
I.	Wells < 12' deep	
J.	Water quality reports	
K.	Treatment when MCL is exceeded	
L.	Pump installations, piping, well house	253
	i. Pump bearings	
	ii. Sanitary well seal	
	iii. Casing vent	
	iv. Water depth measurement	
	v. Sampling tap	
	vi. Pump to waste piping	
	vii. Flow metering	
	viii. Concrete slab	
	ix. Grading	
	x. Casing above grade	
	xi. Well house	
	xii. Pump removal provision	
	xiii. Pitless adapters	
M.	Public health threats	
N.	Unconfined aquifers	254
O.	Documentation	
	i. Pumping tests	
	ii. Lab tests	
	iii. Performance data	
	iv. Disinfection proposals	
	v. GWUDI	
b.	Springs	
	A. Well requirements and the following:	
	i. Intercepting ditch	
	ii. Fence	
	iii. Springbox	
	iv. Overflow, etc.	
	v. Collection facilities	
	B. Reports of flow tests	
3.	Surface water source facility	254
	a. Site selection: Infiltration gallery and direct intakes	
	b. Water rights	255
	c. Impounding reservoirs	
	A. Capacity	
	B. Outlet piping	
	C. Drains	

d.	Direct intake structures	
A.	Screens	
B.	Cleaning	
C.	Motors/controls above flood level	
D.	Swimming restrictions	
E.	Valves	
4.	Water treatment (other than disinfection)	255
a.	General	
A.	Capability to meet MCLs	
B.	Raw water investigations	
C.	Deep wells	
D.	Laboratory equipment provided	256
b.	Best available technology	
A.	Pilot studies	
B.	VOCs	
i.	Packed tower aeration	
ii.	GAC	
C.	Fluoride	
i.	Activates alumina	
ii.	Reverse osmosis	
D.	Total coliform	
i.	Well construction and placement	
ii.	Disinfectant residuals	
iii.	Distribution and reservoir operation	
iv.	Filtration and/or disinfection treatment	
v.	Wellhead protection program	257
E.	Organic chemicals	
i.	Packed tower aeration	
ii.	GAC	
iii.	Oxidation	
F.	Inorganic chemicals	
i.	Coagulation/filtration	
ii.	Direct/diatomite filtration	
iii.	GAC	
iv.	Activated alumina	
v.	Ion exchange	
vi.	Lime softening	
vii.	RO	
viii.	Corrosion control	258
ix.	Electrodialysis	
x.	Alkaline chlorination	
xi.	Coagulation-assisted microfiltration	
xii.	Oxidation/filtration	

	xiii.	POU Activated Alumina	
	xiv.	POU RO	
G.		Disinfection byproducts	
	i.	TTHM and HAA5	
	ii.	Bromate	
	iii.	Chlorite	
	iv.	TTHM and HAA5 for source water disinfection	
	v.	TTHM and HAA5, purchasing systems $\geq 10,000$	
	vi.	TTHM and HAA5, purchasing systems less than 10,000	
H.		Disinfectant levels	259
I.		Radionuclides	
	i.	Ion exchange	
	ii.	RO	
	iii.	Lime softening	
	iv.	Coagulation/filtration	
	v.	Activated Alumina	
	vi.	Greensand filtration	
	vii.	Electrodialysis	
	viii.	Hydrous manganese oxide	
	ix.	Barium co-precipitation	
	x.	POU Ion exchange	
	xi.	POU RO	
c.		Filtration; surface and GWUDI	225
	A.	General	
	B.	4 filtration methods	260
	C.	Pilot studies	
	D.	Minimum disinfection	
	E.	Filter design	
	F.	Turbidity monitoring for multiple filters	
	G.	Membrane filtration	261
	H.	Challenge study for membrane filtration	
	i.	Removal efficiency	
	ii.	Maximum removal efficiency	
	I.	Challenge testing	
	i.	Testing module	
	ii.	Surrogate particle	
	iii.	Maximum feed water concentration	
	iv.	Representative hydraulic conditions	262
	v.	Removal efficiency, membrane module	
	vi.	Removal efficiency, membrane filtration process	
	vii.	Quality control release value	
	viii.	Modifying a previously tested membrane	263
	J.	Direct integrity testing	

	i.	Independent application to each membrane unit	
	ii.	Resolution of 3 micrometers or less	
	iii.	Sensitivity	
		I. Applied pressure vacuum	
		II. Particulate or molecular markers	264
	iv.	Control limit	
	v.	Results	
	vi.	Frequency	
	K.	Indirect integrity monitoring	
	i.	Filtrate turbidity monitoring	
	ii.	Frequency of 15 minutes intervals	
	iii.	Continuous monitoring on each membrane unit	
	iv.	Filtrate turbidity readings above 0.15 NTU	265
	v.	Department-approved alternative parameters	
	L.	Challenge Study requirements for Bag and Cartridge Filtration	
	i.	Removal efficiency demonstration	
	ii.	Design of testing	
	iii.	Surrogate particle	
	iv.	Maximum feed water concentration	
	v.	Maximum design flow rate	266
	vi.	Filter evaluation pressure drop	
	vii.	Removal efficiency	
	viii.	Challenge duration	
	ix.	Fewer than 20 filters tested	
	x.	Modifying a previously tested filter	
d.		POE and POU devices	
	A.	Application	267
	B.	Operation responsibility	
	C.	Monitoring	
	D.	Construction plans	
	i.	Pre approval	
	ii.	HPC growth	
	iii.	Evaluation (corrosion, Pb/Cu)	
	E.	All customers protected	
5.		Facilities for continuous disinfection	268
	a.	Minimum chlorination requirements	
	b.	Chlorination of springs	
	c.	Design of chlorination systems to meet 333-061-0032	
	A.	Capability to treat pathogens	
	B.	Dose proportional to flow	
	C.	Residuals	
	D.	Contact time	
	d.	General design of chlorination systems	

	A.	4-log inactivation	
	B.	Contact time	269
		i.	Free chlorine
		ii.	Chloramines
	e.	Low chlorine alarm	
	f.	Sampling taps	
	g.	Testing equipment	
	h.	Backflow prevention	
	i.	Proportion to flow	
	j.	Chlorine gas storage	
		A.	Enclosures
		B.	Gas cylinders
		C.	Doors, ventilation
		D.	Building ventilation
		E.	Electrical switches
		F.	Scales
		G.	Gas mask
	k.	Ultraviolet Light Disinfection	270
		A.	Dosage requirement
		B.	UV lamps insulated
		C.	Flow rate control
		D.	Visual inspection
		E.	Pressure
		F.	Weather proofing
		G.	Lamp replacement
		H.	Shut-off valves
		I.	Reactor validation testing
		i.	Validated operating conditions
		ii.	Validation testing
		iii.	Alternative approach
		J.	NCWS Class
6.		Finished water storage	271
	a.	Construction requirements - reservoirs	
		A.	Materials
		B.	Soils
		C.	Steel tanks - AWWA
		D.	Concrete reinforcement
		E.	Wood tanks
		F.	New redwood tank start-up
		G.	Footing drains
		H.	Fire protection
		I.	Roofs
		J.	Access manhole
			272

	K.	Ladders	
	L.	Screened vents	
	M.	Drain, overflow	
	N.	Silt stop	
	O.	Inlet/outlet piping	
	P.	Fencing	
	Q.	Coatings	
	R.	Tracer studies	
	S.	Effluent flow rate (contact time)	
	b.	Pressure tanks	
	A.	Installed above grade	
	B.	Bypass piping	
	C.	Access manhole	273
	D.	Pressure tank provisions	
	E.	Pressure tank construction	
7.		Pumping facilities	273
	a.	Booster pumps	
	b.	Low-pressure cut-off	
	c.	Suction lift	
	d.	100 year flood level	
	e.	Durable construction	
8.		Distribution systems	273
	a.	Easements	
	b.	AWWA, NSF standards	
	c.	Application, community systems	
	d.	Application, non-community systems	274
	e.	Minimum pressure	
	f.	Bedding, backfill/depth of cover	
	g.	Thrust restraint	
	h.	Looping	
	i.	Air-relief valves	
	j.	Yarn, oakum, lead packing	
	k.	Locator wires(non conductive pipe)	
	l.	Contact time evaluation	
9.		Crossings - Sanitary sewers and water lines	274
	a.	Sanitary sewers	
	b.	Parallel installations	
	c.	Crossing separations	
	A.	Water line 1.5 ft. above sewer line	275
	B.	Water line less than 1.5 ft. above sewer	
	C.	Water line under sewer	
	d.	Stream crossings (Fig. 1: water/sewer line separation)	
10.		Disinfection of facilities	276

a.	Disinfection required	
b.	Cleaning/flushing	
c.	Well, valves, pumps, water lines	
d.	Reservoirs/tanks	277
A.	≥ 10 mg/l, 6-24 hours	
B.	50 mg/l, 6 hours	
C.	200 mg/l	
e.	Draining tank	
f.	Filling tank	
g.	Chlorine residual, coliform test	
h.	Underwater divers	
i.	Disinfection, distribution returned to service	
A.	Customer meters were shut off	
B.	Construction area dewatered	
C.	Exposed pipe treated with hypochlorite solution	
D.	Item affected by the repair disinfected	278
E.	Water line was flushed thoroughly	
F.	Microbiological analysis	
333-061-0055	Waivers from Construction Standards	278
1.	Compliance overly burdensome	
2.	Public/private interest	
3.	Alternate measures meet MCLs	
333-061-0057	Voluntary Drinking Water Protection Program	278
1.	WHPP requirements for certification	
2.	WHPA delineation	
a.	Source water assessment program	
b.	Requirements	
A.	Minimum TOT	
B.	Licensed professional	
C.	Groundwater model	
D.	WHPA submittal	279
E.	Department acknowledgment	
F.	Minimum techniques	
c.	Springs	
d.	Wells	
A.	Pump rate	
i.	Monthly highest usage	
ii.	Comparable community	
iii.	Design capacity	
iv.	Safe yield	
v.	200 gallons per day	
B.	≤500, method	
C.	501-3,300, methods	

	D.	>3,300, methods	280
	E.	3,301-50,000, methods	
	F.	>50,000, methods	
	e.	Susceptibility analysis	
	f.	Delineation update	
		A. Pumping rate change	
		B. Recharge change	
		C. Other wells	
3.		New groundwater sources	280
	a.	New sources	
		A. Outside WHPA	281
		i. Provisional Delineation	
		ii. Delineation	
		B. Inside WHPA	
		i. Delineation	
		ii. Plan modification	
		C. Construction standards	
	b.	Future sources	
4.		Contingency planning	281
	a.	Key elements	
		A. Inventory	
		B. Water usage	
		C. Response anticipation	
		D. Personnel	
		E. Source replacement	
		F. Conservation	
		G. Plan testing	
		H. Training	
		I. Public education	
		J. Logistical/financial resources	
	b.	Coordination	282
			282
		333-061-0058 Wellfield Determination	
1.		Wellfield defined	
2.		Criteria	
	a.	≤2,500 ft	
	b.	Same aquifer	
3.		Data submission	
	a.	Schematic	
	b.	Land use activities	
	c.	Pumping patterns	
4.		Susceptibility analysis alternatives (Table 47)	282
5.		2-year TOT	283
6.		Sampling point designation	

333-061-0060 Plan Submission and Review Requirements

283

- 1. Plan submission
 - a. Plans submitted prior to construction
 - b. Engineered plans
 - c. Contents
 - A. Detail, specifications, overall plan
 - B. Water quality data
 - C. Vicinity map
 - D. Owner/operator
 - E. Cleaning/disinfection procedures
 - d. Well installation information
 - e. SW/GWUSWI disinfection changes/chloramines, ozone 284
 - A. Point of application
 - B. Disinfectants
 - C. Disinfection process
 - D. Other modifications
 - f. Disinfection benchmark calculation
 - A. *Giardia* inactivation
 - B. Lowest monthly value 285
 - C. Requirements
 - i. Monitoring frequency
 - ii. Determination through entire plant
 - iii. Protocol approved by the Department
 - g. Disinfection benchmark (viral) 285
- 2. Plan review 285
 - a. Department review/approval
 - b. Compliance certification statement
 - c. Emergency repairs
- 3. Plan review fees (**Table 48**) 285
- 4. Plan review exemption 286
 - a. Exemption requirements
 - A. Master plan
 - B. Certification of conformance to standards
 - C. Annual summary of projects
 - D. Qualified staff
 - b. Further exemption
 - c. Non-community licensed facility exemption
- 5. Master Plans 286
 - a. Requirement (≥ 300 connections), PE
 - b. Twenty year evaluation 287
 - A. Overall plan summary
 - B. Existing system description
 - C. Water quality, level of service

	D.	Projected growth rate	
	E.	Engineering evaluation	
	F.	Alternative engineering solutions	
	G.	Financing alternatives	
	H.	Recommended improvement program	
	I.	Water management and conservation plans	288
	c.	DHS, DLCDC compliance	
333-061-0061		Technical, Managerial and Financial Capacity, New PWSs	288
1.		Capacity defined	
2.		New water system requirements	
	a.	October 1,1999	
	b.	Technical capacity requirements	
	A.	Land use requirements	
	B.	Plan review/submission	
	C.	Water rights	
	D.	Water quality tests	
	E.	Metering	
	F.	Master plans	
	c.	Managerial capacity requirements	289
	A.	Certified operator	
	B.	Water management/conservation plans	
	d.	Financial capacity requirements	
3.		Water systems applying for SRF loans	289
	a.	Capacity assessment	
	b.	Deficiencies corrected	
	A.	Major deficiencies	
		i. Technical	
		ii. Managerial	
		iii. Financial	
	B.	Loan conditions	
		i. Technical	290
		ii. Managerial	
	C.	Short-term deficiencies	
		i. Technical	
		ii. Managerial	
	D.	Deficiencies corrected with loan	
	E.	Other deficiencies	
	c.	Funding to correct deficiencies	
4.		Other water systems	290
	a.	All CWS, NTNC and TNC water systems	
	A.	Components of capacity assessment	
	B.	Capacity assessment frequency	291
	C.	Correction recommendations	

333-061-0062 Land Use Coordination	291
1. Purpose	
2. Requirements	
a. New public water systems	
b. Additions, alterations, extensions	
c. New water sources	
d. Relocation of treatment/storage facilities	
3. Statewide planning goal compatibility	291
4. Goal compliance findings by the Department	
5. Plan approval documentation	
a. Local land use permit	292
b. Written information from local planning authority	
c. Other written information	
6. Adoption of findings	292
7. Multiple land use approval authority	
8. Master plan inclusion	
9. Incorporated definitions	
333-061-0063 Environmental Review Process for the Safe Drinking Water Revolving Loan Fund Program	292
1. Overview:	
a. Environmental review rule authority	
A. Request for categorical exclusion	293
B. Environmental information document (EID)	
C. Environmental impact report (EIR)	
2. Categorical exclusions:	293
a. Definition of actions:	
A. Minor rehabilitation	
B. Sewered communities 10,000 or less	
C. Unsewered communities 10,000 or less	
b. Categorical exclusions not granted, land use compatibility	
c. Revocation	
d. Public notification	294
3. Environmental review process:	
a. EID or EIR preparation	
b. Applicable law evaluation	
c. Evaluation of impacts and mitigation	
d. EID draft review; environmental assessment; FNSI	
e. EIR requirements:	
A. Public meeting	
B. Draft EIR	295
C. Final EIR	
D. Department approval	
4. Implementation of mitigation measures	

5.	Partitioning of environmental review	
6.	Waiver; Validity	295
	a.	Waiver discretion
	b.	Validity duration
333-061-0064	Emergency Response Plan and Water System Operations Manual Requirements	295
1.	Emergency operations plan	
	a.	Schedule (population)
	A.	>100,000
	B.	50,001-100,000
	C.	3,301-50,000
	D.	≤ 3,300
	E.	SRF loans
	b.	Certification of completion
	c.	Security vulnerability assessments
	d.	County emergency response coordinator
	e.	Plan components
	A.	Communications and authority
	i.	Contacts list
	ii.	Decision making authority
	iii.	Agency notification
	B.	Water system security
	C.	Water System hazard review
	i.	Annual inspection
	ii.	Deficiency correction
	D.	Emergency equipment/supplies
	i.	Auxiliary power
	ii.	Emergency water
	E.	Emergency response procedures
	i.	Develop procedures
	ii.	Mitigate emergency impact
	iii.	Emergency disinfection/disease outbreak
	f.	Instruction /training
333-061-0065	Operation and Maintenance	297
1.	Responsibilities	
	a.	Effective operation
	b.	Leaks/equipment repaired promptly
	c.	Proper equipment, meet construction standards
	d.	Emergency actions
		298
2.	Personnel	
	a.	Experience and training
	b.	Operator certification program
	c.	Non-community systems, surface sources

3.	Ownership identification	298
4.	Water system operations manual	
	a. Schedule for completion	
	b. Certification of completion	
	c. Manual elements	
	A. Source	
	B. Water treatment	
	C. Reservoirs	
	D. Distribution system	299
	E. On-site operator protocols	
	d. Instruction/training	
5.	Documents and records	299
	a. Retained and available to Department	
	A. As built plans	
	B. Operating manuals	
	C. Current master plan	
	D. Production capabilities	
	E. Service connections	
	F. Raw water quality reports	
	G. Chemicals and dosage rates	
	H. Maintenance	
	I. Sampling and analytical reports	
	J. Disinfectant residuals	
	K. Cross connection control	
	L. Customer complaints	
	M. Fluoridation records	
	N. Other records	
6.	Chlorination and use of other chemicals	299
	a. Operation and maintenance responsibilities	
	b. Chlorine use requirements	
	A. Proportional to flow	
	B. 0.2 mg/l free residual/30 minutes contact	
	c. Chloramines, 2.0 mg/l combined residual/3 hrs.	300
	d. Corrosion control location	
7.	Emergency notification of Department	
	333-061-0070 Cross Connection Control Requirements	300
1.	Cross Connection Control Program	
2.	Responsibility	
3.	Minimum requirements	
4.	Coordination	
5.	Inspections	300
	a. Initial inspection	
	b. Annual	

c.	Less than annually	
d.	Backflow incident	
e.	Replumbing	
6.	Air gap backflow assembly repair	
7.	Notification if adding chemical/substance	301
8.	Premise isolation requirements	
a.	Table 49 listed premises	
A.	Non table 49 premises	
B.	In-premise device	
b.	Requirements	
A.	Water Supplier	
i.	Location	
ii.	Alternate location	
iii.	Thermal expansion	
B.	Premise owner	
i.	Alternate location – no cross connection	
ii.	Tester maintenance and repair	
c.	Unique conditions	
d.	Oregon Plumbing Specialty Code Dwellings	
A.	Installation	302
B.	Thermal expansion	
C.	Testing maintenance repair	
9.	Local Cross Connection Program	302
a.	Community Enabling authority	
A.	Failure to remove	
B.	Failure to install	
C.	Failure to maintain	
D.	Failure to test	
b.	Written program Community WS with 300 or more	
A.	List of Premise	
B.	Certified staff list	
C.	Evaluating procedures	
D.	Notification procedures	
E.	Degree of hazard	
F.	Corrective actions	
G.	Records	
H.	Public education	
c.	Annual Summary Report (ASR)	303
d.	Cross Connection specialist	
10.	Fees (schedule)	303
a.	Billing invoices	
b.	Payable to DHS	
c.	Late fee	

11.	Non-community systems	303
	a. Ensure no cross connections exist	
	b. Installation	
	c. Survey	
12.	Approved assemblies	303
13.	Grandparented assemblies	
14.	Tester test conformance	304
15.	Department-certified testers	
	a. 10 working days	
	b. Approved manner/form	
16.	OPSC approved installation	
17.	Advisory Board	304
	a. Plumber	
	b. Tester	
	c. Specialist	
	d. Water Suppliers	
	e. General plumber	
	f. Instructor	
	g. Manufacturer	
	h. Engineer	
	i. Plumbing inspector (Tables 49 and 50)	304
333-061-0071 Backflow Assembly Installation Standards		305
1.	Installation	
	a. USC Approved list	
	b. Submersion	306
	c. Compliance with OPSC	
2.	Premise Isolation installation	
	a. Location	
	b. Alternate location	
	c. No cross connection	
3.	Bypass piping	
	a. Level of protection	
	b. Meets requirements	
4.	OPSC approved fire suppression systems	306
5.	Stand alone fire suppression systems	
6.	Stand alone irrigation systems	
7.	An AVB Shall: (AVB diagram)	306
	a. No shut off	
	b. Corrosive atmospheres	
	c. Flooding	
	d. Minimum height	
	e. Intermittent use	
	f. OPSC approved	

g.	Not pressurized	
h.	Backsiphonage only	
8.	PVB or SVB shall: (PVB/SVB diagram)	307
a.	Minor water discharge	
b.	Spacing	
c.	Flooding	
d.	Minimum height	
e.	No backpressure	
f.	Backsiphonage only	
9.	DC or DCDA shall: (DC/DCDA diagram)	308
a.	Clearances	
b.	Installation	
c.	Below grade installation	
d.	Maximum clearances	
e.	Reduced clearances	
f.	Adequate drainage	
g.	Freeze protection	
h.	Backsiphonage/backpressure	
10.	RV or RPDA shall:(RP/RPDA diagram)	309
a.	Clearances	
b.	Installation horizontally	
c.	100 Year flood	
d.	Relief valves	
e.	Freeze protection	
f.	Air gap drain	
g.	Adequate drainage	
h.	Reduced clearances	
i.	Maximum clearances	
j.	Backsiphonage/backpressure	
	333-061-0072 Backflow Assembly Tester Certification	309
1.	Certification	
a.	Journeyman plumbers	310
b.	Training course	
2.	Initial Certification	
a.	Completion of training	
b.	Satisfactory completion of exams	
	A. Minimum score written	
	B. Minimum score performance	
	C. Approved list	
c.	CCB/LCB	
d.	High school diploma	
e.	Completed application	
f.	Application fee	

3.	Certification renewal	310
	a. Certificate expiration	
	b. CEUs	
	c. Satisfactory exam completion	
	A. Minimum score written exam	311
	B. Minimum score physical performance exam	
	C. Approved list	
	d. CCB/LBC	
	e. Test gauge calibration	
	f. Renewal form	
	g. Application fee	
	h. Without reinstatement fee	
	i. Renewal failure	
4.	Reciprocity	311
	a. Current certification	
	b. Tester renewal class	
	A. Minimum score written exam	
	B. Minimum score physical performance exam	
	C. Approved list	312
	c. CCB/LCB	
	d. High school diploma	
	e. Test gauge	
	f. Reciprocity form	
	g. Application fee	
5.	Fees	312
	a. Method of payment	
	b. Refunds	
	c. Fee schedule	
	A. Initial	
	B. Renewal	
	C. Reciprocity review/initial	
	D. Reinstatement/renewal	
	E. Combination	
	d. Prorating	
	e. Combination certificate/renewal fee	
6.	Enforcement	312
	a. Denial	
	A. False Information	
	B. Revocation	
	C. Unauthorized certificate use	
	D. Failed to perform tests	
	E. Falsification of report	
	F. CCB/LCB	313

	G.	Failed to comply with regulations	
	H.	Uncelebrated gauge	
	b.	Appeal process	
	c.	Reapplication for certification	
	d.	Denial of application	
	e.	Reports available for review	
333-061-0073		Cross Connection Inspector Certification	313
1.		General	
2.		Initial certification requirements	313
	a.	Applicants	
		A. Minimum score written exam	
		B. Approved list	
	b.	CCB/LCB	
	c.	High school diploma	314
	d.	Experience	
	e.	Completed application	
	f.	Application fee	
3.		Certification renewal	314
	a.	Certificate expiration	
	b.	Training, CEUs	
		A. Minimum score written exam	
		B. Approved list	
	c.	CCB/LCB	
	d.	Completed application	
	e.	Application fee	
	f.	Reinstatement fee	
	g.	Failure to renew	
4.		Reciprocity	314
	a.	Current Certificate	
	b.	Renewal class	315
		A. Minimum score written exam	
		B. Approved list	
	c.	CCB/LCB	
	d.	High School Diploma	
	e.	Reciprocity form	
	f.	Application fee	
5.		Fees	315
	a.	Method of payment	
	b.	Refunds	
	c.	Fee schedule	
		A. Initial	
		B. Renewal	
		C. Reciprocity review	

	D. Reinstatement	
	E. Combination	
	d. Prorating	
	e. Combination certificate/renewal fee	
6.	Enforcement	315
	a. Denial	
	A. False Information	
	B. Revocation	
	C. Unauthorized certificate use	
	D. Falsification	
	E. CCB/LCB	316
	F. Failed to comply with regulations	
	b. Appeal process	
	c. Reapplication	
	d. Revocation petition	
333-061-0074	Cross Connection Training Programs, Course and Instructor Requirements	316
1.	Instructor qualifications	
	a. Permanent records	
	b. List of students	
	c. Training Schedule	
	d. Student/training equipment ratio	
	e. Uniform training	
	f. Training materials	
	g. Training equipment	
	A. Test station backflow devices	
	i. Operating devices	317
	ii. Simulator	
	B. Training Aids	
	h. Instructor Requirements/Course Curriculum	
2.	Specialist Training Course Requirements	317
	a. Minimum Hours	
	b. Course content	
	A. Definitions	
	B. Approved methods and specifications	
	C. Cross Connection control requirements	
	D. Public education and record keeping	
	E. Inspection techniques	
	F. Enforcement	
	G. Safety issues	
	c. Minimum score	
3	Backflow Assembly Tester Requirements	317
	a. Minimum Hours	318

b.	Course content	
A.	Definitions	
B.	Hazards	
C.	Back Flow assembly approval requirements	
D.	Disassembly/Reassembly	
E.	Hands on demonstration	
F.	Test gauge calibration	
G.	Safety issues	
c.	Minimum score written exam	
d.	Minimum performance exam score	
4.	Cross Connection Inspector Renewal Regulations	318
a.	CEUs	
b.	Course content	
A.	Review regulations	
B.	Review Backflow incidents	
C.	Review safety issues	
5.	Backflow Assembly Tester Renewal	318
a.	CEUs	
b.	Course content	
A.	Review regulations	
B.	Review test procedures	
C.	Hands on demonstration	
D.	Student diagnosis	
E.	Review safety issues	319
F.	Written exam	
c.	Minimum written exam score	
d.	Minimum performance exam score	
6.	Instructor Qualifications Requirements	319
a.	Instructor eligibility Cross Connection Specialist	
A.	Oregon Certification	
B.	Experience	
C.	Participation in training classes	
D.	Recommendation	
E.	Instructor update attendance	
b.	Tester instructor eligibility	
A.	Oregon certification	
B.	Experience	
C.	Student instructor participation	
D.	Recommendation	
E.	Instructor update attendance	320
c.	Approved list	
	333-061-0075 Sanitary Surveys of Watersheds	320
1.	Sanitary surveys, unfiltered surface/GWDI	

2.	Evaluation of man-made and natural features	
a.	Dams, impoundments, intakes, screens, etc.	
b.	Surface geology, soils, animals, etc.	
c.	Human activities	
d.	Raw water	
e.	Type and effectiveness of control measures	
3.	Survey report	
4.	Watershed management plan guidelines	
333-061-0076	Sanitary Surveys	320
1.	Approved surveyors	
2.	Information to be provided upon request	321
3.	Survey report	321
4.	Significant deficiencies	
a.	Surface water treatment	
A.	Monitoring location	
B.	Automatic alarms (>3300)	
C.	Automatic alarms (conventional/direct)	
D.	Turbidity	
E.	Turbidity profiles	
F.	Cartridge-pressure gauges	
G.	Changing cartridge filters	
H.	DE-body feed	
b.	Groundwater wells	
A.	Sanitary seal	
B.	Setbacks from hazards	
C.	Wellhead not protected from flooding	
D.	Raw water sample tap	
E.	Treated sample tap	
F.	Screened vent	
c.	Groundwater springbox	
A.	Impervious material	
B.	Watertight access hatch	
C.	Screened overflow	
D.	Setbacks from hazards	
d.	Disinfection	
A.	Contact chamber flow rate	
B.	CT calculations	
C.	Contact time determinations	322
e.	Finished water storage	
A.	Locked hatch	
B.	Water tightness	
C.	Drain/overflow	
D.	Screened vent	

5.	Sanitary survey fees (schedule)	322
6.	Required response	
a.	Surface water/GWUDI system response	
A.	Corrective action plan for significant deficiencies	
B.	Corrective action plan for other deficiencies	
C.	Schedule	
b.	Groundwater system response	323
A.	Corrective action	
7.	Compliance	
8.	Violations	
333-061-0077	Composite Correction Program/CPEs	323
1.	Approved evaluators	
2.	Systems required to perform CPEs	
3.	Turbidity > 2.0 NTU	
4.	CPE report	
5.	Department notification	
a.	Corrective plan	324
b.	Schedule	
6.	Compliance	
333-061-0080	Role of Counties	324
1.	Consolidation plans	
2.	Building permits, certification of approved plans	
3.	Water district formation, expansion, etc.	
4.	Delegation of Department duties, assurances	
a.	Qualified personnel	
b.	Performance of duties	
c.	Performance evaluation	
333-061-0085	Supplemental Fluoridation	324
1.	Supplemental fluoridation	
a.	Proportional to flow	
b.	AWWA standards	
A.	Sodium fluoride	325
B.	Sodium fluorosilicate	
C.	Fluorosilicic acid	
c.	Safety equipment	
2.	Department approval	325
a.	Plans and specifications of equipment	
b.	Fluoride compound specifications	
c.	Operator qualifications	
d.	Chemical analysis	
3.	Operator responsibilities	
a.	<2.0 mg/l in finished water	
b.	Maintain equipment	

c.	Approved methods of determination	
A.	Unfluoridated	
B.	Fluoridated	
d.	Daily records, summary submission	
e.	Split samples	
f.	Safety equipment	
333-061-0087	Product Acceptability Criteria	325
1.	Lead prohibition	
a.	All PWS	
b.	Plumbing attached to PWS	
2.	Labeling of solder	
3.	Electrical grounding	
4.	Lead pipe	
5.	NSF standard 61 (Materials/products)	326
6.	NSF standard 60 (Treatment chemicals)	
7.	NSF standard 58 (RO)	
8.	NSF standard 53 (POU)	
333-061-0090	Penalties	326
1.	Class A misdemeanor	
2.	Civil penalties	
3.	Hearing	
4.	Civil penalty violations	
a.	Plan approval	
b.	Construction	327
c.	MCLs	
d.	Monitoring	
e.	Reporting/PN	
f.	Schedules/variances/permits	
g.	Cross connections	
h.	Operation/maintenance	
i.	Administrative orders	
5.	Penalty schedule (Table 51)	
333-061-0095	Severability	327
333-061-0097	Adverse Health Effects Language	
1.	Organic Chemicals: mandatory health effects language	
a.	Volatile Organic Chemicals (VOCs)	
A.	Benzene	
B.	Carbon tetrachloride	
C.	Chlorobenzene	328
D.	o-Dichlorobenzene	
E.	p-Dichlorobenzene	
F.	1,2-Dichloroethane	
G.	1,1-Dichloroethylene	

H.	cis-1,2-Dichloroethylene	
I.	trans-1,2-Dichloroethylene	
J.	Dichloromethane (methylene chloride)	
K.	1,2-Dichloropropane	
L.	Ethylbenzene	
M.	Styrene	
N.	Tetrachloroethylene (PCE)	
O.	1,2,4-Trichlorobenzene	
P.	1,1,1-Trichloroethane	329
Q.	1,1,2-Trichloroethane	
R.	Trichloroethylene (TCE)	
S.	Toluene	
T.	Vinyl chloride	
U.	Xylenes	
b	Synthetic Organic Chemicals (SOCs)	
A.	2,4-D	
B.	2,4,5-TP(Silvex)	
C.	Alachlor	
D.	Atrazine	
E.	Benzo(a)pyrene	
F.	Carbofuran	
G.	Chlordane	
H.	Dalapon	330
I.	Di(2-ethylhexyl)adipate	
J.	Di(2-ethylhexyl)phthalate	
K.	Dibromochloropropane (DBCP)	
L.	Dinoseb	
M.	Diquat	
N.	Dioxin (2,3,7,8-TCDD)	
O.	Endothall	
P.	Endrin	
Q.	Ethylene dibromide (EDB)	
R.	Glyphosate	
S.	Heptachlor	
T.	Heptachlor epoxide	
U.	Hexachlorobenzene	331
V.	Hexachlorocyclopentadiene	
W.	Lindane	
X.	Methoxychlor	
Y.	Oxamyl	
Z.	Polychlorinated biphenyls (PCBs)	
AA.	Pentachlorophenol	
BB.	Picloram	

	CC. Simazine	
	DD. Toxaphene	
2.	Lead and Copper: mandatory health effects language	331
	a. Lead	
	b. Copper	332
3.	Inorganics: mandatory health effects language	332
	a. Antimony	
	b. Arsenic	
	c. Asbestos	
	d. Barium	
	e. Beryllium	
	f. Cadmium	
	g. Chromium	
	h. Cyanide	
	i. Fluoride	
	j. Mercury	333
	k. Nitrate	
	l. Nitrite	
	m. Total Nitrate and Nitrite	
	n. Selenium	
	o. Thallium	
4.	Microbiological, public notice format	333
	a. Mandatory health effects language, total coliform	
	b. Mandatory health effects language, fecal / <i>E. coli</i>	
	c. Optional health effects info: persistent coliform growth	
	d. Turbidity	334
5.	Treatment techniques; mandatory health effects language	334
	a. Acrylamide	
	b. Epichlorohydrin	
	c. SWTR, IESWTR, Filter backwash	
	d. Groundwater	
	e. Emergency groundwater source	
6.	Disinfectant and disinfectant byproducts	335
	a. TTHMs	
	b. HAA5s	
	c. Chlorine	
	d. Chloramines	
	e. Chlorine dioxide	
	A. Treatment	
	B. Distribution	
	f. Bromate	336
	g. Chlorite	
	h. TOC	

7.	Radionuclides	336
a.	Beta/photon emitters	
b.	Alpha emitters	
c.	Combined Radium-226/228	
d.	Uranium	
333-061-0098	References	336
	Water Personnel Certification Rules	338
333-061-0205	Purpose	
1.	Objectives	
a.	Public health protection	
b.	Classification criteria	
c.	Assist applicants	
d.	Award/register certificates	
e.	Communication	
f.	Improve PWS operation	
333-061-0210	Scope	
333-061-0215	Definitions	338
333-061-0220	Classification of Water Systems	340
1.	Classification categories	
a.	Small water system	
b.	Water distribution	
c.	WTP, point system	340
d.	Filtration Endorsement	342
333-061-0225	General Requirements Applying To Water Systems	342
1.	Water system supervision	
2.	Operator grade \geq PWS classification	343
3.	PWS size/complexity/treatment plant	
4.	DRC designation	
5.	Other operators, written protocols	
a.	Operational decisions	
b.	Consultation with DRC operator	
c.	Skills and abilities	
d.	Signed/dated documentation	
333-061-0228	Certification Requirements For Small Groundwater System Operators	343
1.	Initial certification	
a.	High school diploma or equivalent	
b.	Written examination	
2.	Small water system renewal	
3.	Expired certification	
4.	Exemption from fees	
333-061-0230	Contracting For Services	344

1.	Contracting	
2.	Sufficient supervision	
	a.	24-hr call
	b.	Corrective actions
	c.	Operational decisions
3.	Contract verification	
333-061-0235	Operator Requirements Levels 1-4	344
1.	WT/WD level 1	
	a.	Education
	b.	Experience
	c.	Written exam
	d.	Exam
2.	WT/WD level 2	
	a.	Education
		A. 3 yrs
		B. 2 yrs
	b.	Written exam
3.	WT/WD level 3	344
	a.	Education
		A. 1 yr
		B. 2 yrs
		C. 3 yrs
		D. 8 yrs
	b.	Written exam
4.	WT/WD level 4	345
	a.	Grade 3 level
	b.	Education/experience
		A. 4 yrs/4yrs
		B. 3 yrs/5yrs
		C. 2 yrs/6yrs
		D. 10 yrs
	c.	Written exam
5.	Filtration Endorsement	
	a.	WT 2 or higher
	b.	1 yr experience
	c.	Written exam
333-061-0245	Applications For Certification Levels 1-4	345
1.	Criteria for granting certificates:	
	a.	Application information
	b.	Qualifications
	c.	Exam
2.	Reciprocity	
	a.	Application submittal
		346

b.	Review	
c.	Certification w/o exam	
d.	Exam fee	
e.	Renewal	
3.	Education/Experience	346
4.	Appeal process	
5.	Verification	
6.	Qualification criteria	
a.	Experience equivalence	
b.	Substitute experience credit	
A.	Water Distribution certificate	
i.	Wastewater collection	
ii.	WTP	
iii.	Cross connection control	
iv.	Commercial process water treatment	
B.	Water Treatment Certificate	
i.	Wastewater treatment plant	
ii.	Wastewater treatment lab	
iii.	Water distribution system	
iv.	Commercial process water treatment	
c.	Post High School education	
A.	College education	
B.	CEUs	
C.	Combination credits/CEUs	347
D.	College credit	
d.	On-the-job training	
7.	New Certification	
8.	Application (fees/documentation), deadlines	
9.	Qualifications review	
333-061-0250	Examinations Levels 1-4	347
1.	Exam frequency	
2.	Exam/application fees	
3.	Documentation	
4.	Minimum score	
5.	Special exams	
6.	Re-examination restrictions	
7.	Application denial	
8.	Incomplete applications	348
9.	Exam scoring	
10.	Certificates	
333-061-0260	Certificate Renewal Levels 1-4	348
1.	Expiration date, renewal application	
a.	Subject relevance, criteria	

A.	Technical capacity	
B.	Managerial capacity	
C.	Financial capacity	
b.	College credits	
c.	CEUs from other states	
d.	CEU records	
2.	Expiration notice	
3.	Renewal failure/suspension	
4.	Reinstatement	349
5.	Reinstatement exam/fee	
333-061-0265	Fees	349
1.	Payable to DHS	
2.	Application fee refunds	
a.	DHS inaction	
b.	Wrong application	
3.	Examination fee refunds	
a.	Denial	
b.	Applicant unable to take exam	
4.	Fees (schedule)	349
a.	Certification renewal	
b.	Combination	
c.	Exam - all	
d.	Special exam	
e.	Application (WD and WT)	
A.	Level 1	
B.	Level 2	
C.	Level 3	
D.	Level 4	
E.	Filtration endorsement	
f.	Reciprocity review	
g.	Reinstatement	
h.	Late fee	
i.	Document Replacement	
5.	Combination certification	
6.	Filtration endorsement/no annual fee	350
7.	Document replacement fee due date	
333-061-0270	Refusal, Suspension, or Revocation of Certification	
1.	Denial, suspension, and revocation	
a.	Fraud or deceit	
b.	Negligence	
c.	Rule violations	
d.	Investigation	

e.	False statements	
2.	Appeal process	
3.	Recertification after revocation	
333-061-0272	Suspension of Certification	350
1.	Suspension, hearings	
a.	Department response	
b.	Operator request	
333-061-0290	Penalties	351
1.	Punishment	
2.	Civil penalty	
3.	Administrator's role	
4.	Maximum civil penalties	
a.	DRC-certified	
b.	DRC-CEUs	
c.	AO	
5.	Civil Penalties	
333-061-0295	Severability	351
	Domestic Well Testing Program	
333-061-0305	Purpose	351
333-061-0310	Scope	352
333-061-0315	Adoption by Reference	
333-061-0320	Definitions	
333-061-0325	Domestic Well Tests	353
333-061-0330	Certified Labs	
333-061-0335	Sample Collections	353
Oregon Revised Statutes 448		355