

Table 87-3

FILTER EFFICIENCIES FOR CENTRAL VENTILATION¹ AND AIR CONDITIONING SYSTEMS IN NURSING FACILITIES OAR 411-087-0450	MINIMUM NUMBER OF FILTER BEDS	FILTER EFFICIENCIES (Percent) FOR MAIN FILTER BED
Resident Care, Treatment, Diagnostic and Related Areas	1	80
Food Preparation Areas and Laundries	1	80
Administrative, Bulk Storage and Soiled Holding Areas	1	25

¹Central ventilation systems are those supplying air to more than one room or area when return air from a single room is recirculated to other rooms. Resident toilet rooms may be exhausted using make-up air from adjoining resident rooms by undercutting doors or through provision of transfer grills without mandating installation of filters when otherwise not required.