

**TABLE 3
(OAR 333-535-0300)**

**FILTER EFFICIENCIES FOR VENTILATION AND
AIR CONDITIONING SYSTEMS IN GENERAL HOSPITALS**

AREA DESIGNATION	Number of Filter Beds	FILTER EFFICIENCIES	
		Filter Bed No. 1	Filter Bed No. 2
All areas for inpatient care, treatment and/or diagnosis, and those areas providing direct service or clean supplies such as laboratories, sterile and clean processing, etc.	2	25	90
Food preparation areas and laundries.	1	80	--
Administrative, bulk storage soiled holding areas, and all non-patient areas. Kitchen range hood dedicated make-up air systems.		25	-

NOTE:

1/ Ratings shall be based on ASHRAE Standard 52-2.

2/ Outpatient laboratories and hospital facilities identified in OAR 333-535-0300(4)(a) as not requiring conformance to Table 2 are also exempt from compliance to Table 3, if at least one 25% minimum efficiency filter is provided. In addition, hospital outpatient facilities with no air-to-air connection with inpatient facilities providing cancer treatment, endoscopy or kidney dialysis services are exempt from meeting Table 3, with provision of at least one 25% efficient filter.