



# Oregon

Theodore R. Kulongoski, Governor

Department of Corrections  
General Services Division  
Fiscal Services Section, Contracts Unit  
3601 State Street, Suite 280  
Salem, OR 97301-5780  
PHONE (503) 378-3798 x 22486  
FAX (503) 371-3161  
e-mail [Kay.Duffey@doc.state.or.us](mailto:Kay.Duffey@doc.state.or.us)

## ADDENDUM #2 TO REQUEST FOR PROPOSALS #3091

TO: Holders of RFP #3091

DATE: December 6, 2004

FROM: Kay Duffey, Contracts Coordinator  
Oregon Department of Corrections

This is Addendum #2 to Request for Proposals #3091 issued November 10, 2004.

1. Paragraph 13.2.22.14 of RFP #3091 is hereby amended as follows. Deleted language is shown in [brackets] and new language is underscored:

“13.2.22.14 FIRE ALARM SYSTEM – CONTROL PANEL - Consultant shall observe all tests conducted on 30% of the fire alarm system control panels, and all device actuation tests conducted on 30% of ceiling smoke detectors and manual alarm switches. Owner, acting as Project Manager, [anticipates that the Project Management Consultant, Vickers, Foster & Associates,] shall observe all of the contractor point checkout procedures prior to Consultant observing the tests and completing other Commissioning Services on the Fire Alarm system.”

2. All other sections of RFP #3091 are unchanged and remain in effect.
3. If you have questions regarding this Addendum #2, please contact Kay Duffey by phone at (503) 378-3798 x 22486 or by e-mail at [KAY.DUFFEY@DOC.STATE.OR.US](mailto:KAY.DUFFEY@DOC.STATE.OR.US)