



Oregon

John A. Kitzhaber, M.D., Governor

Department of Corrections

Purchasing Section

3601 State Street, Suite 280

Salem, OR 97301-5780

(503) 378-3798, 371-3161 FAX

www.scott.petterson@doc.state.or.us

07/01/2004

Addendum # 1

to

OSP C-Block Roof Replacement Project, Bid No. 189978-04



Below you will find revisions, clarifications, deletions and/or additions to the bid specifications. This addendum modifies the related Invitation to Bid only to the extent specifically indicated herein. All other areas not specifically mentioned or affected by this addendum shall remain in full force and effect.

This addendum shall be added to and become part of the original Invitation to Bid.

The Bid Closing and Bid Opening Time and Date have been changed as follows:

Sealed Bids will be received until the Bid Closing on 07/20/2004 at 2:00 PM.

Sealed Bids will be publicly opened at the Bid Opening on 07/20/2004 at 2:00 PM in ROOM #366, Department of Corrections, 3601 State Street, Suite 280, Salem, OR.

1. Contractor's employees and subcontractors who will be working at the Institution will be required to attend a security/safety training session at OSP prior to starting work. The training session will be approximately two hours long.
2. Work shall be scheduled and performed to minimize down time of the camera installed on the roof. Down time shall not exceed two days and shall be scheduled and approved by the institution.
3. All duct work may be removed at the same time. Materials may be stored on the adjacent roof; it is the contractor's responsibility to provide adequate protection to prevent damaging adjacent roof and to repair any damaged caused by the contractor or his subcontractors.
4. Replace flex duct connection for both Exhaust Fans..
5. Replace both Exhaust Fans Pan Flashing.
6. The pan flashing for the supply AHU can be flashed in place..
7. Provide duct transition to raise the 5'-2" x 3'-2" main duct located between the supply AHU and Exhaust Fans to provide 8 inch clearance from roof surface to fire damper located in duct connected on the bottom side of the main duct.
8. Remaining duct dampers can remain at their existing elevation, if installation is acceptable and warranted by the roofing manufacturer.
9. Clearance at vehicle entry gates is 13'-6".
10. Replace Technical Specification Section 1.4. E with the following:
 1. **E. Roofing Membrane Load-Strain Properties**
 1. Roofing System shall have a Tensile strain at failure of at least 450 lbf-in in both the machine and cross-machine direction when tested according to ASTM D 2523."



Oregon

John A. Kitzhaber, M.D., Governor

Department of Corrections

Purchasing Section

3601 State Street, Suite 280

Salem, OR 97301-5780

(503) 378-3798, 371-3161 FAX

www.scott.petterson@doc.state.or.us



11. Delete Paragraph 1.6 C. and replace with the following:
“C. Manufacturer Qualifications: A qualified manufacture that has UL or FMG listing for roofing system that meets code.
 1. Manufacture to provide Technical Representative to do ongoing periodic project inspection and reporting to Owner.”
12. If required by roofing manufacturer, install the bottom layer of 3” Isocyanurate insulation in two layers.
13. DRAWINGS: Two 11” x 17 “ Drawings giving Roof Plan View and the layout of the ventilation system are being provided under separate cover to the Companies that attended the pre-bid meeting.
14. See attached revised Bid Form. Bid Alternate 2 is added to provide and install new scuppers. Scuppers shall be of the same quality as the original scuppers.

This addendum represents a material change to the ITB and is required to be signed and returned by the Bid closing date and time. Failure to do so may result in bid rejection.

If you have any questions pertaining to this Addendum, please contact Scott Petterson at (503) 378-3798 x 22496.

Company Name: _____

Authorized signature: _____

Date: _____



Oregon

John A. Kitzhaber, M.D., Governor

Department of Corrections

Purchasing Section

3601 State Street, Suite 280

Salem, OR 97301-5780

(503) 378-3798, 371-3161 FAX

www.scott.petterson@doc.state.or.us

OREGON DEPARTMENT OF CORRECTIONS

BID FORM

OSP C-Block Roof Replacement Project

Public Works Project # # 189978-04



The undersigned proposes and agrees, if this Bid is accepted, to enter into an Agreement with OWNER to perform and furnish all Work as specified or indicated herein for the ITB indicated and within the schedule indicated in the Invitation to Bid. Bidder has familiarized itself with the Work and has visited and inspected the site and is familiar with all the field conditions, legal requirements (federal, State, and local laws, ordinances, rules, and regulations), and conditions affecting cost, progress and performance of this Work, and has made such independent investigations as Bidder deems necessary. Bidder has given OWNER written notice of all conflicts, errors, and/or discrepancies that it has discovered in the Contract Documents and the written resolution thereof by OWNER is acceptable to Bidder.

Base Bid \$ _____

Bid Alternate # 1: Delete third party Full Time Inspection

\$ _____

Bid Alternate # 2: Add in to provide and install New Scuppers

\$ _____

Company: _____

Company Address: _____

Telephone No: _____ **Fax No:** _____

Construction Contractors Board Number: _____ **Expiration Date:** _____

I attest that I have the authority to commit the firm named above to this Bid amount and acknowledge that the firm meets the qualifications necessary to perform this Work as outlined in the Invitation to Bid. I understand that I will be required to provide necessary information to verify that the firm meets these qualifications if selected for this Contract.

Signature/Typed Name & Title / Date