



Oregon

Ted Kulongoski, Governor

Department of Corrections

Purchasing Section

3601 State Street, Suite 280

Salem, OR 97301-5780

(503) 378-3798, 371-3161 FAX

www.scott.petterson@doc.state.or.us

10/26/2004



Addendum # 1
For
PRCF HVAC Corrective Action Project, Bid # 193835-04

Below you will find revisions, clarifications, deletions and/or additions to the bid specifications. This addendum modifies the related Invitation to Bid only to the extent specifically indicated herein. All other areas not specifically mentioned or affected by this addendum shall remain in full force and effect.

This addendum shall be added to and become part of the original Invitation to Bid.

The Bid Closing and Bid Opening date and time will remain the same as stated in the original ITB.

The following Items are provided as clarification to questions arising during the Mandatory Pre-Bid Walk-Through.

The following three (3) items are provided as clarification to, and/or answers to questions arising during the Mandatory Pre-Bid Walk-Through.

These items **will not** extend the Bid Closing Date.

Item #1:

Project Scope of Work notes "thirteen (13) 100,00 BTU heaters."

Owner Clarification: Replace the Reznor Indoor Gas Fire Duct Furnaces with a Sterling, Model QUES-100, w/ Stainless Steel Heat Exchangers, as identified & discussed at Pre-bid Conference

Note: Locations of each:

- **Unit #1, East** – 3 each
- **Unit #1, West** – 3 each
- **Unit #3, East** – 1 each
- **Unit #3, West** – 1 each
- **Admin Building** – 1 each
- **Support Building Kitchen** – 2 each
- **Support Building Dining & Office** – 2 each

Item #2:

Contractor to install Pressure Relief at each Unit Location. Relief to be installed in Return Duct, and to Normally Open in Relief Mode, and Normally Closed in Heating Mode

Item #3:

Contractor Question: What is the Manufacturer / Brand of the existing Swamp / Evaporative Coolers ?

Owner Answer: **McQuay, Model ECM-1**

This addendum represents a material change to the ITB and is required to be signed and returned by the Bid closing date and time. Failure to do so may result in bid rejection.

If you have any questions pertaining to this Addendum, please contact Scott Petterson at (503) 378-3798 x 22496.

Company Name: _____

Authorized signature: _____

Date: _____