



Oregon

Ted Kulongoski, Governor

Department of Corrections

Purchasing Section

3601 State Street, Suite 280

Salem, OR 97301-5780

(503) 378-3798 x 22496, 371-3161 FAX

www.scott.petterson@doc.state.or.us

Date: 09/25/2006



Addendum # 2

For

UST Removal at DOC Central Distribution Warehouse, Bid # 220092-06

Below you will find Revisions, clarifications, deletions and/or additions to the bid specifications. This addendum modifies the related Invitation to Bid only to the extent specifically indicated herein. All other areas not specifically mentioned or affected by this addendum shall remain in full force and effect.

This addendum shall be added to and become part of the original Invitation to Bid.

This addendum represent a material change to the ITB and is required to be signed and returned by the Bid Closing Date and Time. Failure to do so may result in bid rejection.

The Bid closing date and time has now been changed to 2:00 PM on 10/05/2006.

1. Delete paragraph 2.03.E.9 of Section 13200 and add the following:

“Card Lock System: 100 card system, Petrovend K800 Fuel Control System or equal.

Install communications cable to DOC offices located approximately 300 feet from AST location (install cable underground per local code). Provide clean sawcut of all AC paving to be cut. Repair AC to match existing AC.”

2. Contractor to supply and install Diesel tank that meets all applicable codes.

3. Contractor to select a dispenser that is compatible with the tank and the card reader.

4. Fire hose length to be maximum that is within fire code regulations.

5. Powder coating is not required for the Fireguard tank.

Company Name: _____

Authorized Signature: _____

Date: _____