



Oregon

Ted Kulongoski, Governor

Department of Corrections

Purchasing Section

3601 State Street, Suite 280

Salem, OR 97301-5780

(503) 378-3798 x 22496, 371-3161 FAX

www.scott.petterson@doc.state.or.us

11/02/2004



Addendum # 5
to
OSP Law Library Upgrade, Bid No. 192923-04

Below you will find Revisions, clarifications, deletions and/or additions to the bid specifications. This addendum modifies the related Invitation to Bid only to the extent specifically indicated herein. All other areas not specifically mentioned or affected by this addendum shall remain in full force and effect.

This addendum shall be added to and become part of the original Invitation to Bid.

Sealed Bids will be received until the Bid Closing on 11/09/2004 at 2:00 PM.

Sealed Bids will be publicly opened at the Bid Opening on 11/09/2004 at 2:00 PM in ROOM #366, Department of Corrections, 3601 State Street, Suite 280, Salem, OR 97301-5780.

- 1) The installation of the second electrical panel and the removal of the buss-duct, is no longer required. There will be one electrical panel installed per Addendum #3 section 1(a).
- 2) Delete the IMU building portion of work, as previously requested by ODOC.
- 3) ODOC requires that all bidding contractors be Asbestos and Lead Certified.
- 4) New Pathway for fiber route; penetrate the East wall of the C Fan room and run qty (4) four inch PVC conduits thru the false ceiling to the outside wall of the building. Place an outdoor rated box (sized for conduits and pass thru cable) and continue two conduits to the third and fourth floors (Education and Resource areas) installing outdoor rated and correctly sized entrance boxes at each floor. Two four inch penetrations from the newly installed box to each floor, at ceiling level, are required. Install two four inch EMT pathways from the newly installed box system to room 360 inside the library. Innerduct; Install four one inch innerducts from the C fan room thru the new fiber pathway to each floor penetrated. Extend four one inch innerducts from room 360 back to the box system via the four inch conduits.

This addendum represents a material change to the ITB and is required to be signed and returned by the Bid Closing Date and Time. Failure to do so may result in bid rejection.

If you have any questions pertaining to this Addendum, please contact Scott Peterson at (503) 378-3792 x 22496.

Company Name: _____

Authorized Signature: _____

Date: _____