



# Oregon

Theodore R. Kulongoski, Governor

## Region 3 Roseburg Construction Office

Ted Paselk, Project Manager

3500 NW Stewart Parkway

Roseburg, OR 97470

Ph (541) 957-3572 FAX (541) 957-3615

November 14, 2006

TO: Prospective Bidders

Re: OR99: N Umpqua River (Old Winchester) Bridge Rehab  
Oakland – Shady Highway  
Douglas County  
Grading, Paving and Structures Project  
LETTER OF CLARIFICATION

The following information is provided in response to questions or issues of significance that have been raised by one or more prospective bidders. This is for information only and there are no addendums that will result from this information.

**Item/Question: Special Provisions – “Section 00583.10 General”:** Galvanized Class 50 Ductile Iron (Cement Lined) 10 inch Sanitary Sewer Pipe, as called for in Section 00583.10 of the Special Provisions, is not readily available.

- **ODOT Clarification/Response:** Galvanization of the Class 50 Ductile Iron (Cement Lined) 10 inch Sanitary Sewer Pipe is not required.