



# Oregon

**Department of Transportation**  
Technical Services  
Roadway Engineering Section  
355 Capitol St. NE, Room 222  
Salem, OR 97301-3871  
Telephone (503) 986-3714  
Fax 503-986-3749

May 5, 2009

**TO: Prospective Bidders**

**RE:** I-84: Fifteen Mile Cr-US97:Spanish Hollow Cr-B207  
Key Number: K14029  
Wasco and Sherman Counties  
Grading, Drainage, Structures, & Paving  
Bid Letting Date: May 7, 2009  
LETTER OF CLARIFICATION #4

The following information is provided in response to questions or issues of significance that have been raised by one or more prospective bidders. This is for information only at this time and will not be included in an addendum.

**Item/Question:** Bid item 1120, Topsoil, has a quantity of 153 cy. Special provision 01040.12 – Water Quality Topsoil and Planting Backfill states, topsoil used in the lining of the water quality pound and as planting backfill shall consist of 33% sandy loam topsoil, 33% course sand, and 34% compost material.

Bid items 1100, Coarse Sand, has a quantity of 53 cy. Bid item 1110, Compost Mulch, has a quantity of 53 cy.

Was it the intention of the designer to mix bid item 1100 and 1110 in with 1120 to make the required mixture? If so, should bid item 1120 top soil have a quantity of 53 cy also so when all the mixing is done the ratios work out as required in the specials?

- **ODOT Clarification/Response:** Yes, the quantity of Bid item 1120, Topsoil, should be 53 CUYD, however, no addendum will be issued. Please bid the quantity as shown in the Bid Schedule.