

**Oregon Fire Code  
Special Amendment  
Section 908.7 Carbon Monoxide**

*Effective Date: April 1, 2011*

Contact: John Caul  
Deputy State Fire Marshal  
[john.caul@state.or.us](mailto:john.caul@state.or.us)

New code section 908.7 has been adopted by the State of Oregon.

*With the passage of House Bill 3450, the Lofgren and Zander Memorial Act, the State Building Codes Division was instructed to require carbon monoxide alarms in all newly constructed Group R occupancies as identified in Section 310 of the Oregon Structural Specialty Code (OSSC) which is based on the 2009 International Building Code (IBC). Examples of these uses may be characterized as; hotels, motels, apartments, dormitories, fraternities, sororities and residential care/assisted living facilities. In addition, SR-3 and SR-4 occupancies as defined in OSSC Appendix SR are included as they are principally built to “residential” standards. **Per the terms of the bill, these requirements are applicable to affected structures submitted for plan review as of April 1, 2011.***

This code has been prepared as an insert page for the 2010 OFC to maintain correlation with the OSSC. Pages are formatted so that when inserted, the amendments will face the page containing the existing code language.

Oregon Fire Code [New Section 908.7](#)

Oregon Fire Code [Chapter 47 UL insert](#)

Oregon Fire Code [Chapter 47 NFPA insert](#)