

2014 Oregon Residential Specialty Code (ORSC)

Code Change:

Suggested changes (strikeout text denotes deletion, **bold/underline denotes addition**)

SECTION 2415 PIPING SYSTEM INSTALLATION

G2415.11 Trenches. The trench shall be graded so that the *pipe* has a firm, substantially continuous bearing on the bottom of the trench.

G2415.11.1 Underground gas pipe separation. ~~Underground gas piping shall be separated vertically or horizontally from other underground piping as follows:~~

- ~~1. Sewer pipe not less than 18 inches (457 mm) from any underground sewer line.~~
- ~~2. Water pipe not less than 12 inches (305 mm) from any underground water line.~~
- ~~3. Drainage pipe not less than 12 inches (305 mm) from any underground drainage line.~~

2014 Oregon Structural Specialty Code (OSSC)

Code Change:

Suggested changes (~~strikeout text~~ denotes deletion, **bold/underline** denotes addition)

[F] **907.2.11 Single- and multiple-station smoke alarms.** *Listed* single- and multiple-station smoke alarms complying with UL 217 shall be installed in accordance with Sections 907.2.11.1 through 907.2.11.4 and NFPA 72. **Section 29.3.8 of NFPA 72 is not adopted.**

908.7 Carbon monoxide alarms. Approved carbon monoxide alarms in new buildings and structures shall be provided in the locations described in Sections 908.7.1 and 908.7.2. **Section 9.4.2.2 of NFPA 720 is not adopted.**

DRAFT