

## SOURCE TESTING AUDIT REPORT: CERTIFICATION FORM

Facility: Hollingsworth & Vose Permit #: 02-2173-ST-01 Test Date: 12/13-15/2022

Emission Unit: CFU 108, 112, 113, 115, 118 Sampling Location: Corvallis, OR

### SECTION 1: TESTING PROGRAM CERTIFICATION INFORMATION


ITEM OF INQUIRY	Yes	No	EXPLANATION
A. Is the purpose(s) for the testing clearly defined within the test report?	X		
B. Did testing include all pollutants specified within the Source Test Plan (STP)?	X		
C. Were all issues within the Department's response to the STP fully addressed?	X		
D. Was the source operating within $\pm 10\%$ of normal maximum capacity?	X		
E. Are all appropriate operating conditions documented?	X		
F. Were there any test interruptions?		X	
G. Were there any variances or modifications to the STP? (if Yes; reply to i & ii)		X	
i. Were the variances or modifications approved by the Department?			
ii. Does the report include an evaluation of the impact the variances or modifications had on the test data?			

### SECTION 2: SOURCE SAMPLING REPORT AUDITOR CERTIFICATION:

I hereby certify that to the best of my knowledge, the information provided within this source sampling audit report is complete and factual.

Name: Jacob Rankin

Title: Helena Source Team Lead

Signature: 

Date: 02/03/2023

### SECTION 3: PERMITTEE REPRESENTATIVE CERTIFICATION:

I hereby certify that to the best of my knowledge, the information provided within this source sampling audit report is complete and factual.

Name: Anita Ragan

Title: EHS Manager

Signature: 

Date: 02/03/2023

### SECTION 4: DEPARTMENT REPRESENTATIVE:

The Oregon Department of Environmental Quality has evaluated the Source Sampling Audit Report and has determined that the information provided is sufficient for accepting the results originating from the testing program. Although no deficiencies were exposed by the Source Sampling Audit Report, additional errors and/or inconsistencies may be detected through additional Departmental review at a later date, which may lead to a retest or an enforcement action against the permittee.

Name: \_\_\_\_\_ Title: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

# EMISSIONS TEST REPORT

## HOLLINGSWORTH & VOSE GLASS FIBER MANUFACTURING PLANT

### CFUs EMISSION FACTOR VERIFICATION AND MATERIALS HANDLING AREA VERIFICATION OF PERMANENT TOTAL ENCLOSURE

Oregon Department of Environmental Quality  
Air Contaminant Discharge Permit: 02-2173-ST-01

Prepared for:

**Hollingsworth & Vose Fiber Company**  
1115 SE Crystal Lake Drive  
Corvallis, OR 97333

Prepared by:

**Bison Engineering, Inc.**  
3143 E. Lyndale Avenue  
Helena, MT 59601  
(406) 442-5768  
[www.bison-eng.com](http://www.bison-eng.com)

Project Number: HAV222965  
Test Dates: December 13-15, 2022  
Report Issued: February 3, 2023



## EXECUTIVE SUMMARY

Hollingsworth & Vose Fiber Company contracted Bison Engineering, Inc. to perform emissions tests on the rotary coarse, ultra-rotary coarse, glass furnace, flameblown, and rotary fine ceramic filtration units (CFU 108, 112, 113, 115, and 118 respectively) for emission factor verification, and to conduct a permanent total enclosure verification on the raw materials handling area at the Hollingsworth & Vose facility in Corvallis, Oregon. This facility is subject to the provisions of Oregon Department of Environmental Quality permit number 02-2173-ST-01. All testing was performed in accordance with the Environmental Protection Agency (EPA) testing methodology in Title 40 Code of Federal Regulations, Part 60 (40 CFR 60) Appendix A, as outlined in the protocol, and the Oregon Department of Environmental Quality Source Sampling Manual. Table 1 summarizes the results for the emission factor verification. Table 2 provides the average results for facial velocity measurements via the differential pressure approach for permanent total enclosure verification of the raw materials handling area.

**Table 1** CFU Emission Factor Verification Results Summary

Analyte	CFU 108	CFU 112	CFU 113	CFU 115	CFU 118
	lb/ton glass				
Dichlorodifluoromethane	<8.82E-04	<4.70E-04	<4.05E-05	<5.72E-03	<2.99E-03
Chloromethane	<3.68E-04	1.96E-04	1.69E-05	4.08E-02	3.84E-03
Freon 114	<1.25E-03	<6.64E-04	<5.72E-05	<8.09E-03	<4.22E-03
Vinyl chloride	<4.56E-04	<2.43E-04	<2.09E-05	<2.96E-03	<1.54E-03
1,3-Butadiene	<3.95E-04	<2.21E-04	5.79E-04	<2.56E-03	<1.34E-03
Bromomethane	<6.93E-04	<3.69E-04	<3.18E-05	<4.49E-03	<2.35E-03
Chloroethane	<4.71E-04	<2.51E-04	<2.16E-05	<3.05E-03	<1.59E-03
Freon 11	<1.00E-03	<5.34E-04	<4.60E-05	<6.50E-03	<3.39E-03
Freon 113	<1.37E-03	<7.28E-04	<6.27E-05	<8.87E-03	<4.63E-03
1,1-Dichloroethene	<7.07E-04	<3.77E-04	<3.25E-05	<4.59E-03	<2.40E-03
Acetone	1.24E-02	1.92E-02	5.48E-03	4.31E-01	4.97E-02
Carbon disulfide	<5.56E-04	<2.96E-04	3.82E-05	<3.60E-03	<1.88E-03
Methylene chloride	<6.20E-04	<3.30E-04	<2.84E-05	<4.02E-03	<2.10E-03
trans-1,2-Dichloroethene	<7.07E-04	<3.77E-04	<3.25E-05	<4.59E-03	<2.40E-03
Methyl t-butyl ether	<6.43E-04	<3.42E-04	<2.95E-05	<4.17E-03	<2.18E-03
Vinyl acetate	<6.28E-04	<3.34E-04	<2.88E-05	<4.07E-03	<2.13E-03
2-Butanone	<5.71E-04	<7.83E-04	7.24E-05	1.37E-02	<1.88E-03
cis-1,2-Dichloroethene	<7.07E-04	<3.77E-04	<3.25E-05	<4.59E-03	<2.40E-03
1,1-Dichloroethane	<7.22E-04	<3.84E-04	<3.31E-05	<4.68E-03	<2.45E-03
Ethyl acetate	<1.29E-03	<6.85E-04	<5.90E-05	<8.34E-03	<4.35E-03
Hexane	2.00E-03	1.64E-02	7.89E-04	6.25E-01	4.86E-02
Chloroform	<8.71E-04	<4.64E-04	<4.00E-05	<5.65E-03	<2.95E-03
Tetrahydrofuran	<5.26E-04	<2.80E-04	<2.41E-05	<3.41E-03	<1.78E-03

Analyte	CFU 108	CFU 112	CFU 113	CFU 115	CFU 118
	lb/ton glass				
1,2-Dichloroethane	<7.22E-04	<3.84E-04	<3.31E-05	<4.68E-03	<2.45E-03
1,1,1-Trichloroethane	<9.73E-04	<5.18E-04	<4.47E-05	<6.31E-03	<3.30E-03
Carbon tetrachloride	<1.12E-03	<5.98E-04	<5.15E-05	<7.28E-03	<3.80E-03
Benzene	1.10E-03	4.24E-03	1.31E-03	1.08E-01	9.88E-03
Cyclohexane	<6.14E-04	<3.27E-04	<2.82E-05	<6.65E-03	<2.08E-03
Trichloroethene	<9.59E-04	<5.10E-04	<4.40E-05	<6.22E-03	<3.25E-03
1,2-Dichloropropane	<8.24E-04	<4.39E-04	<3.78E-05	<5.35E-03	<2.79E-03
Bromodichloromethane	<1.20E-03	<6.36E-04	<5.49E-05	<7.75E-03	<4.05E-03
Heptane	<7.31E-04	1.59E-03	<5.53E-05	4.16E-02	7.84E-03
cis-1,3-Dichloropropene	<8.10E-04	<4.31E-04	<3.72E-05	<5.25E-03	<2.74E-03
4-Methyl-2-pentanone	<7.31E-04	<3.89E-04	<3.35E-05	<4.99E-03	<2.47E-03
trans-1,3-Dichloropropene	<8.10E-04	<4.31E-04	<3.72E-05	<5.25E-03	<2.74E-03
1,1,2-Trichloroethane	<9.73E-04	<5.18E-04	<4.47E-05	<6.31E-03	<3.30E-03
Toluene	5.14E-03	1.26E-02	3.28E-04	1.09E-01	2.34E-02
2-Hexanone	<1.46E-03	<7.78E-04	<6.71E-05	<9.48E-03	<4.95E-03
Tetrachloroethene	<1.21E-03	<6.44E-04	<5.55E-05	<7.85E-03	<4.10E-03
Dibromochloromethane	<1.52E-03	<8.09E-04	<6.97E-05	<9.86E-03	<5.15E-03
1,2-Dibromoethane	<1.37E-03	<7.30E-04	<6.29E-05	<8.89E-03	<4.64E-03
Chlorobenzene	<8.21E-04	<4.37E-04	<3.77E-05	<5.33E-03	<2.78E-03
Ethyl benzene	<8.85E-04	<4.62E-04	<3.56E-05	<5.66E-03	<2.62E-03
m,p-Xylene	<2.10E-03	<8.25E-04	<7.11E-05	<1.17E-02	<5.25E-03
o-Xylene	<9.96E-04	<4.12E-04	<3.56E-05	<5.02E-03	<2.62E-03
Styrene	<1.52E-03	<8.09E-04	<6.98E-05	<9.86E-03	<5.15E-03
Bromoform	<3.69E-03	<1.96E-03	<1.69E-04	<2.39E-02	<1.25E-02
1,1,2,2-Tetrachloroethane	<1.22E-03	<6.52E-04	<5.62E-05	<7.94E-03	<4.15E-03
4-Ethyl toluene	<1.75E-03	<9.34E-04	<8.05E-05	<1.14E-02	<5.94E-03
1,3,5-Trimethylbenzene	<1.75E-03	<9.34E-04	<8.05E-05	<1.14E-02	<5.94E-03
1,2,4-Trimethylbenzene	<1.75E-03	<9.34E-04	<8.05E-05	<1.14E-02	<5.94E-03
1,3-Dichlorobenzene	<2.15E-03	<1.14E-03	<9.85E-05	<1.39E-02	<7.26E-03
1,4-Dichlorobenzene	<2.15E-03	<1.14E-03	<9.85E-05	<1.39E-02	<7.26E-03
Benzyl chloride	<1.85E-03	<9.84E-04	<8.48E-05	<1.20E-02	<6.26E-03
1,2-Dichlorobenzene	<2.15E-03	<1.14E-03	<9.85E-05	<1.39E-02	<7.26E-03
1,2,4-Trichlorobenzene	<2.65E-03	<1.41E-03	<1.22E-04	<1.72E-02	<8.97E-03
Hexachloro-1,3-butadiene	<3.81E-03	<2.03E-03	<1.75E-04	<2.47E-02	<1.29E-02

**Note** The symbol '<' indicates that the actual result is less than the numerical value listed. The value shown was calculated using the reporting limit (RL) for lab results that are less than the RL.

CFU – ceramic filtration unit

lb/ton-glass – pounds per ton of glass pulled

**Table 2** Raw Materials Handling Permanent Total Enclosure Evaluation Summary

Parameter	Units	Test Result	Limit	Pass/Fail
NEAR Ratio	NA	No NDOs	$\leq 0.05$	NA
Facial velocity (via differential pressure measurement approach)	inH <sub>2</sub> O	All readings were below -0.007.	$\leq -0.007$	Pass
Distance to any NDO from each emission point	Equivalent opening diameters	No NDOs	$\geq 4$	NA
Inward direction of airflow	NA	No NDOs	NA	NA

NEAR – natural draft opening to enclosure area ratio

inH<sub>2</sub>O – inches of water

NDO – natural draft opening

NA – not applicable

**Note** Please see Section 3.1.2 for full discussion of permanent total enclosure evaluation and Table 9 for all differential pressure measurements.

## TABLE OF CONTENTS

---

EXECUTIVE SUMMARY .....	2
TABLE OF CONTENTS .....	5
CERTIFICATION FROM RESPONSIBLE OFFICIAL .....	7
REVIEW AND CERTIFICATION.....	8
1.0 INTRODUCTION .....	9
1.1 Project Summary and Objectives.....	9
1.2 Project Contacts .....	10
1.3 Testing Personnel.....	11
2.0 SOURCE DESCRIPTION .....	12
2.1 Facility Description .....	12
2.2 Emission Source Description .....	12
3.0 EMISSION TEST RESULTS .....	13
3.1 Summary of Results.....	13
3.1.1 Emission Factor Verification Results.....	13
3.1.2 PTE Verification Results.....	16
3.2 Operating Conditions.....	17
3.3 Field Observations .....	17
3.4 Method 18 Acknowledgement.....	17
4.0 EMISSION TEST METHODS AND PROCEDURES.....	18
4.1 Testing Methods and Procedures.....	18
4.2 Sample Handling and Analytical Procedures .....	18
4.3 Audit Samples .....	19

## LIST OF TABLES

---

Table 1 CFU Emission Factor Verification Results Summary.....	2
Table 2 Raw Materials Handling Permanent Total Enclosure Evaluation Summary .....	4
Table 3 Project Matrix.....	9
Table 4 CFU 113 Gas Stream Characteristics .....	13
Table 5 CFU 112 Gas Stream Characteristics .....	14
Table 6 CFU 108 Gas Stream Characteristics .....	14
Table 7 CFU 115 Gas Stream Characteristics .....	15
Table 8 CFU 118 Gas Stream Characteristics .....	15
Table 9 Differential Pressure Measurement Summary.....	16

## **LIST OF APPENDICES**

---

APPENDIX A:	CFU 113 Test Data
APPENDIX B:	CFU 112 Test Data
APPENDIX C:	CFU 108 Test Data
APPENDIX D:	CFU 115 Test Data
APPENDIX E:	CFU 118 Test Data
APPENDIX F:	M204 Test Data
APPENDIX G:	Laboratory Reports
APPENDIX H:	Plant Operating Records
APPENDIX I:	Calibrations and Certifications

**CERTIFICATION FROM RESPONSIBLE OFFICIAL**

---

I have reviewed the information being submitted in its entirety. Based on information and belief formed after reasonable inquiry, I certify that the statements and information contained in this submittal are true, accurate, and complete.



02/03/2023

Signature

Date

Anita Ragan

Name (printed)

EHS Manager

Title

Hollingsworth & Vose

Company



## REVIEW AND CERTIFICATION

---

All work, calculations, other activities, and tasks performed and documented in this report were carried out under my direction and supervision. This test project conforms to the requirements of Bison Engineering, Inc.'s quality manual and American Society for Testing and Materials (ASTM) D7036-04.

Project Manager: Jacob Rankin, QSTI, EIT

Title: Helena Source Team Lead

Signature: *Jacob Rankin*

Date: 2/3/2023

I have reviewed all testing details, calculations, results, conclusions and other appropriate written material contained herein, and hereby certify that the presented material is authentic and accurate.

Reviewer: Jennifer Kessler, QI

Title: Quality Manager / Environmental Scientist

Signature: *Jennifer Kessler*

Date: 2/3/2023

## 1.0 INTRODUCTION

### 1.1 Project Summary and Objectives

Hollingsworth & Vose Fiber Company (H&V) contracted Bison Engineering, Inc. (Bison) to perform emissions testing on the rotary coarse, ultra rotary coarse, glass furnace, flameblown, and rotary fine CFUs (108, 112, 113, 115, and 118 respectively), and permanent total enclosure verification on the raw materials handling area at the H&V facility in Corvallis, Oregon. Bison performed the testing in accordance with the pre-test protocol dated November 13, 2022, that was submitted to the Oregon Department of Environmental Quality (ODEQ). Testing was performed pursuant to ODEQ Air Contaminant Discharge Permit #02-2173-ST-01. Bison employed U.S. Environmental Protection Agency (EPA) test methods as described in Title 40 Code of Federal Regulations, Part 60 (40 CFR 60), Appendix A. The pollutants measured include speciated organic toxic air contaminants (TAC). In addition, carbon dioxide (CO<sub>2</sub>), oxygen (O<sub>2</sub>), stack flow rate and moisture were measured for mass emission rate determinations. Table 3 summarizes the test methods used during the test campaign.

**Table 3** Project Matrix

Source	EPA Method	Parameter	Test Plan and Comments
CFU 108	1	Sampling location and traverse points	Once per source, prior to testing.
	2	Velocity/flow rate	One traverse per run in addition to a cyclonic flow check prior to testing.
CFU 112	3A	O <sub>2</sub> , CO <sub>2</sub> , molecular weight	Three, 60-minute test runs concurrently with TO-15.
CFU 113		Moisture	
CFU 115	4		
CFU 118	TO-15	Speciated Organic TAC	Three, 60-minute test runs.
Raw Materials Handling Area	204	Verification of PTE	Three rounds of five differential pressure measurements at potential NDOs*

PTE - permanent total enclosure

NDO - natural draft opening

CFU-108 Rotary Coarse - Glass Plant 1 (GP 1)

CFU-112 Ultra-Rotary Coarse - Glass Plant 1 (GP 1)

CFU-113 Glass Furnace - Glass Plant 1 (GP 1)

CFU-115 Flameblown - Glass Plant 1 (GP 2)

CFU-118 Rotary Fine - Glass Plant 1 (GP 2)

\*No true NDOs were visible.

## 1.2 Project Contacts

**Facility:** **Hollingsworth & Vose Fiber Company**  
**Address:** 1115 SE Crystal Lake Drive  
Corvallis, OR 97333  
**Contact:** Anita Ragan  
**Phone:** (541) 738-5382  
**Email:** anita.ragan@hovo.com

**Consultant:** **Bison Engineering, Inc.**  
**Address:** 3143 E. Lyndale Avenue  
Helena, MT 59601  
**Contact:** Conor Fox  
**Phone:** (406) 442-5768  
**Email:** cfox@bison-eng.com

**Consultant:** **Bison Engineering, Inc.**  
**Address:** 3143 E. Lyndale Avenue  
Helena, MT 59601  
**Contact:** Jacob Rankin  
**Phone:** (406) 442-5768  
**Email:** jrankin@bison-eng.com

**State Authority:** **Oregon Department of Environmental Quality**  
**Address:** 4026 Fairview Industrial Dr. SE  
Salem, OR 97302  
**Contact:** Julia DeGagné  
**Phone:** (503) 866-9643  
**Email:** julia.degagne@deq.oregon.gov

**Contract Laboratory:** **ALS Environmental**  
**Address:** 960 Levoy Dr.  
Salt Lake City, UT 84123  
**Contact:** Paul Pope  
**Phone:** (801) 266-7700  
**Website:** www.alsglobal.com

### **1.3 Testing Personnel**

The Bison on-site testing team was led by Conor Fox, Qualified Source Testing Individual (QSTI), Project Scientist. He was assisted during field testing by Matt Kruger, Qualified Individual (QI), Environmental Scientist. Mr. Fox served as project manager during the field operations. Jacob Rankin, QSTI, Environmental Engineer, assumed project manager responsibilities for the remainder of the project following Mr. Fox's departure from Bison. Joanne Sufi, QSTI, Environmental Engineer, processed the test data and authored this report. Jennifer Kessler, QI, Environmental Scientist/Quality Manager, performed a final quality assurance review of the data and test report.

Anita Ragan, Environmental Health & Safety Manager, was the primary contact for H&V. Ms. Ragan was on-site during testing. H&V staff members were responsible for monitoring process parameters during testing.

Julia DeGagné and Mike Eisley from ODEQ were on-site during the test campaign and observed a portion of the testing.

## **2.0 SOURCE DESCRIPTION**

---

### **2.1 Facility Description**

H&V operates a glass fiber manufacturing facility in Corvallis, Oregon, consisting of two glass plants. The glass plants generally operate 24 hours per day throughout the year. H&V melts raw materials to produce molten glass in two electrically heated furnaces. The molten glass is used to produce glass fiber in four different size/manufacturing classifications: rotary fine, rotary coarse, ultra-rotary coarse, and flameblown. The emissions from all fiberizers and the glass furnaces are controlled by ceramic filtration units (CFUs)

### **2.2 Emission Source Description**

Emission factor verification was performed on the rotary fine (CFU 118), rotary coarse (CFU 108), ultra-rotary coarse (CFU 112), glass furnace (CFU 113), and the flameblown (CFU 115) units. These CFUs represent emission points from the four types/sizes of glass fiber manufactured at the facility.

CFUs 108, 112, and 118 exhaust stacks are 30 inches inner diameter. The CFU 115 exhaust stack is 36 inches inner diameter. The CFU 113 exhaust stack is 20 inches inner diameter. Purpose-built sampling ports utilized are accessible via stairs and a platform for all sources.

While on-site, Bison verified each exhaust stack meets EPA Method 1 specifications; detailed Method 1 information is included in the appendices to this report.

## 3.0 EMISSION TEST RESULTS

### 3.1 Summary of Results

#### 3.1.1 Emission Factor Verification Results

Test results for CFUs 108, 112, 113, 115, and 118 were presented in the executive summary. In addition to the TACs identified, compounds were listed in the lab report labeled Tentatively Identified Compounds (TIC). Bison has elected not to include these compounds with the total TACs as the EPA states that due to the uncertainty of the identification of the TIC, the interpretation of these results is difficult. Complete results for both TACs and TICs have been included in the report appendices.

Tables 4 through 8 present the testing parameters measured. These parameters are used in the calculation of mass flow rates. On December 14, 2022, three test runs were performed on CFU 115, then at the request of ODEQ, three additional runs were performed using a heated sample line. A total of six test runs were performed on CFU 115; test runs one through three are used for informational purposes and are not included in final calculations. All CFU 115 data is included in the appendices and runs four through six are presented in Table 7. Additional supporting material, including raw data, plant data, example calculations and calibration records, can be found in the appendices to this report.

**Table 4** CFU 113 Gas Stream Characteristics

Run	1	2	3	Average
Date	12/13/2022			
Run Start Time	6:55	8:05	9:20	
Run End Time	7:54	9:04	10:19	
Duration, min.	61	61	61	
Stack Diameter, in.	20.00	20.00	20.00	
Stack Area, sq.ft.	2.182	2.182	2.182	
Barometric Pressure, "Hg	30.00	30.01	30.00	30.00
Static Pressure, "H <sub>2</sub> O	0.70	0.70	0.70	0.70
Stack Temperature, °F	125	128	122	125
CO <sub>2</sub> , %vd	0.77	0.77	0.82	0.79
O <sub>2</sub> , %vd	20.53	20.52	20.54	20.53
H <sub>2</sub> O, %v	1.44	1.65	1.68	1.59
Wet Molecular Weight, lb/lb-mole	28.78	28.76	28.77	28.77
Velocity, FPS	78.54	72.06	73.35	74.65
WSCFM	9,317	8,509	8,745	8,857
DSCFM	9,183	8,368	8,598	8,716
Production Data, lb/hr	3,959.3	4,143.4	4,077.5	4,060.1

**Table 5** CFU 112 Gas Stream Characteristics

Run	1	2	3	Average
Date	12/13/2022			
Run Start Time	10:35	11:45	13:00	
Run End Time	11:34	12:44	13:59	
Duration, min.	60	60	60	
Stack Diameter, in.	30.00	30.00	30.00	
Stack Area, sq.ft.	4.909	4.909	4.909	
Barometric Pressure, "Hg	30.02	30.02	30.02	30.02
Static Pressure, "H <sub>2</sub> O	0.92	0.92	0.92	0.92
Stack Temperature, °F	188	191	191	190
CO <sub>2</sub> , %vd	0.46	0.46	0.46	0.46
O <sub>2</sub> , %vd	20.41	20.39	20.41	20.40
H <sub>2</sub> O, %v	1.38	1.51	1.56	1.48
Wet Molecular Weight, lb/lb-mole	28.74	28.73	28.72	28.73
Velocity, FPS	73.76	71.63	74.83	73.41
WSCFM	17,803	17,214	17,978	17,665
DSCFM	17,558	16,954	17,698	17,403
Production Data, lb/hr	700.8	692.8	700.0	697.9

**Table 6** CFU 108 Gas Stream Characteristics

Run	1	2	3	Average
Date	12/13/2022			
Run Start Time	14:30	15:40	16:50	
Run End Time	15:29	16:39	17:49	
Duration, min.	60	60	60	
Stack Diameter, in.	30.00	30.00	30.00	
Stack Area, sq.ft.	4.909	4.909	4.909	
Barometric Pressure, "Hg	30.00	30.00	30.00	30.00
Static Pressure, "H <sub>2</sub> O	0.55	0.55	0.55	0.55
Stack Temperature, °F	194	208	209	204
CO <sub>2</sub> , %vd	0.58	0.57	0.58	0.58
O <sub>2</sub> , %vd	20.12	20.13	20.12	20.12
H <sub>2</sub> O, %v	3.14	1.30	1.50	1.98
Wet Molecular Weight, lb/lb-mole	28.56	28.76	28.74	28.69
Velocity, FPS	76.17	79.89	78.76	78.27
WSCFM	18,178	18,684	18,372	18,411
DSCFM	17,607	18,441	18,097	18,048
Production Data, lb/hr	385.7	390.4	380.1	385.4

**Table 7** CFU 115 Gas Stream Characteristics

Run	4	5	6	Average
Date	12/14/2022			
Run Start Time	13:05	14:15	15:25	
Run End Time	14:04	15:14	16:24	
Duration, min.	60	60	60	
Stack Diameter, in.	36.00	36.00	36.00	
Stack Area, sq.ft.	7.069	7.069	7.069	
Barometric Pressure, "Hg	30.15	30.15	30.15	30.15
Static Pressure, "H <sub>2</sub> O	-0.72	-0.72	-0.72	-0.72
Stack Temperature, °F	272	269	272	271
CO <sub>2</sub> , %vd	0.64	0.64	0.63	0.63
O <sub>2</sub> , %vd	20.04	20.04	20.04	20.04
H <sub>2</sub> O, %v	1.96	2.08	1.78	1.94
Wet Molecular Weight, lb/lb-mole	28.69	28.67	28.71	28.69
Velocity, FPS	63.73	63.41	62.82	63.32
WSCFM	19,603	19,595	19,341	19,513
DSCFM	19,219	19,187	18,996	19,134
Production Data, lb/hr	63.0	63.0	63.0	63.0

Note CFU 115 Runs 1-3 are presented in the appendices to this report.

**Table 8** CFU 118 Gas Stream Characteristics

Run	1	2	3	Average
Date	12/15/2022			
Run Start Time	8:20	9:30	10:40	
Run End Time	9:19	10:29	11:39	
Duration, min.	60	60	60	
Stack Diameter, in.	30.00	30.00	30.00	
Stack Area, sq.ft.	4.909	4.909	4.909	
Barometric Pressure, "Hg	30.21	30.21	30.21	30.21
Static Pressure, "H <sub>2</sub> O	-0.73	-0.73	-0.73	-0.73
Stack Temperature, °F	222	225	226	224
CO <sub>2</sub> , %vd	0.54	0.55	0.54	0.54
O <sub>2</sub> , %vd	20.19	20.21	20.23	20.21
H <sub>2</sub> O, %v	1.13	1.39	1.17	1.23
Wet Molecular Weight, lb/lb-mole	28.77	28.75	28.76	28.76
Velocity, FPS	75.52	79.33	76.08	76.97
WSCFM	17,342	18,147	17,392	17,627
DSCFM	17,146	17,895	17,188	17,410
Production Data, lb/hr	108.7	110.3	110.3	109.8



### 3.1.2 PTE Verification Results

Bison followed EPA Method 204 to assess whether the raw materials handling area meets the criteria for a PTE. The building did not have any true NDOs visible. For the purposes of Method 204 verification, differential pressure measurements were taken from 5 potential NDOs, all of which are normally closed during regular operations. Drawings identifying the location of potential NDO's are included in the report appendices. All potential NDO's were sealed off with plastic and a small opening of approximately one inch was used to measure the differential pressure. Field personnel did not measure the area of the potential NDO's, and a NEAR value was not calculated because every potential NDO was confirmed to be fully sealed by the plastic. It is Bison's understanding that H&V intends to install high-speed roll up doors to ensure the enclosure envelope remains sealed. Inward direction of air flow was not shown with photographic evidence because the average FV was greater than 500 fpm, and there were no true NDOs.

Direct measurements of differential pressure were used in lieu of a calculated FV following Method 204, eq. 204-3. Pressure differential at all measurement locations were greater than -0.007 inches H<sub>2</sub>O. Table 9 summarizes the differential pressure measurements. All direct measurements of differential pressure were made using a Shortridge ADM-850L micromanometer with a four decimal place display and current calibration certificate demonstrating instrument accuracy to differential pressures as low as 0.0100 inches of water. Differential pressure measurements were recorded in a series of three rounds; during each round, five measurements were recorded per location.

**Table 9** Differential Pressure Measurement Summary

Measurement Location	Units	Round 1 Average	Round 2 Average	Round 3 Average	Overall Average
North Man Door	in H <sub>2</sub> O	-0.0388	-0.0181	-0.0257	-0.0275
NE Load In/Out Door	in H <sub>2</sub> O	-0.0135	-0.0238	-0.0193	-0.0189
SE Load In/Out Door	in H <sub>2</sub> O	-0.0171	-0.0200	-0.0121	-0.0164
Second Floor Load In/Out Door	in H <sub>2</sub> O	-0.0362	-0.0312	-0.0138	-0.0271
Second Floor Man Door	in H <sub>2</sub> O	-0.3050	-0.0851	-0.6055	-0.3319

in H<sub>2</sub>O – inches of water

## **3.2 Operating Conditions**

H&V personnel compiled the raw process data and details of plant operations during testing and provided them to Bison for use in this report. Process data is presented in the report appendices and was used to calculate lb/ton glass.

## **3.3 Field Observations**

Testing was performed as outlined in the test protocol. No adverse or unusual environmental conditions were noted that are known to have influenced the outcome of these tests.

Six test runs were conducted on CFU 115 on December 14, 2022. All data from these runs is presented in the appendices to this report, however, only runs 4 through 6 are used to calculate emissions in lb/ton of glass.

Field personnel did not perform stratification checks on all the CFUs. Bison has sampled from these sources multiple instances preceding this test campaign and has verified they were previously not stratified. No major process changes were noted that would change the overall flow profile or gas composition of the exhaust stream which would trigger the necessity to perform a stratification test.

The large time difference from the completion of the calibrations for CFU 118 to the beginning of the stratification test can be attributed to the field personnel finishing the instrument calibration procedure first and then finishing the setup of the moisture and TAC sampling equipment.

## **3.4 Method 18 Acknowledgement**

Bison would like to acknowledge ODEQ's Test Method Specific Comments, 1. c. in the protocol approval letter dated November 23, 2022, "For organic TACs detected at concentrations greater than 1 part per million by volume (ppmv) using TO-15, DEQ may require quantification using an approvable stack test method such as EPA Method 18."

Method 18 samples were collected, but were not analyzed, since no TACs were detected at concentrations greater than 1 ppmv.

## 4.0 EMISSION TEST METHODS AND PROCEDURES

---

### 4.1 Testing Methods and Procedures

Bison testing personnel performed the following EPA methods as described in 40 CFR 60, Appendix A. Instrumental analyzers used by Bison to measure pollutant and diluent concentrations in stack gas are purpose-built by reputable companies and have been subjected to comprehensive interference response test procedures by their respective manufacturers. Further documentation regarding interferences for individual analyzers can be provided upon request.

**EPA Reference Method 1, "Sample and Velocity Traverses for Stationary Sources."** The objective of Method 1 is to determine a suitable location for testing and to determine the velocity and/or sample points for the source. The results of Method 1 sampling location and sample or velocity point measurement locations are included in the appendices.

**EPA Reference Method 2, "Determination of Stack Gas Velocity and Volumetric Flow Rate (Type-S Pitot Tube)."** The objective of Method 2 is to determine volumetric flow. The average velocity, temperature, static pressure, and source area are used to calculate volumetric flow for the source.

**EPA Reference Method 3A, "Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)."** The objective of Method 3A is to determine the O<sub>2</sub> and CO<sub>2</sub> concentrations in the stack gas stream.

**EPA Reference Method 204, "Criteria for and Verification of a Permanent or Temporary Total Enclosure."** The objective of Method 204 is to determine whether a permanent or temporary enclosure meets the criteria for being considered a total enclosure. If all the criteria are met, then the volatile organic compound capture efficiency (CE) is assumed to be 100 percent.

**EPA TO-15, "Determination of Volatile Organic Compounds (VOC) in Air Collected in Specially prepared Canisters and Analyzed by Gas Chromatography/Mass Spectrometry (GC/MS)."** The objective of TO-15 is to determine speciated organic TAC analytes from a source.

### 4.2 Sample Handling and Analytical Procedures

Sampling procedures are cited in the appropriate methods and there was no deviation from those methods. Bison's project manager retained custody of the samples until relinquishing them to Bison's Helena, Montana qualified lab personnel to be shipped to ALS Environmental for TO-15 analysis. A chain of custody is included in the appendices.

### **4.3 Audit Samples**

The stationary source audit program (SSAP) is effectively suspended as of March 2022 because there are currently no independent accredited audit sample providers (AASP).

## **APPENDIX A: CFU 113 TEST DATA**

---

Hollingsworth & Vose  
 Corvallis, OR  
 CFU 113 Speciated Organic Toxic Air Contaminants (TAC)

Run Number	1	2	3
Sample Collection Date	12/13/2022	12/13/2022	12/13/2022
Glass Production Rate Supplied by H&V (lb/hr)	3,959.3	4,143.4	4,077.5
Volumetric Flow Rate Measured by Bison (dscfm)	9.183	8.368	8.600

Analyte	Molecular Weight g/mol	CFU 113-1				CFU 113-2				CFU 113-3				CFU 113 Averages			
		ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass
Dichlorodifluoromethane	120.9129	< 0.5	< 5.0E-04	< 8.65E-05	< 4.37E-05	< 0.5	< 5.0E-04	< 7.88E-05	< 3.80E-05	< 0.5	< 5.0E-04	< 8.10E-05	< 3.97E-05	< 0.50	< 5.0E-04	< 8.21E-05	< 4.05E-05
Chloromethane	50.4872	< 0.5	< 5.0E-04	< 3.61E-05	< 1.82E-05	< 0.5	< 5.0E-04	< 3.29E-05	< 1.59E-05	< 0.5	< 5.0E-04	< 3.38E-05	< 1.66E-05	< 0.50	< 5.0E-04	< 3.43E-05	< 1.69E-05
Freon 114	170.92	< 0.5	< 5.0E-04	< 1.22E-04	< 6.18E-05	< 0.5	< 5.0E-04	< 1.11E-04	< 5.38E-05	< 0.5	< 5.0E-04	< 1.15E-04	< 5.62E-05	< 0.50	< 5.0E-04	< 1.16E-04	< 5.72E-05
Vinyl chloride	62.50	< 0.5	< 5.0E-04	< 4.47E-05	< 2.26E-05	< 0.5	< 5.0E-04	< 4.07E-05	< 1.97E-05	< 0.5	< 5.0E-04	< 4.19E-05	< 2.05E-05	< 0.50	< 5.0E-04	< 4.24E-05	< 2.09E-05
1,3-Butadiene	54.0904	16	1.6E-02	1.24E-03	6.25E-04	17	1.7E-02	1.20E-03	5.79E-04	15	1.5E-02	1.09E-03	5.33E-04	16.00	1.6E-02	1.17E-03	5.79E-04
Bromomethane	94.94	< 0.5	< 5.0E-04	< 6.79E-05	< 3.43E-05	< 0.5	< 5.0E-04	< 6.19E-05	< 2.99E-05	< 0.5	< 5.0E-04	< 6.36E-05	< 3.12E-05	< 0.50	< 5.0E-04	< 6.45E-05	< 3.18E-05
Chloroethane	64.51	< 0.5	< 5.0E-04	< 4.61E-05	< 2.33E-05	< 0.5	< 5.0E-04	< 4.21E-05	< 2.03E-05	< 0.5	< 5.0E-04	< 4.32E-05	< 2.12E-05	< 0.50	< 5.0E-04	< 4.38E-05	< 2.16E-05
Freon 11	137.3672	< 0.5	< 5.0E-04	< 9.83E-05	< 4.96E-05	< 0.5	< 5.0E-04	< 8.95E-05	< 4.32E-05	< 0.5	< 5.0E-04	< 9.20E-05	< 4.51E-05	< 0.50	< 5.0E-04	< 9.33E-05	< 4.60E-05
Freon 113	187.38	< 0.5	< 5.0E-04	< 1.34E-04	< 6.77E-05	< 0.5	< 5.0E-04	< 1.22E-04	< 5.90E-05	< 0.5	< 5.0E-04	< 1.26E-04	< 6.16E-05	< 0.50	< 5.0E-04	< 1.27E-04	< 6.27E-05
1,1-Dichloroethene	96.9427	< 0.5	< 5.0E-04	< 6.93E-05	< 3.50E-05	< 0.5	< 5.0E-04	< 6.32E-05	< 3.05E-05	< 0.5	< 5.0E-04	< 6.49E-05	< 3.19E-05	< 0.50	< 5.0E-04	< 6.58E-05	< 3.25E-05
Acetone	58.08	250	2.5E-01	2.08E-02	1.05E-02	94	9.4E-02	7.12E-03	3.44E-03	66	6.6E-02	5.14E-03	2.52E-03	136.67	1.4E-01	1.10E-02	5.48E-03
Carbon disulfide	76.143	0.77	7.7E-04	8.39E-05	4.24E-05	0.8	8.0E-04	7.94E-05	3.83E-05	0.68	6.8E-04	6.94E-05	3.40E-05	0.75	7.5E-04	7.76E-05	3.82E-05
Methylene chloride	84.9320	< 0.5	< 5.0E-04	< 6.08E-05	< 3.07E-05	< 0.5	< 5.0E-04	< 5.54E-05	< 2.67E-05	< 0.5	< 5.0E-04	< 5.69E-05	< 2.79E-05	< 0.50	< 5.0E-04	< 5.77E-05	< 2.84E-05
trans-1,2-Dichloroethene	96.9427	< 0.5	< 5.0E-04	< 6.93E-05	< 3.50E-05	< 0.5	< 5.0E-04	< 6.32E-05	< 3.05E-05	< 0.5	< 5.0E-04	< 6.49E-05	< 3.19E-05	< 0.50	< 5.0E-04	< 6.58E-05	< 3.25E-05
Methyl t-butyl ether	88.1482	< 0.5	< 5.0E-04	< 6.31E-05	< 3.19E-05	< 0.5	< 5.0E-04	< 5.75E-05	< 2.77E-05	< 0.5	< 5.0E-04	< 5.91E-05	< 2.90E-05	< 0.50	< 5.0E-04	< 5.99E-05	< 2.95E-05
Vinyl acetate	86.0892	< 0.5	< 5.0E-04	< 6.16E-05	< 3.11E-05	< 0.5	< 5.0E-04	< 5.61E-05	< 2.71E-05	< 0.5	< 5.0E-04	< 5.77E-05	< 2.83E-05	< 0.50	< 5.0E-04	< 5.85E-05	< 2.88E-05
2-Butanone	72.1057	0.87	8.7E-04	8.98E-05	4.53E-05	1.7	1.7E-03	1.60E-04	7.71E-05	2.0	2.0E-03	1.93E-04	9.48E-05	1.52	1.5E-03	1.48E-04	7.24E-05
cis-1,2-Dichloroethene	96.9427	< 0.5	< 5.0E-04	< 6.93E-05	< 3.50E-05	< 0.5	< 5.0E-04	< 6.32E-05	< 3.05E-05	< 0.5	< 5.0E-04	< 6.49E-05	< 3.19E-05	< 0.50	< 5.0E-04	< 6.58E-05	< 3.25E-05
1,1-Dichloroethane	98.9586	< 0.5	< 5.0E-04	< 7.08E-05	< 3.58E-05	< 0.5	< 5.0E-04	< 6.45E-05	< 3.11E-05	< 0.5	< 5.0E-04	< 6.63E-05	< 3.25E-05	< 0.50	< 5.0E-04	< 6.72E-05	< 3.31E-05
Ethyl acetate	88.1051	< 1.0	< 1.0E-03	< 1.26E-04	< 6.37E-05	< 1.0	< 1.0E-03	< 1.15E-04	< 5.54E-05	< 1.0	< 1.0E-03	< 1.18E-04	< 5.79E-05	< 1.00	< 1.0E-03	< 1.20E-04	< 5.90E-05
Hexane	86.1754	20	2.0E-02	2.47E-03	1.25E-03	12	1.2E-02	1.35E-03	6.51E-04	8.3	8.3E-03	9.58E-04	4.70E-04	13.43	1.3E-02	1.59E-03	7.89E-04
Chloroform	119.3767	< 0.5	< 5.0E-04	< 8.54E-05	< 4.31E-05	< 0.5	< 5.0E-04	< 7.78E-05	< 3.76E-05	< 0.5	< 5.0E-04	< 8.00E-05	< 3.92E-05	< 0.50	< 5.0E-04	< 8.11E-05	< 4.00E-05
Tetrahydrofuran	72.1057	< 0.5	< 5.0E-04	< 5.16E-05	< 2.61E-05	< 0.5	< 5.0E-04	< 4.70E-05	< 2.27E-05	< 0.5	< 5.0E-04	< 4.83E-05	< 2.37E-05	< 0.50	< 5.0E-04	< 4.90E-05	< 2.41E-05
1,2-Dichloroethane	98.9586	< 0.5	< 5.0E-04	< 7.08E-05	< 3.58E-05	< 0.5	< 5.0E-04	< 6.45E-05	< 3.11E-05	< 0.5	< 5.0E-04	< 6.63E-05	< 3.25E-05	< 0.50	< 5.0E-04	< 6.72E-05	< 3.31E-05
1,1,1-Trichloroethane	133.4033	< 0.5	< 5.0E-04	< 9.54E-05	< 4.82E-05	< 0.5	< 5.0E-04	< 8.70E-05	< 4.20E-05	< 0.5	< 5.0E-04	< 8.94E-05	< 4.38E-05	< 0.50	< 5.0E-04	< 9.06E-05	< 4.47E-05
Carbon tetrachloride	153.8215	< 0.5	< 5.0E-04	< 1.10E-04	< 5.56E-05	< 0.5	< 5.0E-04	< 1.00E-04	< 4.84E-05	< 0.5	< 5.0E-04	< 1.03E-04	< 5.05E-05	< 0.50	< 5.0E-04	< 1.04E-04	< 5.15E-05
Benzene	78.1118	18	1.8E-02	2.01E-03	1.38E-03	28	2.8E-02	2.85E-03	1.38E-03	30	3.0E-02	3.14E-03	1.54E-03	25.33	2.5E-02	2.67E-03	1.31E-03
Cyclohexane	84.1595	< 0.5	< 5.0E-04	< 6.02E-05	< 3.04E-05	< 0.5	< 5.0E-04	< 5.49E-05	< 2.65E-05	< 0.5	< 5.0E-04	< 5.64E-05	< 2.77E-05	< 0.50	< 5.0E-04	< 5.71E-05	< 2.82E-05
Trichloroethene	131.3874	< 0.5	< 5.0E-04	< 9.40E-05	< 4.75E-05	< 0.5	< 5.0E-04	< 8.56E-05	< 4.13E-05	< 0.5	< 5.0E-04	< 8.80E-05	< 4.32E-05	< 0.50	< 5.0E-04	< 8.92E-05	< 4.40E-05
1,2-Dichloropropane	112.9851	< 0.5	< 5.0E-04	< 8.08E-05	< 4.08E-05	< 0.5	< 5.0E-04	< 7.37E-05	< 3.56E-05	< 0.5	< 5.0E-04	< 7.57E-05	< 3.71E-05	< 0.50	< 5.0E-04	< 7.67E-05	< 3.78E-05
Bromodichloromethane	163.828	< 0.5	< 5.0E-04	< 1.17E-04	< 5.92E-05	< 0.5	< 5.0E-04	< 1.07E-04	< 5.15E-05	< 0.5	< 5.0E-04	< 1.10E-04	< 5.38E-05	< 0.50	< 5.0E-04	< 1.11E-04	< 5.49E-05
Heptane	100.2019	< 0.5	< 5.0E-04	< 7.17E-05	< 3.62E-05	0.7	7.0E-04	9.14E-05	4.41E-05	1.3	1.3E-03	1.75E-04	8.56E-05	0.83	8.3E-04	1.13E-04	5.53E-05
cis-1,3-Dichloropropene	110.9693	< 0.5	< 5.0E-04	< 7.94E-05	< 4.01E-05	< 0.5	< 5.0E-04	< 7.23E-05	< 3.49E-05	< 0.5	< 5.0E-04	< 7.43E-05	< 3.65E-05	< 0.50	< 5.0E-04	< 7.54E-05	< 3.72E-05
4-Methyl-2-pentanone	100.1589	< 0.5	< 5.0E-04	< 7.16E-05	< 3.62E-05	< 0.5	< 5.0E-04	< 6.53E-05	< 3.15E-05	< 0.5	< 5.0E-04	< 6.71E-05	< 3.29E-05	< 0.50	< 5.0E-04	< 6.80E-05	< 3.35E-05
trans-1,3-Dichloropropene	110.9693	< 0.5	< 5.0E-04	< 7.94E-05	< 4.01E-05	< 0.5	< 5.0E-04	< 7.23E-05	< 3.49E-05	< 0.5	< 5.0E-04	< 7.43E-05	< 3.65E-05	< 0.50	< 5.0E-04	< 7.54E-05	< 3.72E-05
1,1,2-Trichloroethane	133.4033	< 0.5	< 5.0E-04	< 9.54E-05	< 4.82E-05	< 0.5	< 5.0E-04	< 8.70E-05	< 4.20E-05	< 0.5	< 5.0E-04	< 8.94E-05	< 4.38E-05	< 0.50	< 5.0E-04	< 9.06E-05	< 4.47E-05
Toluene	92.1384	0.96	9.6E-04	1.27E-04	6.39E-05	4.4	4.4E-03	5.29E-04	2.55E-04	11	1.1E-02	1.36E-03	6.66E-04	5.45	5.5E-03	6.71E-04	3.28E-04
2-Hexanone	100.1589	< 1.0	< 1.0E-03	< 1.43E-04	< 7.24E-05	< 1.0	< 1.0E-03	< 1.31E-04	< 6.30E-05	< 1.0	< 1.0E-03	< 1.34E-04	< 6.58E-05	< 1.00	< 1.0E-03	< 1.36E-04	< 6.71E-05
Tetrachloroethene	165.833	< 0.5	< 5.0E-04	< 1.19E-04	< 5.99E-05	< 0.5	< 5.0E-04	< 1.08E-04	< 5.22E-05	< 0.5	< 5.0E-04	< 1.11E-04	< 5.45E-05	< 0.50	< 5.0E-04	< 1.13E-04	< 5.55E-05
Dibromochloromethane	208.279	< 0.5	< 5.0E-04	< 1.49E-04	< 7.53E-05	< 0.5	< 5.0E-04	< 1.36E-04	< 6.55E-05	< 0.5	< 5.0E-04	< 1.40E-04	< 6.84E-05	< 0.50	< 5.0E-04	< 1.41E-04	< 6.97E-05
1,2-Dibromoethane	187.861	< 0.5	< 5.0E-04	< 1.34E-04	< 6.79E-05	< 0.5	< 5.0E-04	< 1.22E-04	< 5.91E-05	< 0.5	< 5.0E-04	< 1.26E-04	< 6.17E-05	< 0.50	< 5.0E-04	< 1.28E-04	< 6.29E-05
Chlorobenzene	112.5566	< 0.5	< 5.0E-04	< 8.05E-05	< 4.07E-05	< 0.5	< 5.0E-04	< 7.34E-05	< 3.54E-05	< 0.5	< 5.0E-04	< 7.54E-05	< 3.70E-05	< 0.50	< 5.0E-04	< 7.64E-05	< 3.77E-05
Ethyl benzene	106.1650	< 0.5	< 5.0E-04	< 7.59E-05	< 3.84E-05	< 0.5	< 5.0E-04	< 6.92E-05	< 3.34E-05	< 0.5	< 5.0E-04	< 7.11E-05	< 3.49E-05	< 0.50	< 5.0E-04	< 7.21E-05	< 3.56E-05
m,p-Xylene	106.1650																

Hollingsworth & Vose  
 Corvallis, OR  
 CFU 113 Tentatively Identified Compounds (TIC)

Run Number	1	2	3
Sample Collection Date	12/13/2022	12/13/2022	12/13/2022
Glass Production Rate Supplied by H&V (lb/hr)	3,959.3	4,143.4	4,077.5
Volumetric Flow Rate measured by Bison (dscfm)	9,183	8,368	8,600

Analyte	Molecular Weight g/mol	CFU 113-1				CFU 113-2				CFU 113-3				CFU 113 Averages			
		ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass
Propene	42.08	81	8.1E-02	4.88E-03	2.46E-03	88	8.8E-02	4.83E-03	2.33E-03	83	8.3E-02	4.68E-03	2.30E-03	84.00	8.4E-02	4.79E-03	2.36E-03
Acetaldehyde	44.053	31	3.1E-02	1.95E-03	9.87E-04	34	3.4E-02	1.95E-03	9.43E-04	36	3.6E-02	2.12E-03	1.04E-03	33.67	3.4E-02	2.01E-03	9.91E-04
2-Butene	56.1063	40	4.0E-02	3.21E-03	1.62E-03	41	4.1E-02	3.00E-03	1.45E-03					40.50	4.1E-02	3.10E-03	1.53E-03
Butane	58.12	10	1.0E-02	8.32E-04	4.20E-04	12	1.2E-02	9.09E-04	4.39E-04	10	1.0E-02	7.79E-04	3.82E-04	10.67	1.1E-02	8.40E-04	4.14E-04
Cyclopropane, ethyl-	42.0800	12	1.2E-02	7.22E-04	3.65E-04	13	1.3E-02	7.13E-04	3.44E-04	11	1.1E-02	6.20E-04	3.04E-04	12.00	1.2E-02	6.85E-04	3.38E-04
Pentane	72.150	8.4	8.4E-03	8.67E-04	4.38E-04	8.1	8.1E-03	7.62E-04	3.68E-04	5.2	5.2E-03	5.03E-04	2.47E-04	7.23	7.2E-03	7.11E-04	3.51E-04
3-Penten-1-yne	66.101					14	1.4E-02	1.21E-03	5.82E-04					14.00	1.4E-02	1.21E-03	5.82E-04
3-Penten-1-yne, (E)-	66.101	12	1.2E-02	1.13E-03	5.73E-04									12.00	1.2E-02	1.13E-03	5.73E-04
1-Hexene	84.1600	19	1.9E-02	2.29E-03	1.16E-03					22	2.2E-02	2.48E-03	1.22E-03	20.50	2.1E-02	2.38E-03	1.19E-03
Pentane, 2,4-dimethyl-	100.20	8.4	8.4E-03	1.20E-03	6.08E-04									8.40	8.4E-03	1.20E-03	6.08E-04
Butane, 2,2,3,3-tetramethyl-	114.2285	19	1.9E-02	3.11E-03	1.57E-03									19.00	1.9E-02	3.11E-03	1.57E-03
*1-Propene, 2-methyl-	56.1063					5.8	5.8E-03	4.24E-04	2.05E-04	35	3.5E-02	2.63E-03	1.29E-03	20.40	2.0E-02	1.53E-03	7.48E-04
1,2-Pentadiene	68.1170					7.1	7.1E-03	6.31E-04	3.04E-04					7.10	7.1E-03	6.31E-04	3.04E-04
1-Butene	68.1170									5.8	5.8E-03	5.29E-04	2.60E-04	5.80	5.8E-03	5.29E-04	2.60E-04
1-Heptene	98.1861									7	7.0E-03	9.21E-04	4.52E-04	7.00	7.0E-03	9.21E-04	4.52E-04
*1-Propene, 2-methyl-	56.1063					24	2.4E-02	1.76E-03	8.47E-04	5.2				2.4E-02		1.76E-03	8.47E-04

\* This TIC has two separate results in the ALS analytical report. Both are presented here.  
 Note: Concentrations listed for all TICs are estimated values.

**Bison Engineering, Inc**  
**TO-15 Example Calculations**

**Client:** Hollingsworth & Vose  
**Location:** Corvallis, OR  
**Source:** CFU 113  
**Method:** TO-15

**Run:** 1  
**Start Time:** 6:55  
**End Time:** 7:54  
**Date:** 12/13/2022

**Ex. Run 1 1,3-Butadiene**

- 1.) Laboratory results = 16 ppbvd
- 2.) ppmvd = ppbvd/1,000 = 0.016 ppmvd
- 3.) lb/hr = (ppmvd\*dscfm\*MW\*1.558E-07) = 1.24E-03 lb/hr  
where MW: 54.0904  
flow rate: 9,183 dscfm  
ppmvd: 0.016  
Conversion Factor: 1.558E-07
- 4.) lb/ton glass = lb/hr / (Production rate/2,000) = 6.25E-04 lb/ton glass  
where lb/hr: 1.24E-03  
Production Rate: 3,959.3 lb/hr glass produced



**Bison Engineering, Inc.**  
**Gaseous Testing Summary**

Client: **Hollingsworth & Vose**  
 Facility: **Glass Plant 1**  
 Location: **Corvallis, OR**

Source: **CFU 113**  
 Test Date: **December 13, 2022**

Environmental Conditions / Test Notes: 40 °F and Foggy

Run		1	2	3	Average
Date		12/13/2022	12/13/2022	12/13/2022	
Run Start Time		6:55	8:05	9:20	
Run End Time		7:54	9:04	10:19	
Duration, min.		61	61	61	
Stack Diameter, in.		20.00	20.00	20.00	
Stack Area, sq.ft.		2.182	2.182	2.182	
Barometric Pressure, "Hg		30.00	30.01	30.01	30.01
Static Pressure, "H <sub>2</sub> O		0.70	0.70	0.70	0.70
Stack Temperature, °F		125	128	122	125
CO <sub>2</sub> , %vd		0.77	0.77	0.82	0.79
O <sub>2</sub> , %vd		20.53	20.52	20.54	20.53
H <sub>2</sub> O, %v		1.44	1.65	1.68	1.59
Wet Molecular Weight, lb/lb-mole		28.78	28.76	28.77	28.77
Velocity, FPS		78.54	72.06	73.34	74.64
WSCFM		9,317	8,509	8,747	8,858
DSCFM		9,183	8,368	8,600	8,717
Production Data, Total Glass Melt	lb/hr	3,959.3	4,143.4	4,077.5	4,060.0
Production Data, L1	lb/hr	2095.9	2107.0	2057.0	2,086.6
Production Data, L2	lb/hr	1863.4	2036.4	2020.5	1,973.4

Note: Negative concentrations are reported as zero.

**Bison Engineering, Inc.**  
**Pre-Test Traverse**

**Client:** Hollingsworth & Vose  
**Location:** Corvallis, OR  
**Source:** CFU 113

**Stack Temp:** NA °F

<b>Traverse Point</b>	<b>Velocity ΔP (H<sub>2</sub>O)</b>	<b>Null Angle</b>
1	NA	2
2	NA	3
3	NA	0
4	NA	1
5	NA	0
6	NA	2
7	NA	1
8	NA	0

Average: NA 1  
Flow is found to be: Non-cyclonic

No nozzle was needed for flow measurements, therefore no pre-velocity measurements or stack temperature was recorded prior to testing.

**Bison Engineering, Inc.**  
**EPA Method 1**  
**Stack Parameters and Traverse Points**

**Client:** Hollingsworth & Vose  
**Location:** Corvallis, OR  
**Source:** CFU 113  
**Facility:** Glass Plant 1

Type of Testing: V V for Velocity/Nonparticulate)  
 Type of Duct: C (C for circular; R for rectangular)

Number of ports available: 2  
 Number of ports to be used: 2  
 Port diameter: 5 inches  
 Sampling location height (approx.): 40.00 feet  
 Stack height (approx.): 7.00 feet

Circular ID (Rectangular Depth): 20.00 inches  
 Port depth and/or wall thickness: 6.00 inches  
 Stack width (Rectangular only): inches

Equivalent Diameter  
 If rectangular =  $\frac{2 * \text{Depth} * \text{Width}}{\text{Depth} + \text{Width}} = 20.00$  inches (If circular = duct ID)

Stack/duct area = 2.182 sq. feet 314.2 sq. inches


Sample Port Location:	Downstream flow disturbance from process	Upstream flow disturbance toward exit
	B	A
Number of Inches:	165.00	96.00
Number of Diameters:	8.25	4.80

Minimum Number of Traverse Points: 8

Traverse points less than 0.50 inch from the stack wall are relocated to a distance of 0.50 inch.

Points	% of diameter	Distance from inside wall (in.)	Distance including port (in.)
1	6.7	1.34	7 3/8
2	25.0	5.00	11
3	75.0	15.00	21
4	93.3	18.66	24 5/8

**Reference Diagram**



Drawing NOT to scale and NOT an accurate representation of stack.

**Bison Engineering, Inc.**

**Method 2**

**Stack Gas Velocity and Volumetric Flow Rate**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 1  
**Location:** Corvallis, OR

**Source:** CFU 113  
**Test Date:** 12/13/22

Molecular Weight		
Choose One by "x" below		
Measured	Ambient	Combustion
x		

Pitot ID	4E
----------	----

Leak Checks:	Run 1		Run 2		Run 3	
	Pre	Post	Pre	Post	Pre	Post
<b>Pitot</b>	x	x	x	x	x	x
<b>Barometric Pressure ("Hg)</b>	30.00		30.01		30.01	

Traverse	Sample Point	Run 1		Run 2		Run 3	
		Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)
A	1	1.90	125	1.60	127	1.50	120
	2	2.00	124	1.70	128	1.60	122
	3	2.00	126	1.70	129	1.60	123
	4	1.80	125	1.40	129	1.40	123
B	1	1.70	124	1.50	126	1.60	121
	2	1.80	125	1.50	128	1.60	123
	3	1.60	126	1.40	128	1.50	123
	4	1.40	126	1.10	129	1.60	123

Method 2 -Flow Calculations							
Static Pressure, "H <sub>2</sub> O		0.70		0.70		0.70	
Pitot tube cp		0.84		0.84		0.84	
Stack Area, ft <sup>3</sup>		2.182		2.182		2.182	
H <sub>2</sub> O, %v		1.44		1.65		1.68	
Average √ΔP		1.330		1.217		1.245	
Average Absolute Temp. ( °R )		584.8		587.7		581.9	
Stack Pressure (in. Hg)		30.05		30.06		30.06	
Stack Velocity (ft/sec)		78.54		72.06		73.34	
Actual Flow Rate (acfm)		10,280		9,432		9,600	
Standard Flow Rate (wscf/hr)		559,007		510,511		524,791	
Dry Standard Flow Rate (dscf/hr)		550,957		502,088		515,975	
Dry Standard Flow Rate (dscfm)		9,183		8,368		8,600	

	O <sub>2</sub>	CO <sub>2</sub>	Calculated N <sub>2</sub>
Run 1	20.53	0.77	78.70
Run 2	20.52	0.77	78.70
Run 3	20.54	0.82	78.64

	Molecular Weight (lb/lb-mole)					
	Calculated		Ambient		Combustion	
Run1	M <sub>d</sub>	28.94	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.78	M <sub>s</sub>		M <sub>s</sub>	
Run 2	M <sub>d</sub>	28.94	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.76	M <sub>s</sub>		M <sub>s</sub>	
Run 3	M <sub>d</sub>	28.95	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.77	M <sub>s</sub>		M <sub>s</sub>	

**Bison Engineering, Inc.**  
**Moisture Field Data**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 1  
**Location:** Corvallis, OR  
**Source:** CFU 113  
**Test date:** 12/13/2022

**Meterbox ID:** Box 11  
**Meter "Y"-Factor:** 0.9690

Moisture Field Data Entry				
Run 1				
Leak Checks:		Pre-test	Post-test	
Train leak rate, dcf		0.000	0.000	
Leak check vacuum, "Hg		16	7	
Start Time		6:55		
End Time		7:55		
Bp, "Hg		30.00		
Minutes	Meter Volume	Meter °F	Condenser °F	Delta H
	170.350			
5	174.180	40	41	1.800
10	177.970	40	41	1.800
15	181.760	40	44	1.800
20	185.530	40	44	1.800
25	189.310	41	44	1.800
30	192.980	41	46	1.800
35	196.990	42	46	1.800
40	200.620	42	46	1.800
45	204.400	42	46	1.800
50	208.190	43	48	1.800
55	211.980	43	47	1.800
60	215.760	44	48	1.800
Impinger gain by weight (g):				
#	Initial	Final	Gain	
1	779.7	784.5	4.8	
2	767.5	768.9	1.4	
3	695.9	696.5	0.6	
Silica Gel	976.1	983.8	7.7	
Impinger Totals:	2,243.1	3,233.7	6.8	

Moisture Field Data Entry				
Run 2				
Leak Checks:		Pre-test	Post-test	
Train leak rate, dcf		0.000	0.000	
Leak check vacuum, "Hg		15	5	
Start Time		8:05		
End Time		9:05		
Bp, "Hg		30.01		
Meter Volume	Meter °F	Condenser °F	Delta H	
216.205				
219.970	43	37	1.800	
223.600	44	40	1.800	
227.430	44	42	1.800	
231.190	44	44	1.800	
235.120	45	44	1.800	
238.680	44	45	1.800	
242.510	44	46	1.800	
246.250	44	46	1.800	
249.878	44	48	1.800	
253.600	44	48	1.800	
257.340	44	46	1.800	
259.990	45	47	1.800	
Impinger gain by weight (g):				
#	Initial	Final	Gain	
1	747.9	754.2	6.3	
2	774.4	775.9	1.5	
3	613.9	614.8	0.9	
Silica Gel	871.6	878.8	7.2	
Impinger Totals:	3,007.8	3,023.7	8.7	

Moisture Field Data Entry				
Run 3				
Leak Checks:		Pre-test	Post-test	
Train leak rate, dcf		0.000	0.000	
Leak check vacuum, "Hg		17	7	
Start Time		9:20		
End Time		10:20		
Bp, "Hg		30.01		
Meter Volume	Meter °F	Condenser °F	Delta H	
261.415				
265.310	43	35	1.800	
269.080	43	36	1.800	
273.000	43	35	1.800	
277.040	43	42	1.800	
280.060	44	42	1.800	
284.310	44	42	1.800	
288.430	43	44	1.800	
292.010	44	43	1.800	
296.430	45	45	1.800	
299.510	45	45	1.800	
303.320	45	45	1.800	
307.105	45	44	1.800	
Impinger gain by weight (g):				
#	Initial	Final	Gain	
1	784.5	792.6	8.1	
2	768.9	769.9	1.0	
3	696.5	696.8	0.3	
Silica Gel	983.8	991.3	7.5	
Impinger Totals:	3,233.7	3,250.6	9.4	

**Bison Engineering, Inc.**  
**Method 4 Moisture Calculations**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 1  
**Location:** Corvallis, OR  
**Source:** CFU 113  
**Test date:** 12/13/2022

Method 4 -Moisture Determination					
Run Number	#	1	2	3	
Start Time	hh:mm	6:55	8:05	9:20	
Meter Box Identification	#	Box 11	Box 11	Box 11	
Meter "Y" Factor	Factor	0.9690	0.9690	0.9690	
Barometric Pressure	in Hg	30.00	30.01	30.01	
Sample Duration	hh:mm	1:00	1:00	1:00	
Average Meter Temperature	Deg F	41.5	44.1	43.9	
Average Condenser Temperature	Deg F	45.1	44.4	41.5	
Average Delta H	in H2O	1.800	1.800	1.800	
Average Meter Pressure	in Hg	30.132	30.142	30.142	
Meter Volume Start	dcf	170.350	216.205	261.415	
Meter Volume End	dcf	215.760	259.990	307.105	
Meter Volume	dcf	45.410	43.785	45.690	
Corrected Meter Volume	dscf	46.657	44.772	46.735	
Impinger Gain	g	6.8	8.7	9.4	
Silica Gel Gain	g	7.7	7.2	7.5	Average
Volume of Condensed Water Vapor	scf	0.684	0.750	0.797	0.744
Moisture Calculation	Bws	0.0144	0.0165	0.0168	0.016
Percent Moisture	Bws%	1.44	1.65	1.68	1.59

**Bison Engineering, Inc.**  
**Method 3A Oxygen**  
**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU 113</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 1</b>	Date: <b>December 13, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values				Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference	
		Analyzer Cal. Response	System Cal Response	Pre test System Cal. Bias		System Cal Response	Post test System Cal. Bias		System Drift					
				% of span	pass/fail		% of span	pass/fail	% of span					pass/fail
Run 1	zero	-0.02	0.08	0.46	pass	0.09	0.50	pass	0.05	pass				
	upscale	10.01	9.98	-0.14	pass	10.08	0.32	pass	0.46	pass	21.94	20.40	20.53	10.05
Run 2	zero	-0.02	0.09	0.50	pass	0.09	0.50	pass	0.00	pass				
	upscale	10.01	10.08	0.32	pass	10.08	0.32	pass	0.00	pass	21.94	20.49	20.52	10.05
Run 3	zero	-0.02	0.09	0.50	pass	0.09	0.50	pass	0.00	pass				
	upscale	10.01	10.08	0.32	pass	10.08	0.32	pass	0.00	pass	21.94	20.51	20.54	10.05
				<b>&lt; 5%*</b>		<b>&lt; 5%*</b>		<b>&lt; 3%*</b>						

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	10.05	21.94
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	-0.02	10.01	22.00
Analyzer Calibration Error	-0.09	-0.18	0.27
Analyzer Calibration Error < 2%*	pass	pass	pass

System Response Time	
31	seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %  
 \*Or < 0.5 % absolute difference

**Bison Engineering, Inc.**  
**Method 3A CO<sub>2</sub>**  
**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU 113</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 1</b>	Date: <b>December 13, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values				Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference Gas	
		Analyzer Cal. Response	System Cal Response	Pre test		System Cal Response	Post test		System Drift					
				System Cal. Bias % of span	pass/fail		System Cal. Bias % of span	pass/fail	% of span					pass/fail
Run 1	zero	-0.01	0.03	0.18	pass	0.02	0.14	pass	0.05	pass				
	upscale	9.82	9.92	0.46	pass	9.83	0.05	pass	0.41	pass	21.70	0.79	0.77	9.951
Run 2	zero	-0.01	0.02	0.14	pass	0.04	0.23	pass	0.09	pass				
	upscale	9.82	9.83	0.05	pass	10.03	0.97	pass	0.92	pass	21.70	0.80	0.77	9.951
Run 3	zero	-0.01	0.04	0.23	pass	0.02	0.14	pass	0.09	pass				
	upscale	9.82	10.03	0.97	pass	10.01	0.88	pass	0.09	pass	21.70	0.85	0.82	9.951
				< 5%*				< 5%*				< 3%*		

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	9.951	21.70
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	-0.01	9.82	21.89
Analyzer Calibration Error	-0.05	-0.60	0.88
Analyzer Calibration Error < 2% *	pass	pass	pass

System Response Time
29 seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %  
 \*Or < 0.5 % absolute difference



**Bison Engineering, Inc.**  
**EPA Method 2-4**  
**Example Calculations**

Client: **Hollingsworth & Vose**  
 Location: **Corvallis, OR**  
 Source: **CFU 113**

Run: **1**  
 Start Time: **6:55**  
 End Time: **7:54**  
 Date: **12/13/2022**

**EPA Methods 2-4:**

- 1)  $P_m \cdot P_b + (\Delta H/13.6) =$  32.206 "Hg  
     where  $P_b$ : 30.00 "Hg  
      $\Delta H$ : 30.000 "H<sub>2</sub>O
  
- 2)  $P_s = P_b + (\text{Static Press.}/13.6) =$  30.051 "Hg  
     where  $P_b$ : 30.00 "Hg  
     Static Press.: 0.70 "H<sub>2</sub>O
  
- 3)  $V_m(\text{std}) = V_m(T_{\text{std}}/P_{\text{std}})(Y)\left(\frac{P_m}{T_m}\right) =$  46.657 dscf  
     where  $V_m$ : 45.410 dcf  
     Y: 0.9690  
      $P_m$ : 30.132 "Hg  
      $P_{\text{std}}$ : 29.92 "Hg  
      $T_{\text{std}}$ : 527.67 °R  
      $T_m$ : 41.5 °F
  
- 4)  $V_w(\text{std}) = V_{lc} \frac{(R)(T_{\text{std}})(\text{H}_2\text{O Conv.})}{(M_w)(P_{\text{std}})} =$  0.684 scf  
     where  $V_{lc}$ : 14.50 g  
     R: 21.85 ("Hg)(ft<sup>3</sup>)/(°R)(lb/-mole)  
      $T_{\text{std}}$ : 527.67 °R  
      $M_w$ : 18.015 lb/lb-mol  
      $P_{\text{std}}$ : 29.92 "Hg  
     water conversion: 0.0022046 lb/gram water
  
- 5)  $B_{ws} = \left(\frac{V_w(\text{std})}{V_w(\text{std})+V_m(\text{std})}\right) =$  0.0144  
     where  $V_w(\text{std})$ : 0.684 scf  
      $V_m(\text{std})$ : 46.657 dscf
  
- 6) % H<sub>2</sub>O =  $B_{ws} \times 100 =$  1.44 %v
  
- 7)  $V_m(\text{actual}) = \left(\frac{Y \times V_m}{(1-B_{ws})}\right) \left(\frac{T_s}{T_m}\right) \left(\frac{P_m}{P_s}\right) =$  55.831 awcf  
     where Y: 0.9690  
      $V_m$ : 45.410 dcf  
      $B_{ws}$ : 0.0144  
      $T_s$ : 584.8 °R  
      $T_m$ : 501.2 °R  
      $P_m$ : 32.206 "Hg  
      $P_s$ : 30.051 "Hg
  
- 8)  $M_d = 0.44(\text{CO}_2) + 0.32(\text{O}_2) + 0.28(\text{N}_2 + \text{CO}) =$  28.94 lb/lb-mole  
     where  $\text{CO}_2$ : 0.77 %vd  
     O<sub>2</sub>: 20.53 %vd  
      $\text{N}_2+\text{CO} = (100-(\text{O}_2+\text{CO}_2))$ : 78.70 %vd

- 9)  $M_s = M_d(1 - B_{ws}) + (18 \times B_{ws}) =$  28.78 lb/lb-mole  
where  $M_d$ : 28.94 lb/lb-mole  
 $B_{ws}$ : 0.0144
- 10) Stack Area(cir.) =  $3.1416 (\text{stack diameter}/24)^2 =$  2.182 sq. ft.  
where Stack ID: 20 inches
- 11) Velocity,  $V_s = 85.49(C_p)(\text{Ave. Sqrt } \Delta P) \left( \sqrt{\frac{T_s}{(P_s \times M_s)}} \right) =$  78.54 fps  
where  $C_p$ : 0.84  
Ave. Sqrt  $\Delta P$ : 1.3300  
 $T_s$ : 584.8 °R  
 $P_s$ : 30.051 "Hg  
 $M_s$ : 28.78 lb/lb-mole
- 12) ACFM =  $(V_s)(\text{stack area})(60 \text{ sec}/\text{min}) =$  10,281 ACFM  
where  $V_s$ : 78.54 ft/sec  
Stack Area: 2.182 sq. ft
- 13) ADCFM =  $(\text{ACFM})(1 - B_{ws}) =$  10,133 ADCFM  
where ACFM: 10,281  
 $B_{ws}$ : 0.0144
- 14)  $Q_{sw} = 3600(V_s)(\text{stack area}) \left( \frac{527.67^\circ R}{T_s} \right) \left( \frac{P_s}{29.92 \text{ "Hg}} \right) =$  559,008 wscf/hr  
where  $V_s$ : 78.54 ft/sec  
Stack Area: 2.1817 sq. ft.  
 $T_s$ : 584.8 °R  
 $P_s$ : 30.051 "Hg
- 15)  $Q_{sd} = (\text{wscf}/\text{hr})(1 - B_{ws}) =$  550,959 dscf/hr  
where wscf/hr: 559,008  
 $B_{ws}$ : 0.0144
- 16) DSCFM =  $(\text{dscf}/\text{hr})/60 \text{ mins}/\text{hr} =$  9,183 DSCFM  
where dscf/hr: 550,959

**Bison Engineering, Inc.**  
**EPA Method 3A (O<sub>2</sub>)**  
**Example Calculations**

Client: **Hollingsworth & Vose**  
 Location: **Corvallis, OR**  
 Source: **CFU 113**

Run: **1**  
 Start Time: **6:55**  
 End Time: **7:54**  
 Date: **12/13/2022**

**EPA Method 3A:**

Analyzer Calibration Error (Mid)

$$1) \text{ ACE} = \left( \frac{C_{\text{Dir}} - C_V}{C_S} \right) \times 100 = -0.18 \% \text{v}$$

where  $C_{\text{Dir}}$ : 10.01 %  
 $C_V$ : 10.05 %  
 $C_S$ : 21.94 %

System Bias (Upscale)

$$2) \text{ SB} = \left( \frac{C_s - C_{\text{Dir}}}{C_S} \right) \times 100 = -0.14 \% \text{v}$$

where  $C_{\text{Dir}}$ : 10.01 %  
 $C_S$ : 9.98 %  
 $C_S$ : 21.94 %

Drift Assessment (Upscale)

$$3) \text{ D} = | \text{SB}_{\text{Final}} - \text{SB}_i | = 0.46 \% \text{v}$$

where  $\text{SB}_{\text{Final}}$ : 0.32 %  
 $\text{SB}_i$ : -0.14 %

Effluent Gas Concentration

$$4) \text{ C}_{\text{Gas}} = (C_{\text{Avg}} - C_O) \left( \frac{C_{\text{MA}}}{C_M - C_O} \right) = 20.53 \% \text{v}$$

where  $C_{\text{Avg}}$ : 20.40 %  
 $C_O$ : 0.09 %  
 $C_{\text{MA}}$ : 10.05 %  
 $C_M$ : 10.03 %

**Bison Engineering, Inc.**  
**EPA Method 3A (CO<sub>2</sub>)**  
**Example Calculations**

Client: **Hollingsworth & Vose**  
 Location: **Corvallis, OR**  
 Source: **CFU 113**

Run: **1**  
 Start Time: **6:55**  
 End Time: **7:54**  
 Date: **12/13/2022**

**EPA Method 3A:**

Analyzer Calibration Error (Mid)

$$1) \text{ ACE} = \left( \frac{C_{\text{Dir}} - C_V}{C_S} \right) \times 100 = -0.60 \% \text{ v}$$

where  $C_{\text{Dir}}$ : 9.82 %  
 $C_V$ : 9.95 %  
 $C_S$ : 21.70 %

System Bias (Upscale)

$$2) \text{ SB} = \left( \frac{C_s - C_{\text{Dir}}}{C_S} \right) \times 100 = 0.46 \% \text{ v}$$

where  $C_{\text{Dir}}$ : 9.82 %  
 $C_s$ : 9.92 %  
 $C_S$ : 21.70 %

Drift Assessment (Upscale)

$$3) \text{ D} = | \text{SB}_{\text{Final}} - \text{SB}_i | = 0.41 \% \text{ v}$$

where  $\text{SB}_{\text{Final}}$ : 0.05 %  
 $\text{SB}_i$ : 0.46 %

Effluent Gas Concentration

$$4) \text{ C}_{\text{Gas}} = (C_{\text{Avg}} - C_O) \left( \frac{C_{\text{MA}}}{C_M - C_O} \right) = 0.77 \% \text{ v}$$

where  $C_{\text{Avg}}$ : 0.79 %  
 $C_O$ : 0.03 %  
 $C_{\text{MA}}$ : 9.95 %  
 $C_M$ : 9.88 %

## **APPENDIX B: CFU 112 TEST DATA**

---

Hollingsworth & Vose  
 Corvallis, OR  
 CFU 112 Speciated Organic Toxic Air Contaminants (TAC)

Run Number	1	2	3
Sample Collection Date	12/13/2022	12/13/2022	12/13/2022
Glass Production Rate Supplied by H&V (lb/hr)	700.8	692.8	700.0
Volumetric Flow Rate Measured by Bison (dscfm)	17,558	16,954	17,698

Analyte	Molecular Weight g/mol	CFU 112-1				CFU 112-2				CFU 112-3				CFU 112 Averages			
		ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass
<b>Dichlorodifluoromethane</b>	120.9129	< 0.5	< 5.0E-04	< 1.65E-04	< 4.72E-04	< 0.5	< 5.0E-04	< 1.60E-04	< 4.61E-04	< 0.5	< 5.0E-04	< 1.67E-04	< 4.76E-04	< 0.50	< 5.0E-04	< 1.64E-04	< 4.70E-04
<i>Chloromethane</i>	50.4872	< 0.5	< 5.0E-04	< 6.91E-05	< 1.97E-04	< 0.5	< 5.0E-04	< 6.67E-05	< 1.92E-04	< 0.5	< 5.0E-04	< 6.96E-05	< 1.99E-04	< 0.50	< 5.0E-04	< 6.84E-05	< 1.96E-04
<b>Freon 114</b>	170.92	< 0.5	< 5.0E-04	< 2.34E-04	< 6.67E-04	< 0.5	< 5.0E-04	< 2.26E-04	< 6.52E-04	< 0.5	< 5.0E-04	< 2.36E-04	< 6.73E-04	< 0.50	< 5.0E-04	< 2.32E-04	< 6.64E-04
<i>Vinyl chloride</i>	62.50	< 0.5	< 5.0E-04	< 8.55E-05	< 2.44E-04	< 0.5	< 5.0E-04	< 8.25E-05	< 2.38E-04	< 0.5	< 5.0E-04	< 8.62E-05	< 2.46E-04	< 0.50	< 5.0E-04	< 8.47E-05	< 2.43E-04
<b>1,3-Butadiene</b>	54.0904	<b>0.58</b>	<b>5.8E-04</b>	<b>8.58E-05</b>	<b>2.45E-04</b>	< 0.5	< 5.0E-04	< 7.14E-05	< 2.06E-04	< 0.5	< 5.0E-04	< 7.46E-05	< 2.13E-04	< <b>0.53</b>	< <b>5.3E-04</b>	< <b>7.73E-05</b>	< <b>2.21E-04</b>
<i>Bromomethane</i>	94.94	< 0.5	< 5.0E-04	< 1.30E-04	< 3.71E-04	< 0.5	< 5.0E-04	< 1.25E-04	< 3.62E-04	< 0.5	< 5.0E-04	< 1.31E-04	< 3.74E-04	< 0.50	< 5.0E-04	< 1.29E-04	< 3.69E-04
<i>Chloroethane</i>	64.51	< 0.5	< 5.0E-04	< 8.82E-05	< 2.52E-04	< 0.5	< 5.0E-04	< 8.52E-05	< 2.46E-04	< 0.5	< 5.0E-04	< 8.89E-05	< 2.54E-04	< 0.50	< 5.0E-04	< 8.75E-05	< 2.51E-04
<b>Freon 11</b>	137.3672	< 0.5	< 5.0E-04	< 1.88E-04	< 5.36E-04	< 0.5	< 5.0E-04	< 1.81E-04	< 5.24E-04	< 0.5	< 5.0E-04	< 1.89E-04	< 5.41E-04	< 0.50	< 5.0E-04	< 1.86E-04	< 5.34E-04
<b>Freon 113</b>	187.38	< 0.5	< 5.0E-04	< 2.56E-04	< 7.31E-04	< 0.5	< 5.0E-04	< 2.47E-04	< 7.14E-04	< 0.5	< 5.0E-04	< 2.58E-04	< 7.38E-04	< 0.50	< 5.0E-04	< 2.54E-04	< 7.28E-04
<b>1,1-Dichloroethene</b>	96.9427	< 0.5	< 5.0E-04	< 1.33E-04	< 3.78E-04	< 0.5	< 5.0E-04	< 1.28E-04	< 3.70E-04	< 0.5	< 5.0E-04	< 1.34E-04	< 3.82E-04	< 0.50	< 5.0E-04	< 1.31E-04	< 3.77E-04
<i>Acetone</i>	58.08	<b>67</b>	<b>6.7E-02</b>	<b>1.06E-02</b>	<b>3.04E-02</b>	<b>46</b>	<b>4.6E-02</b>	<b>7.06E-03</b>	<b>2.04E-02</b>	<b>15</b>	<b>1.5E-02</b>	<b>2.40E-03</b>	<b>6.86E-03</b>	<b>42.67</b>	<b>4.3E-02</b>	<b>6.70E-03</b>	<b>1.92E-02</b>
<i>Carbon disulfide</i>	76.143	< 0.5	< 5.0E-04	< 1.04E-04	< 2.97E-04	< 0.5	< 5.0E-04	< 1.01E-04	< 2.90E-04	< 0.5	< 5.0E-04	< 1.05E-04	< 3.00E-04	< 0.50	< 5.0E-04	< 1.03E-04	< 2.96E-04
<i>Methylene chloride</i>	84.9320	< 0.5	< 5.0E-04	< 1.16E-04	< 3.32E-04	< 0.5	< 5.0E-04	< 1.12E-04	< 3.24E-04	< 0.5	< 5.0E-04	< 1.17E-04	< 3.35E-04	< 0.50	< 5.0E-04	< 1.15E-04	< 3.30E-04
<b>trans-1,2-Dichloroethene</b>	96.9427	< 0.5	< 5.0E-04	< 1.33E-04	< 3.78E-04	< 0.5	< 5.0E-04	< 1.28E-04	< 3.70E-04	< 0.5	< 5.0E-04	< 1.34E-04	< 3.82E-04	< 0.50	< 5.0E-04	< 1.31E-04	< 3.77E-04
<i>Methyl t-butyl ether</i>	88.1482	< 0.5	< 5.0E-04	< 1.21E-04	< 3.44E-04	< 0.5	< 5.0E-04	< 1.16E-04	< 3.36E-04	< 0.5	< 5.0E-04	< 1.22E-04	< 3.47E-04	< 0.50	< 5.0E-04	< 1.20E-04	< 3.42E-04
<i>Vinyl acetate</i>	86.0892	< 0.5	< 5.0E-04	< 1.18E-04	< 3.36E-04	< 0.5	< 5.0E-04	< 1.14E-04	< 3.28E-04	< 0.5	< 5.0E-04	< 1.19E-04	< 3.39E-04	< 0.50	< 5.0E-04	< 1.17E-04	< 3.34E-04
<b>2-Butanone</b>	72.1057	<b>2.3</b>	<b>2.3E-03</b>	<b>4.54E-04</b>	<b>1.29E-03</b>	<b>1.4</b>	<b>1.4E-03</b>	<b>2.67E-04</b>	<b>7.70E-04</b>	< 0.5	< 5.0E-04	< 9.94E-05	< 2.84E-04	< 1.40	< 1.4E-03	< 2.73E-04	< 7.83E-04
<i>cis-1,2-Dichloroethene</i>	96.9427	< 0.5	< 5.0E-04	< 1.33E-04	< 3.78E-04	< 0.5	< 5.0E-04	< 1.28E-04	< 3.70E-04	< 0.5	< 5.0E-04	< 1.34E-04	< 3.82E-04	< 0.50	< 5.0E-04	< 1.31E-04	< 3.77E-04
<i>1,1-Dichloroethane</i>	98.9586	< 0.5	< 5.0E-04	< 1.35E-04	< 3.86E-04	< 0.5	< 5.0E-04	< 1.31E-04	< 3.77E-04	< 0.5	< 5.0E-04	< 1.36E-04	< 3.90E-04	< 0.50	< 5.0E-04	< 1.34E-04	< 3.84E-04
<i>Ethyl acetate</i>	88.1051	< 1.0	< 1.0E-03	< 2.41E-04	< 6.88E-04	< 1.0	< 1.0E-03	< 2.33E-04	< 6.72E-04	< 1.0	< 1.0E-03	< 2.43E-04	< 6.94E-04	< 1.00	< 1.0E-03	< 2.39E-04	< 6.85E-04
<b>Hexane</b>	86.1754	<b>47</b>	<b>4.7E-02</b>	<b>1.11E-02</b>	<b>3.16E-02</b>	<b>22</b>	<b>2.2E-02</b>	<b>5.01E-03</b>	<b>1.45E-02</b>	<b>4.8</b>	<b>4.8E-03</b>	<b>1.14E-03</b>	<b>3.26E-03</b>	<b>24.60</b>	<b>2.5E-02</b>	<b>5.74E-03</b>	<b>1.64E-02</b>
<i>Chloroform</i>	119.3767	< 0.5	< 5.0E-04	< 1.63E-04	< 4.66E-04	< 0.5	< 5.0E-04	< 1.58E-04	< 4.55E-04	< 0.5	< 5.0E-04	< 1.65E-04	< 4.70E-04	< 0.50	< 5.0E-04	< 1.62E-04	< 4.64E-04
<i>Tetrahydrofuran</i>	72.1057	< 0.5	< 5.0E-04	< 9.86E-05	< 2.81E-04	< 0.5	< 5.0E-04	< 9.52E-05	< 2.75E-04	< 0.5	< 5.0E-04	< 9.94E-05	< 2.84E-04	< 0.50	< 5.0E-04	< 9.78E-05	< 2.80E-04
<i>1,2-Dichloroethane</i>	98.9586	< 0.5	< 5.0E-04	< 1.35E-04	< 3.86E-04	< 0.5	< 5.0E-04	< 1.31E-04	< 3.77E-04	< 0.5	< 5.0E-04	< 1.36E-04	< 3.90E-04	< 0.50	< 5.0E-04	< 1.34E-04	< 3.84E-04
<b>1,1,1-Trichloroethane</b>	133.4033	< 0.5	< 5.0E-04	< 1.82E-04	< 5.21E-04	< 0.5	< 5.0E-04	< 1.76E-04	< 5.09E-04	< 0.5	< 5.0E-04	< 1.84E-04	< 5.25E-04	< 0.50	< 5.0E-04	< 1.81E-04	< 5.18E-04
<i>Carbon tetrachloride</i>	153.8215	< 0.5	< 5.0E-04	< 2.10E-04	< 6.00E-04	< 0.5	< 5.0E-04	< 2.03E-04	< 5.86E-04	< 0.5	< 5.0E-04	< 2.12E-04	< 6.06E-04	< 0.50	< 5.0E-04	< 2.09E-04	< 5.98E-04
<b>Benzene</b>	78.1118	<b>12</b>	<b>1.2E-02</b>	<b>2.56E-03</b>	<b>7.32E-03</b>	<b>7.3</b>	<b>7.3E-03</b>	<b>1.51E-03</b>	<b>4.35E-03</b>	<b>1.7</b>	<b>1.7E-03</b>	<b>3.66E-04</b>	<b>1.05E-03</b>	<b>7.00</b>	<b>7.0E-03</b>	<b>1.48E-03</b>	<b>4.24E-03</b>
<i>Cyclohexane</i>	84.1595	< 0.5	< 5.0E-04	< 1.15E-04	< 3.29E-04	< 0.5	< 5.0E-04	< 1.11E-04	< 3.21E-04	< 0.5	< 5.0E-04	< 1.16E-04	< 3.32E-04	< 0.50	< 5.0E-04	< 1.14E-04	< 3.27E-04
<i>Trichloroethene</i>	131.3874	< 0.5	< 5.0E-04	< 1.80E-04	< 5.13E-04	< 0.5	< 5.0E-04	< 1.74E-04	< 5.01E-04	< 0.5	< 5.0E-04	< 1.81E-04	< 5.18E-04	< 0.50	< 5.0E-04	< 1.78E-04	< 5.10E-04
<b>1,2-Dichloropropane</b>	112.9851	< 0.5	< 5.0E-04	< 1.55E-04	< 4.41E-04	< 0.5	< 5.0E-04	< 1.49E-04	< 4.31E-04	< 0.5	< 5.0E-04	< 1.56E-04	< 4.45E-04	< 0.50	< 5.0E-04	< 1.53E-04	< 4.39E-04
<b>Bromodichloromethane</b>	163.828	< 0.5	< 5.0E-04	< 2.24E-04	< 6.39E-04	< 0.5	< 5.0E-04	< 2.16E-04	< 6.25E-04	< 0.5	< 5.0E-04	< 2.26E-04	< 6.45E-04	< 0.50	< 5.0E-04	< 2.22E-04	< 6.36E-04
<b>Heptane</b>	100.2019	<b>3.8</b>	<b>3.8E-03</b>	<b>1.04E-03</b>	<b>2.97E-03</b>	<b>1.8</b>	<b>1.8E-03</b>	<b>4.76E-04</b>	<b>1.38E-03</b>	<b>0.55</b>	<b>5.5E-04</b>	<b>1.52E-04</b>	<b>4.34E-04</b>	<b>2.05</b>	<b>2.1E-03</b>	<b>5.57E-04</b>	<b>1.59E-03</b>
<i>cis-1,3-Dichloropropene</i>	110.9693	< 0.5	< 5.0E-04	< 1.52E-04	< 4.33E-04	< 0.5	< 5.0E-04	< 1.47E-04	< 4.23E-04	< 0.5	< 5.0E-04	< 1.53E-04	< 4.37E-04	< 0.50	< 5.0E-04	< 1.50E-04	< 4.31E-04
<i>4-Methyl-2-pentanone</i>	100.1589	< 0.5	< 5.0E-04	< 1.37E-04	< 3.91E-04	< 0.5	< 5.0E-04	< 1.32E-04	< 3.82E-04	< 0.5	< 5.0E-04	< 1.38E-04	< 3.95E-04	< 0.50	< 5.0E-04	< 1.36E-04	< 3.89E-04
<b>trans-1,3-Dichloropropene</b>	110.9693	< 0.5	< 5.0E-04	< 1.52E-04	< 4.33E-04	< 0.5	< 5.0E-04	< 1.47E-04	< 4.23E-04	< 0.5	< 5.0E-04	< 1.53E-04	< 4.37E-04	< 0.50	< 5.0E-04	< 1.50E-04	< 4.31E-04
<i>1,1,2-Trichloroethane</i>	133.4033	< 0.5	< 5.0E-04	< 1.82E-04	< 5.21E-04	< 0.5	< 5.0E-04	< 1.76E-04	< 5.09E-04	< 0.5	< 5.0E-04	< 1.84E-04	< 5.25E-04	< 0.50	< 5.0E-04	< 1.81E-04	< 5.18E-04
<i>Toluene</i>	92.1384	<b>31</b>	<b>3.1E-02</b>	<b>7.81E-03</b>	<b>2.23E-02</b>	<b>16</b>	<b>1.6E-02</b>	<b>3.89E-03</b>	<b>1.12E-02</b>	<b>5.9</b>	<b>5.9E-03</b>	<b>1.50E-03</b>	<b>4.28E-03</b>	<b>17.63</b>	<b>1.8E-02</b>	<b>4.40E-03</b>	<b>1.26E-02</b>
<i>2-Hexanone</i>	100.1589	< 1.0	< 1.0E-03	< 2.74E-04	< 7.82E-04	< 1.0	< 1.0E-03	< 2.65E-04	< 7.64E-04	< 1.0	< 1.0E-03	< 2.76E-04	< 7.89E-04	< 1.00	< 1.0E-03	< 2.72E-04	< 7.78E-04
<b>Tetrachloroethene</b>	165.833	< 0.5	< 5.0E-04	< 2.27E-04	< 6.47E-04	< 0.5	< 5.0E-04	< 2.19E-04	< 6.32E-04	< 0.5	< 5.0E-04	< 2.29E-04	< 6.53E-04	< 0.50	< 5.0E-04	< 2.25E-04	< 6.44E-04
<b>Dibromochloromethane</b>	208.279	< 0.5	< 5.0E-04	< 2.85E-04	< 8.13E-04	< 0.5	< 5.0E-04	< 2.75E-04	< 7.94E-04	< 0.5	< 5.0E-04	< 2.87E-04	< 8.20E-04	< 0.50	< 5.0E-04	< 2.82E-04	< 8.09E-04
<i>1,2-Dibromoethane</i>	187.861	< 0.5	< 5.0E-04	< 2.57E-04	< 7.33E-04	< 0.5	< 5.0E-04	< 2.48E-04	< 7.16E-04	< 0.5	< 5.0E-04	< 2.59E-04	< 7.40E-04	< 0.50			

Hollingsworth & Vose  
 Corvallis, OR  
 CFU 112 Tentatively Identified Compounds (TIC)

Run Number	1	2	3
Sample Collection Date	12/13/2022	12/13/2022	12/13/2022
Glass Production Rate Supplied by H&V (lb/hr)	700.8	692.8	700.0
Volumetric Flow Rate measured by Bison (dscfm)	17,558	16,954	17,698

Analyte	Molecular Weight g/mol	CFU 112-1				CFU 112-2				CFU 112-3				CFU 112 Averages			
		ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass
Propane	44.097	15	1.5E-02	1.81E-03	5.16E-03	11	1.1E-02	1.28E-03	3.70E-03	7.5	7.5E-03	9.12E-04	2.61E-03	11	1.1E-02	1.33E-03	3.82E-03
Isobutane	58.124	11	1.1E-02	1.75E-03	4.99E-03	6.6	6.6E-03	1.01E-03	2.93E-03	4.2	4.2E-03	6.73E-04	1.92E-03	7	7.3E-03	1.15E-03	3.28E-03
Butane	58.12	9	9.0E-03	1.43E-03	4.08E-03	6.5	6.5E-03	9.98E-04	2.88E-03	3.5	3.5E-03	5.61E-04	1.60E-03	6	6.3E-03	9.97E-04	2.86E-03
Pentane	72.150	20	2.0E-02	3.95E-03	1.13E-02	13	1.3E-02	2.48E-03	7.15E-03	3.6	3.6E-03	7.16E-04	2.05E-03	12	1.2E-02	2.38E-03	6.82E-03
2-Pentene, (E)-	70.130	4.2	4.2E-03	8.06E-04	2.30E-03		0.0E+00	0.00E+00	0.00E+00					4	2.1E-03	4.03E-04	1.15E-03
Pentane, 2-methyl-	86.175	7.9	7.9E-03	1.86E-03	5.31E-03	4.6	4.6E-03	1.05E-03	3.02E-03					6	6.3E-03	1.45E-03	4.17E-03
1-Pentene, 4-methyl-	84.160	7.8	7.8E-03	1.80E-03	5.12E-03	4.2	4.2E-03	9.34E-04	2.70E-03					6	6.0E-03	1.36E-03	3.91E-03
Pentane, 2,3-dimethyl-	100.20	5.6	5.6E-03	1.53E-03	4.38E-03	3.6	3.6E-03	9.53E-04	2.75E-03					5	4.6E-03	1.24E-03	3.57E-03
1-Heptene	98.1861	3.9	3.9E-03	1.05E-03	2.99E-03									4	3.9E-03	1.05E-03	2.99E-03
Pentane, 2,2,4-trimethyl-	114.23	7.2	7.2E-03	2.25E-03	6.42E-03									7	7.2E-03	2.25E-03	6.42E-03
Cyclopropane, 1,2-dimethyl-, trans-	70.1329					2.9	2.9E-03	5.37E-04	1.55E-03					3	2.9E-03	5.37E-04	1.55E-03
1-Butene, 3-methyl-	70.13					2.2	2.2E-03	4.08E-04	1.18E-03					2	2.2E-03	4.08E-04	1.18E-03
Butane, 2,2,3,3-tetramethyl-	114.2285					4.2	4.2E-03	1.27E-03	3.66E-03					4	4.2E-03	1.27E-03	3.66E-03

Note: Concentrations listed for all TICs are estimated values.

**Bison Engineering, Inc.**  
**Gaseous Testing Summary**

Client: **Hollingsworth & Vose**  
 Facility: **Glass Plant 1**  
 Location: **Corvallis, OR**

Source: **CFU112**  
 Test Date: **December 13, 2022**

Environmental Conditions / Test Notes: 40 °F and Foggy

Run		1	2	3	Average
Date		12/13/2022	12/13/2022	12/13/2022	
Run Start Time		10:35	11:45	13:00	
Run End Time		11:34	12:44	13:59	
Duration, min.		60	60	60	
Stack Diameter, in.		30.00	30.00	30.00	
Stack Area, sq.ft.		4.909	4.909	4.909	
Barometric Pressure, "Hg		30.02	30.02	30.02	30.02
Static Pressure, "H <sub>2</sub> O		0.92	0.92	0.92	0.92
Stack Temperature, °F		188	191	191	190
CO <sub>2</sub> , %vd		0.46	0.46	0.46	0.46
O <sub>2</sub> , %vd		20.41	20.39	20.41	20.40
H <sub>2</sub> O, %v		1.38	1.51	1.56	1.48
Wet Molecular Weight, lb/lb-mole		28.74	28.73	28.72	28.73
Velocity, FPS		73.76	71.63	74.83	73.41
WSCFM		17,803	17,214	17,978	17,665
DSCFM		17,558	16,954	17,698	17,403
Production Data, Ultra-Rotary Course	lb/hr	700.8	692.8	700.0	697.9
Production Data, L2R4	lb/hr	354.0	341.3	354.7	350.0
Production Data, L2R9	lb/hr	346.8	351.6	345.2	347.9

Note: Negative concentrations are reported as zero.



**Bison Engineering, Inc.**  
**Pre-Test Traverse**

**Client:** Hollingsworth & Vose  
**Location:** Corvallis, OR  
**Source:** CFU112

**Stack Temp:** NA °F

Traverse Point	Velocity ΔP ("H <sub>2</sub> O)	Null Angle
1	NA	8
2	NA	4
3	NA	13
4	NA	0
5	NA	4
6	NA	5
7	NA	8
8	NA	0
9	NA	1
10	NA	3
11	NA	0
12	NA	0
13	NA	4
14	NA	4
15	NA	3
16	NA	2

Average: NA 4  
 Flow is found to be: Non-cyclonic

No nozzle was needed for flow measurements, therefore no pre-velocity measurements or stack temperature was recorded prior to testing.

**Bison Engineering, Inc.**  
**EPA Method 1**  
**Stack Parameters and Traverse Points**

**Client:** Hollingsworth & Vose  
**Location:** Corvallis, OR  
**Source:** CFU112  
**Facility:** Glass Plant 1

Type of Testing: V V for Velocity/Nonparticulate)  
 Type of Duct: C (C for circular; R for rectangular)

Number of ports available: 2  
 Number of ports to be used: 2  
 Port diameter: 5 inches  
 Sampling location height (approx.): 40.00 feet  
 Stack height (approx.): 7.00 feet

Circular ID (Rectangular Depth): 30.00 inches  
 Port depth and/or wall thickness: 6.00 inches  
 Stack width (Rectangular only): inches

Equivalent Diameter  
 If rectangular =  $\frac{2 * \text{Depth} * \text{Width}}{\text{Depth} + \text{Width}} = 30.00$  inches (If circular = duct ID)

Stack/duct area = 4.909 sq. feet 706.9 sq. inches

Sample Port Location:


	<u>Downstream flow disturbance from process</u>	<u>Upstream flow disturbance toward exit</u>
	B	A
Number of Inches:	145.00	96.00
Number of Diameters:	4.83	3.20

Minimum Number of Traverse Points: 16

Traverse points less than 1.0 inch from the stack wall are relocated to a distance of 1.0 inch.

Points	% of diameter	Distance from inside wall (in.)	Distance including port (in.)
1	3.2	0.96	7
2	10.5	3.15	9 1/8
3	19.4	5.82	11 7/8
4	32.3	9.69	15 3/4
5	67.7	20.31	26 1/4
6	80.6	24.18	30 1/8
7	89.5	26.85	32 7/8
8	96.8	29.04	35

**Reference Diagram**



Drawing NOT to scale and NOT an accurate representation of stack.

**Bison Engineering, Inc.**

**Method 2**

**Stack Gas Velocity and Volumetric Flow Rate**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 1  
**Location:** Corvallis, OR

**Source:** CFU112  
**Test Date:** 12/13/22

Molecular Weight		
Choose One by "x" below		
Measured	Ambient	Combustion
x		

Pitot ID	4E
----------	----

Leak Checks:	Run 1		Run 2		Run 3	
	Pre	Post	Pre	Post	Pre	Post
<b>Pitot</b>	x	x	x	x	x	x
<b>Barometric Pressure ("Hg)</b>	30.02		30.02		30.02	

Traverse	Sample Point	Run 1		Run 2		Run 3	
		Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)
A	1	1.10	185	1.10	189	1.30	185
		1.30	185	1.10	192	1.40	187
		1.50	186	1.20	192	1.50	191
		1.50	189	1.30	193	1.50	192
		1.50	189	1.30	192	1.60	192
		1.50	188	1.30	191	1.50	192
		1.50	189	1.20	190	1.60	192
B	1	1.60	184	1.30	189	1.50	191
		1.20	189	1.40	185	1.30	191
		1.50	189	1.30	189	1.40	192
		1.50	188	1.40	190	1.40	192
		1.40	189	1.50	191	1.50	193
		1.40	190	1.40	192	1.50	192
		1.40	189	1.50	192	1.40	191
		1.40	189	1.50	192	1.50	190
	8	1.30	188	1.40	191	1.20	191

Method 2 -Flow Calculations							
Static Pressure, "H <sub>2</sub> O			0.92		0.92		0.92
Pitot tube cp			0.84		0.84		0.84
Stack Area, ft <sup>3</sup>			4.909		4.909		4.909
H <sub>2</sub> O, %v			1.38		1.51		1.56
Average √ΔP			1.187		1.150		1.201
Average Absolute Temp. ( °R )			647.5		650.3		650.5
Stack Pressure (in. Hg)			30.09		30.09		30.09
Stack Velocity (ft/sec)			73.76		71.63		74.83
Actual Flow Rate (acfm)			21,724		21,096		22,039
Standard Flow Rate (wscf/hr)			1,068,198		1,032,851		1,078,686
Dry Standard Flow Rate (dscf/hr)			1,053,457		1,017,255		1,061,858
Dry Standard Flow Rate (dscfm)			17,558		16,954		17,698

	O <sub>2</sub>	CO <sub>2</sub>	Calculated N <sub>2</sub>
Run 1	20.41	0.46	79.14
Run 2	20.39	0.46	79.15
Run 3	20.41	0.46	79.13

	Molecular Weight (lb/lb-mole)					
	Calculated		Ambient		Combustion	
Run 1	M <sub>d</sub>	28.89	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.74	M <sub>s</sub>		M <sub>s</sub>	
Run 2	M <sub>d</sub>	28.89	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.73	M <sub>s</sub>		M <sub>s</sub>	
Run 3	M <sub>d</sub>	28.89	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.72	M <sub>s</sub>		M <sub>s</sub>	

**Bison Engineering, Inc.**  
**Moisture Field Data**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 1  
**Location:** Corvallis, OR  
**Source:** CFU112  
**Test date:** 12/13/2022

**Meterbox ID:** Box 11  
**Meter "Y"-Factor** 0.9690

Moisture Field Data Entry			
Run 1			
Leak Checks:		Pre-test	Post-test
Train leak rate, dcf		0.000	0.000
Leak check vacuum, "Hg		16	5
Start Time		10:35	
End Time		11:35	
Bp, "Hg		30.02	

Minutes	Meter Volume	Meter °F	Condenser °F	Delta H
	307.720			
5	311.545	45	42	1.800
10	315.360	46	45	1.800
15	319.180	46	50	1.800
20	323.000	46	51	1.800
25	326.83	47	52	1.800
30	330.630	47	55	1.800
35	334.460	48	56	1.800
40	338.270	49	58	1.800
45	342.110	49	59	1.800
50	345.910	50	60	1.800
55	349.730	50	60	1.800
60	353.465	50	61	1.800

Impinger gain by weight (g):			
#	Initial	Final	Gain
1	754.2	756.6	2.4
2	775.9	777.3	1.4
3	614.8	615.0	0.2
Silica Gel	878.8	888.6	9.8
Impinger Totals:	2,144.9	3,037.5	4.0

Moisture Field Data Entry			
Run 2			
Leak Checks:		Pre-test	Post-test
Train leak rate, dcf		0.000	0.000
Leak check vacuum, "Hg		15	6
Start Time		11:45	
End Time		12:45	
Bp, "Hg		30.02	

Meter Volume	Meter °F	Condenser °F	Delta H
354.355			
358.020	49	49	1.800
361.900	49	51	1.800
365.720	50	53	1.800
369.410	50	56	1.800
373.210	51	54	1.800
376.930	51	52	1.800
380.740	52	51	1.800
384.560	50	51	1.800
388.380	52	52	1.800
392.200	51	50	1.800
396.210	51	51	1.800
399.835	50	51	1.800

Impinger gain by weight (g):			
#	Initial	Final	Gain
1	792.6	796.6	4.0
2	769.9	771.7	1.8
3	696.8	697.9	1.1
Silica Gel	991.3	999.3	8.0
Impinger Totals:	3,250.6	3,265.5	6.9

Moisture Field Data Entry			
Run 3			
Leak Checks:		Pre-test	Post-test
Train leak rate, dcf		0.000	0.000
Leak check vacuum, "Hg		18	7
Start Time		13:00	
End Time		14:00	
Bp, "Hg		30.02	

Meter Volume	Meter °F	Condenser °F	Delta H
401.005			
404.980	48	44	1.800
408.650	48	46	1.800
412.460	49	47	1.800
416.270	49	50	1.800
420.070	50	50	1.800
423.890	51	52	1.800
427.690	51	52	1.800
431.510	52	51	1.800
435.350	52	52	1.800
439.180	53	54	1.800
443.210	53	53	1.800
446.830	54	60	1.800

Impinger gain by weight (g):			
#	Initial	Final	Gain
1	756.6	760.0	3.4
2	777.3	779.7	2.4
3	615.0	616.1	1.1
Silica Gel	888.6	897.2	8.6
Impinger Totals:	3,037.5	3,053.0	6.9

**Bison Engineering, Inc.**  
**Method 4 Moisture Calculations**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 1  
**Location:** Corvallis, OR  
**Source:** CFU112  
**Test date:** 12/13/2022

Method 4 -Moisture Determination					
Run Number	#	1	2	3	
Start Time	hh:mm	10:35	11:45	13:00	
Meter Box Identification	#	Box 11	Box 11	Box 11	
Meter "Y" Factor	Factor	0.9690	0.9690	0.9690	
Barometric Pressure	in Hg	30.02	30.02	30.02	
Sample Duration	hh:mm	1:00	1:00	1:00	
Average Meter Temperature	Deg F	47.8	50.5	50.8	
Average Condenser Temperature	Deg F	54.1	51.8	50.9	
Average Delta H	in H2O	1.800	1.800	1.800	
Average Meter Pressure	in Hg	30.152	30.152	30.152	
Meter Volume Start	dcf	307.720	354.355	401.005	
Meter Volume End	dcf	353.465	399.835	446.830	
Meter Volume	dcf	45.745	45.480	45.825	
Corrected Meter Volume	dscf	46.453	45.935	46.254	
Impinger Gain	g	4.0	6.9	6.9	
Silica Gel Gain	g	9.8	8.0	8.6	Average
Volume of Condensed Water Vapor	scf	0.651	0.703	0.731	0.695
Moisture Calculation	Bws	0.0138	0.0151	0.0156	0.015
Percent Moisture	Bws%	1.38	1.51	1.56	1.48

**Bison Engineering, Inc.**  
**Method 3A Oxygen**  
**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU112</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 1</b>	Date: <b>December 13, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values				Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference	
		Analyzer Cal. Response	System Cal Response	Pre test		System Cal Response	Post test		System Drift					
				System Cal. Bias % of span	pass/fail		System Cal. Bias % of span	pass/fail	System Drift % of span					pass/fail
Run 1	zero	-0.02	0.09	0.50	pass	0.10	0.55	pass	0.05	pass				
	upscale	10.01	10.08	0.32	pass	10.07	0.27	pass	0.05	pass	21.94	20.36	20.41	10.05
Run 2	zero	-0.02	0.10	0.55	pass	0.08	0.46	pass	0.09	pass				
	upscale	10.01	10.07	0.27	pass	10.07	0.27	pass	0.00	pass	21.94	20.34	20.39	10.05
Run 3	zero	-0.02	0.08	0.46	pass	0.09	0.50	pass	0.05	pass				
	upscale	10.01	10.07	0.27	pass	10.05	0.18	pass	0.09	pass	21.94	20.34	20.41	10.05
				<b>&lt; 5%*</b>		<b>&lt; 5%*</b>		<b>&lt; 3%*</b>						

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	10.05	21.94
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	-0.02	10.01	22.00
Analyzer Calibration Error	-0.09	-0.18	0.27
Analyzer Calibration Error < 2%*	pass	pass	pass

System Response Time	
10.08	seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %  
 \*Or < 0.5 % absolute difference

**Bison Engineering, Inc.**  
**Method 3A CO<sub>2</sub>**  
**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU112</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 1</b>	Date: <b>December 13, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values				Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference Gas
		Analyzer Cal. Response	System Cal Response	Pre test System Cal. Bias		System Cal Response	Post test System Cal. Bias		System Drift				
				% of span	pass/fail		% of span	pass/fail	% of span	pass/fail			
Run 1	zero	-0.01	0.02	0.14	pass	0.02	0.14	pass	0.00	pass			
	upscale	9.82	10.01	0.88	pass	10.06	1.11	pass	0.23	pass	21.70	0.48	0.46
Run 2	zero	-0.01	0.02	0.14	pass	0.02	0.14	pass	0.00	pass			
	upscale	9.82	10.06	1.11	pass	10.03	0.97	pass	0.14	pass	21.70	0.48	0.46
Run 3	zero	-0.01	0.02	0.14	pass	0.03	0.18	pass	0.05	pass			
	upscale	9.82	10.03	0.97	pass	10.00	0.83	pass	0.14	pass	21.70	0.49	0.46
				<b>&lt; 5%*</b>		<b>&lt; 5%*</b>		<b>&lt; 3%*</b>					

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	9.951	21.70
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	-0.01	9.82	21.89
Analyzer Calibration Error	-0.05	-0.60	0.88
Analyzer Calibration Error < 2% *	pass	pass	pass

System Response Time
10.01 seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %  
 \*Or < 0.5 % absolute difference

## **APPENDIX C: CFU 108 TEST DATA**

---



**Hollingsworth & Vose**  
**Corvallis, OR**  
**CFU 108 Speciated Organic Toxic Air Contaminants (TAC)**

Run Number	1	2	3
Sample Collection Date	12/13/2022	12/13/2022	12/13/2022
Glass Production Rate Supplied by H&V (lb/hr)	385.7	390.4	380.1
Volumetric Flow Rate Measured by Bison (dscfm)	17,607	18,441	18,097

Analyte	Molecular Weight g/mol	CFU 108-1						CFU 108-2						CFU 108-3						CFU 108 Averages					
		ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass				
Dichlorodifluoromethane	120.9129	< 0.5	< 5.0E-04	< 1.66E-04	< 8.60E-04	< 0.5	< 5.0E-04	< 1.74E-04	< 8.90E-04	< 0.5	< 5.0E-04	< 1.70E-04	< 8.97E-04	< 0.50	< 5.0E-04	< 1.70E-04	< 8.82E-04	< 0.5	< 5.0E-04	< 1.70E-04	< 8.82E-04				
Chloromethane	50.4872	< 0.5	< 5.0E-04	< 6.92E-05	< 3.59E-04	< 0.5	< 5.0E-04	< 7.25E-05	< 3.72E-04	< 0.5	< 5.0E-04	< 7.12E-05	< 3.75E-04	< 0.50	< 5.0E-04	< 7.10E-05	< 3.68E-04	< 0.5	< 5.0E-04	< 7.10E-05	< 3.68E-04				
Freon 114	170.92	< 0.5	< 5.0E-04	< 2.34E-04	< 1.22E-03	< 0.5	< 5.0E-04	< 2.46E-04	< 1.26E-03	< 0.5	< 5.0E-04	< 2.41E-04	< 1.27E-03	< 0.50	< 5.0E-04	< 2.40E-04	< 1.25E-03	< 0.5	< 5.0E-04	< 2.40E-04	< 1.25E-03				
Vinyl chloride	62.50	< 0.5	< 5.0E-04	< 8.57E-05	< 4.45E-04	< 0.5	< 5.0E-04	< 8.98E-05	< 4.60E-04	< 0.5	< 5.0E-04	< 8.81E-05	< 4.64E-04	< 0.50	< 5.0E-04	< 8.79E-05	< 4.56E-04	< 0.5	< 5.0E-04	< 8.79E-05	< 4.56E-04				
1,3-Butadiene	54.0904	< 0.5	< 5.0E-04	< 7.42E-05	< 3.85E-04	< 0.5	< 5.0E-04	< 7.77E-05	< 3.98E-04	< 0.5	< 5.0E-04	< 7.63E-05	< 4.01E-04	< 0.50	< 5.0E-04	< 7.60E-05	< 3.95E-04	< 0.5	< 5.0E-04	< 7.60E-05	< 3.95E-04				
Bromomethane	94.94	< 0.5	< 5.0E-04	< 1.30E-04	< 6.75E-04	< 0.5	< 5.0E-04	< 1.36E-04	< 6.99E-04	< 0.5	< 5.0E-04	< 1.34E-04	< 7.04E-04	< 0.50	< 5.0E-04	< 1.33E-04	< 6.93E-04	< 0.5	< 5.0E-04	< 1.33E-04	< 6.93E-04				
Chloroethane	64.51	< 0.5	< 5.0E-04	< 8.85E-05	< 4.59E-04	< 0.5	< 5.0E-04	< 9.27E-05	< 4.75E-04	< 0.5	< 5.0E-04	< 9.09E-05	< 4.79E-04	< 0.50	< 5.0E-04	< 9.07E-05	< 4.71E-04	< 0.5	< 5.0E-04	< 9.07E-05	< 4.71E-04				
Freon 11	137.3672	< 0.5	< 5.0E-04	< 1.88E-04	< 9.77E-04	< 0.5	< 5.0E-04	< 1.97E-04	< 1.01E-03	< 0.5	< 5.0E-04	< 1.94E-04	< 1.02E-03	< 0.50	< 5.0E-04	< 1.93E-04	< 1.00E-03	< 0.5	< 5.0E-04	< 1.93E-04	< 1.00E-03				
Freon 113	187.38	< 0.5	< 5.0E-04	< 2.57E-04	< 1.33E-03	< 0.5	< 5.0E-04	< 2.69E-04	< 1.38E-03	< 0.5	< 5.0E-04	< 2.64E-04	< 1.39E-03	< 0.50	< 5.0E-04	< 2.63E-04	< 1.37E-03	< 0.5	< 5.0E-04	< 2.63E-04	< 1.37E-03				
1,1-Dichloroethane	96.9427	< 0.5	< 5.0E-04	< 1.33E-04	< 6.89E-04	< 0.5	< 5.0E-04	< 1.39E-04	< 6.34E-04	< 0.5	< 5.0E-04	< 1.37E-04	< 7.19E-04	< 0.50	< 5.0E-04	< 1.36E-04	< 7.07E-04	< 0.5	< 5.0E-04	< 1.36E-04	< 7.07E-04				
Acetone	58.08	<b>24</b>	<b>2.4E-02</b>	<b>3.82E-03</b>	<b>1.98E-02</b>	<b>11</b>	<b>1.1E-02</b>	<b>1.84E-03</b>	<b>9.40E-03</b>	<b>9.3</b>	<b>9.3E-03</b>	<b>1.52E-03</b>	<b>8.01E-03</b>	<b>14.77</b>	<b>1.5E-02</b>	<b>2.39E-03</b>	<b>1.24E-02</b>	< 0.5	< 5.0E-04	< 1.37E-04	< 7.19E-04				
Carbon disulfide	76.143	< 0.5	< 5.0E-04	< 1.04E-04	< 5.42E-04	< 0.5	< 5.0E-04	< 1.09E-04	< 5.60E-04	< 0.5	< 5.0E-04	< 1.07E-04	< 5.65E-04	< 0.50	< 5.0E-04	< 1.07E-04	< 5.56E-04	< 0.5	< 5.0E-04	< 1.07E-04	< 5.56E-04				
Methylene chloride	84.9320	< 0.5	< 5.0E-04	< 1.16E-04	< 6.04E-04	< 0.5	< 5.0E-04	< 1.22E-04	< 6.25E-04	< 0.5	< 5.0E-04	< 1.20E-04	< 6.30E-04	< 0.50	< 5.0E-04	< 1.19E-04	< 6.20E-04	< 0.5	< 5.0E-04	< 1.19E-04	< 6.20E-04				
trans-1,2-Dichloroethane	96.9427	< 0.5	< 5.0E-04	< 1.33E-04	< 6.89E-04	< 0.5	< 5.0E-04	< 1.39E-04	< 7.13E-04	< 0.5	< 5.0E-04	< 1.37E-04	< 7.19E-04	< 0.50	< 5.0E-04	< 1.36E-04	< 7.07E-04	< 0.5	< 5.0E-04	< 1.36E-04	< 7.07E-04				
Methyl t-butyl ether	88.1482	< 0.5	< 5.0E-04	< 1.21E-04	< 6.27E-04	< 0.5	< 5.0E-04	< 1.27E-04	< 6.49E-04	< 0.5	< 5.0E-04	< 1.24E-04	< 6.54E-04	< 0.50	< 5.0E-04	< 1.24E-04	< 6.43E-04	< 0.5	< 5.0E-04	< 1.24E-04	< 6.43E-04				
Vinyl acetate	86.0892	< 0.5	< 5.0E-04	< 1.18E-04	< 6.12E-04	< 0.5	< 5.0E-04	< 1.24E-04	< 6.34E-04	< 0.5	< 5.0E-04	< 1.21E-04	< 6.39E-04	< 0.50	< 5.0E-04	< 1.21E-04	< 6.28E-04	< 0.5	< 5.0E-04	< 1.21E-04	< 6.28E-04				
2-Butanone	72.1057	<b>0.63</b>	<b>6.3E-04</b>	<b>1.25E-04</b>	<b>6.46E-04</b>	< 0.5	< 5.0E-04	< 1.04E-04	< 5.31E-04	< 0.5	< 5.0E-04	< 1.02E-04	< 5.35E-04	< 0.50	< 5.0E-04	< 1.01E-04	< 5.07E-04	< 0.5	< 5.0E-04	< 1.01E-04	< 5.07E-04				
cis-1,2-Dichloroethane	96.9427	< 0.5	< 5.0E-04	< 1.33E-04	< 6.89E-04	< 0.5	< 5.0E-04	< 1.39E-04	< 7.13E-04	< 0.5	< 5.0E-04	< 1.37E-04	< 7.19E-04	< 0.50	< 5.0E-04	< 1.36E-04	< 7.07E-04	< 0.5	< 5.0E-04	< 1.36E-04	< 7.07E-04				
1,1-Dichloroethane	98.9586	< 0.5	< 5.0E-04	< 1.36E-04	< 7.04E-04	< 0.5	< 5.0E-04	< 1.42E-04	< 7.28E-04	< 0.5	< 5.0E-04	< 1.40E-04	< 7.34E-04	< 0.50	< 5.0E-04	< 1.39E-04	< 7.22E-04	< 0.5	< 5.0E-04	< 1.39E-04	< 7.22E-04				
Ethyl acetate	88.1051	< 1.0	< 1.0E-03	< 2.42E-04	< 1.25E-03	< 1.0	< 1.0E-03	< 2.53E-04	< 1.30E-03	< 1.0	< 1.0E-03	< 2.48E-04	< 1.31E-03	< 1.00	< 1.0E-03	< 2.48E-04	< 1.29E-03	< 0.5	< 5.0E-04	< 2.48E-04	< 1.29E-03				
Hexane	86.1754	<b>2.8</b>	<b>2.8E-03</b>	<b>6.62E-04</b>	<b>3.43E-03</b>	<b>1.3</b>	<b>1.3E-03</b>	<b>3.22E-04</b>	<b>1.65E-03</b>	<b>0.71</b>	<b>7.1E-04</b>	<b>1.73E-04</b>	<b>9.08E-04</b>	<b>1.60</b>	<b>1.6E-03</b>	<b>3.85E-04</b>	<b>2.90E-03</b>	< 0.5	< 5.0E-04	< 1.68E-04	< 8.71E-04				
Chloroform	119.3767	< 0.5	< 5.0E-04	< 1.64E-04	< 8.49E-04	< 0.5	< 5.0E-04	< 1.71E-04	< 8.79E-04	< 0.5	< 5.0E-04	< 1.68E-04	< 8.86E-04	< 0.50	< 5.0E-04	< 1.68E-04	< 8.71E-04	< 0.5	< 5.0E-04	< 1.68E-04	< 8.71E-04				
Tetrahydrofuran	72.1057	< 0.5	< 5.0E-04	< 9.89E-05	< 5.13E-04	< 0.5	< 5.0E-04	< 1.04E-04	< 5.31E-04	< 0.5	< 5.0E-04	< 1.02E-04	< 5.35E-04	< 0.50	< 5.0E-04	< 1.01E-04	< 5.26E-04	< 0.5	< 5.0E-04	< 1.01E-04	< 5.26E-04				
1,2-Dichloroethane	98.9586	< 0.5	< 5.0E-04	< 1.36E-04	< 7.04E-04	< 0.5	< 5.0E-04	< 1.42E-04	< 7.28E-04	< 0.5	< 5.0E-04	< 1.40E-04	< 7.34E-04	< 0.50	< 5.0E-04	< 1.39E-04	< 7.22E-04	< 0.5	< 5.0E-04	< 1.39E-04	< 7.22E-04				
1,1,1-Trichloroethane	133.4033	< 0.5	< 5.0E-04	< 1.83E-04	< 9.49E-04	< 0.5	< 5.0E-04	< 1.92E-04	< 9.82E-04	< 0.5	< 5.0E-04	< 1.88E-04	< 9.90E-04	< 0.50	< 5.0E-04	< 1.88E-04	< 9.73E-04	< 0.5	< 5.0E-04	< 1.88E-04	< 9.73E-04				
Carbon tetrachloride	153.8215	< 0.5	< 5.0E-04	< 2.11E-04	< 1.09E-03	< 0.5	< 5.0E-04	< 2.21E-04	< 1.13E-03	< 0.5	< 5.0E-04	< 2.17E-04	< 1.14E-03	< 0.50	< 5.0E-04	< 2.16E-04	< 1.12E-03	< 0.5	< 5.0E-04	< 2.16E-04	< 1.12E-03				
Benzene	78.1118	<b>1.7</b>	<b>1.7E-03</b>	<b>3.64E-04</b>	<b>1.89E-03</b>	<b>0.65</b>	<b>6.5E-04</b>	<b>1.46E-04</b>	<b>7.47E-04</b>	<b>0.56</b>	<b>5.6E-04</b>	<b>1.23E-04</b>	<b>6.49E-04</b>	<b>0.97</b>	<b>9.7E-04</b>	<b>2.11E-04</b>	<b>1.10E-03</b>	< 0.5	< 5.0E-04	< 1.10E-03	< 1.10E-03				
Cyclohexane	84.1595	< 0.5	< 5.0E-04	< 1.15E-04	< 5.99E-04	< 0.5	< 5.0E-04	< 1.21E-04	< 6.19E-04	< 0.5	< 5.0E-04	< 1.19E-04	< 6.24E-04	< 0.50	< 5.0E-04	< 1.18E-04	< 6.14E-04	< 0.5	< 5.0E-04	< 1.18E-04	< 6.14E-04				
Trichloroethane	131.3874	< 0.5	< 5.0E-04	< 1.80E-04	< 9.34E-04	< 0.5	< 5.0E-04	< 1.89E-04	< 9.67E-04	< 0.5	< 5.0E-04	< 1.85E-04	< 9.75E-04	< 0.50	< 5.0E-04	< 1.85E-04	< 9.59E-04	< 0.5	< 5.0E-04	< 1.85E-04	< 9.59E-04				
1,2-Dichloropropane	112.9851	< 0.5	< 5.0E-04	< 1.55E-04	< 8.04E-04	< 0.5	< 5.0E-04	< 1.62E-04	< 8.32E-04	< 0.5	< 5.0E-04	< 1.59E-04	< 8.38E-04	< 0.50	< 5.0E-04	< 1.59E-04	< 8.24E-04	< 0.5	< 5.0E-04	< 1.59E-04	< 8.24E-04				
Bromodichloromethane	163.828	< 0.5	< 5.0E-04	< 2.25E-04	< 1.17E-03	< 0.5	< 5.0E-04	< 2.35E-04	< 1.21E-03	< 0.5	< 5.0E-04	< 2.31E-04	< 1.22E-03	< 0.50	< 5.0E-04	< 2.30E-04	< 1.20E-03	< 0.5	< 5.0E-04	< 2.30E-04	< 1.20E-03				
Heptane	100.2019	< 0.5	< 5.0E-04	< 1.37E-04	< 7.13E-04	< 0.5	< 5.0E-04	< 1.44E-04	< 7.37E-04	< 0.5	< 5.0E-04	< 1.41E-04	< 7.43E-04	< 0.50	< 5.0E-04	< 1.41E-04	< 7.31E-04	< 0.5	< 5.0E-04	< 1.41E-04	< 7.31E-04				
cis-1,3-Dichloropropene	110.9693	< 0.5	< 5.0E-04	< 1.52E-04	< 7.89E-04	< 0.5	< 5.0E-04	< 1.59E-04	< 8.17E-04	< 0.5	< 5.0E-04	< 1.56E-04	< 8.23E-04	< 0.50	< 5.0E-04	< 1.56E-04	< 8.10E-04	< 0.5	< 5.0E-04	< 1.56E-04	< 8.10E-04				
4-Methyl-2-pentanone	100.1589	< 0.5	< 5.0E-04	< 1.37E-04	< 7.12E-04	< 0.5	< 5.0E-04	< 1.44E-04	< 7.37E-04	< 0.5	< 5.0E-04	< 1.41E-04	< 7.43E-04	< 0.50	< 5.0E-04	< 1.41E-04	< 7.31E-04	< 0.5	< 5.0E-04	< 1.41E-04	<				

**Hollingsworth & Vose**  
**Corvallis, OR**  
**CFU 108 Tentatively Identified Compounds (TIC)**

Run Number	1	2	3
Sample Collection Date	12/13/2022	12/13/2022	12/13/2022
Glass Production Rate Supplied by H&V (lb/hr)	385.7	390.4	380.1
Volumetric Flow Rate measured by Bison (dscfm)	17,607	18,441	18,097

Analyte	Molecular Weight g/mol	CFU 108-1				CFU 108-2				CFU 108-3				CFU 108 Averages			
		ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass
Propane	44.097	9.1	9.1E-03	1.10E-03	5.71E-03	7.6	7.6E-03	9.63E-04	4.93E-03	7.7	7.7E-03	9.57E-04	5.04E-03	8.13	8.1E-03	1.01E-03	5.23E-03
Isobutane	58.124	5.5	5.5E-03	8.77E-04	4.55E-03	4	4.0E-03	6.68E-04	3.42E-03	4.1	4.1E-03	6.72E-04	3.54E-03	4.53	4.5E-03	7.39E-04	3.83E-03
Butane	58.12	2.7	2.7E-03	4.30E-04	2.23E-03	2.4	2.4E-03	4.01E-04	2.05E-03	2.2	2.2E-03	3.61E-04	1.90E-03	2.43	2.4E-03	3.97E-04	2.06E-03
Pentane	72.150	3.2	3.2E-03	6.33E-04	3.28E-03	2	2.0E-03	4.15E-04	2.12E-03					2.60	2.6E-03	5.24E-04	2.70E-03
Hexane, 2,2-dimethyl	114.230	2.9	2.9E-03	9.09E-04	4.71E-03									2.90	2.9E-03	9.09E-04	4.71E-03
Cyclohexanone	98.150					2	2.0E-03	5.64E-04	2.89E-03					2.00	2.0E-03	5.64E-04	2.89E-03

Note: Concentrations listed for all TICs are estimated values. Therefore, all calculated concentrations and mass rates are also considered estimates.  
 ALS Lab data identified an unknown compound in the amount of 2.5ppb in the sample for CFU 108, run 1.

**Bison Engineering, Inc.**  
**Gaseous Testing Summary**

Client: **Hollingsworth & Vose**  
 Facility: **Glass Plant 1**  
 Location: **Corvallis, OR**

Source: **CFU 108**  
 Test Date: **December 13, 2022**

Environmental Conditions / Test Notes: 40 °F and Partly sunny

Run		1	2	3	Average
Date		12/13/2022	12/13/2022	12/13/2022	
Run Start Time		14:30	15:40	16:50	
Run End Time		15:29	16:39	17:49	
Duration, min.		60	60	60	
Stack Diameter, in.		30.00	30.00	30.00	
Stack Area, sq.ft.		4.909	4.909	4.909	
Barometric Pressure, "Hg		30.00	30.00	30.00	30.00
Static Pressure, "H <sub>2</sub> O		0.55	0.55	0.55	0.55
Stack Temperature, °F		194	208	209	204
CO <sub>2</sub> , %vd		0.58	0.57	0.58	0.58
O <sub>2</sub> , %vd		20.12	20.13	20.12	20.12
H <sub>2</sub> O, %v		3.14	1.30	1.50	1.98
Wet Molecular Weight, lb/lb-mole		28.56	28.76	28.74	28.69
Velocity, FPS		76.17	79.89	78.76	78.27
WSCFM		18,178	18,684	18,372	18,411
DSCFM		17,607	18,441	18,097	18,048
Production Data, Total Rotary Course	lb/hr	385.7	390.4	380.1	385.4
Production Data, L1R5	lb/hr	189.7	196.0	192.1	192.6
Production Data, L1R6	lb/hr	196.0	194.4	188.1	192.8

Note: Negative concentrations are reported as zero.

**Bison Engineering, Inc.**  
**Pre-Test Traverse**

**Client:** Hollingsworth & Vose  
**Location:** Corvallis, OR  
**Source:** CFU 108

**Stack Temp:** NA °F

Traverse Point	Velocity ΔP ("H <sub>2</sub> O)	Null Angle
1	NA	6
2	NA	7
3	NA	5
4	NA	1
5	NA	1
6	NA	2
7	NA	3
8	NA	0
9	NA	1
10	NA	5
11	NA	6
12	NA	10
13	NA	8
14	NA	2
15	NA	1
16	NA	0

Average: NA 4  
Flow is found to be: Non-cyclonic

No nozzle was needed for flow measurements, therefore no pre-velocity measurements or stack temperature was recorded prior to testing.

**Bison Engineering, Inc.**  
**EPA Method 1**  
**Stack Parameters and Traverse Points**

**Client:** Hollingsworth & Vose  
**Location:** Corvallis, OR  
**Source:** CFU 108  
**Facility:** Glass Plant 1

Type of Testing: V V for Velocity/Nonparticulate)  
 Type of Duct: C (C for circular; R for rectangular)

Number of ports available: 2  
 Number of ports to be used: 2  
 Port diameter: 5 inches  
 Sampling location height (approx.): 40.00 feet  
 Stack height (approx.): 7.00 feet

Circular ID (Rectangular Depth): 30.00 inches  
 Port depth and/or wall thickness: 6.00 inches  
 Stack width (Rectangular only): inches

Equivalent Diameter  
 If rectangular =  $\frac{2 * \text{Depth} * \text{Width}}{\text{Depth} + \text{Width}} =$  30.00 inches (If circular = duct ID)

Stack/duct area = 4.909 sq. feet 706.9 sq. inches

Sample Port Location:


	Downstream flow disturbance from process	Upstream flow disturbance toward exit
	B	A
Number of Inches:	128.00	102.00
Number of Diameters:	4.27	3.40

Minimum Number of Traverse Points: 16

Traverse points less than 1.0 inch from the stack wall are relocated to a distance of 1.0 inch.

Points	% of diameter	Distance from inside wall (in.)	Distance including port (in.)
1	3.2	0.96	7
2	10.5	3.15	9 1/8
3	19.4	5.82	11 7/8
4	32.3	9.69	15 3/4
5	67.7	20.31	26 1/4
6	80.6	24.18	30 1/8
7	89.5	26.85	32 7/8
8	96.8	29.04	35

**Reference Diagram**



Drawing NOT to scale and NOT an accurate representation of stack.

**Bison Engineering, Inc.**

**Method 2**

**Stack Gas Velocity and Volumetric Flow Rate**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 1  
**Location:** Corvallis, OR

**Source:** CFU 108  
**Test Date:** 12/13/22

Molecular Weight		
Choose One by "x" below		
Measured	Ambient	Combustion
x		

Pitot ID	4E
----------	----

Leak Checks:	Run 1		Run 2		Run 3	
	Pre	Post	Pre	Post	Pre	Post
<b>Pitot</b>	x	x	x	x	x	x
<b>Barometric Pressure ("Hg)</b>	30.00		30.00		30.00	

Traverse	Sample Point	Run 1		Run 2		Run 3	
		Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)
A	1	1.20	191	1.50	205	1.60	205
	2	1.50	191	1.50	206	1.70	207
	3	1.60	192	1.80	207	1.60	208
	4	1.60	193	1.70	208	1.70	209
	5	1.60	195	1.70	208	1.70	210
	6	1.50	195	1.40	208	1.60	210
	7	1.50	194	1.60	209	1.40	210
	8	1.40	195	1.20	208	1.50	210
B	1	1.30	196	1.50	206	1.60	209
	2	1.60	195	1.60	207	1.60	210
	3	1.60	195	1.60	208	1.60	210
	4	1.60	194	1.70	208	1.60	210
	5	1.60	195	1.80	208	1.60	210
	6	1.50	195	1.80	209	1.50	209
	7	1.50	195	1.70	208	1.40	210
	8	1.10	195	1.60	207	1.20	210

Method 2 -Flow Calculations							
Static Pressure, "H <sub>2</sub> O		0.55		0.55		0.55	
Pitot tube cp		0.84		0.84		0.84	
Stack Area, ft <sup>3</sup>		4.909		4.909		4.909	
H <sub>2</sub> O, %v		3.14		1.30		1.50	
Average √ΔP		1.215		1.266		1.246	
Average Absolute Temp. ( °R )		653.8		667.2		668.9	
Stack Pressure (in. Hg)		30.04		30.04		30.04	
Stack Velocity (ft/sec)		76.17		79.89		78.76	
Actual Flow Rate (acfm)		22,433		23,531		23,197	
Standard Flow Rate (wscf/hr)		1,090,668		1,121,060		1,102,345	
Dry Standard Flow Rate (dscf/hr)		1,056,421		1,106,486		1,085,810	
Dry Standard Flow Rate (dscfm)		17,607		18,441		18,097	

	O <sub>2</sub>	CO <sub>2</sub>	Calculated N <sub>2</sub>
Run 1	20.12	0.58	79.31
Run 2	20.13	0.57	79.30
Run 3	20.12	0.58	79.30

	Molecular Weight (lb/lb-mole)					
	Calculated		Ambient		Combustion	
Run1	M <sub>d</sub>	28.9	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.56	M <sub>s</sub>		M <sub>s</sub>	
Run 2	M <sub>d</sub>	28.90	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.76	M <sub>s</sub>		M <sub>s</sub>	
Run 3	M <sub>d</sub>	28.90	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.74	M <sub>s</sub>		M <sub>s</sub>	

**Bison Engineering, Inc.**  
**Moisture Field Data**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 1  
**Location:** Corvallis, OR  
**Source:** CFU 108  
**Test date:** 12/13/2022

**Meterbox ID:** Box 11  
**Meter "Y"-Factor:** 0.9690

Moisture Field Data Entry			
Run 1			
Leak Checks:		Pre-test	Post-test
Train leak rate, dcf		0.000	0.000
Leak check vacuum, "Hg		15	8
Start Time		14:30	
End Time		15:30	
Bp, "Hg		30.00	

Minutes	Meter Volume	Meter °F	Condenser °F	Delta H
	447.135			
5	450.990	56	61	1.800
10	454.940	57	50	1.800
15	458.800	58	51	1.800
20	462.570	58	51	1.800
25	466.480	59	51	1.800
30	470.250	59	51	1.800
35	474.180	60	50	1.800
40	478.170	59	50	1.800
45	421.930	59	49	1.800
50	485.830	59	49	1.800
55	489.710	59	48	1.800
60	493.605	58	49	1.800

Impinger gain by weight (g):			
#	Initial	Final	Gain
1	792.6	800.7	8.1
2	769.9	774.9	5.0
3	696.8	699.2	2.4
Silica Gel	991.3	1007.5	16.2
Impinger Totals:	2,259.3	3,282.3	15.5

Moisture Field Data Entry			
Run 2			
Leak Checks:		Pre-test	Post-test
Train leak rate, dcf		0.000	0.000
Leak check vacuum, "Hg		15	9
Start Time		15:40	
End Time		16:40	
Bp, "Hg		30.00	

Meter Volume	Meter °F	Condenser °F	Delta H
494.300			
498.190	56	45	1.800
501.870	55	46	1.800
505.720	55	48	1.800
509.540	55	49	1.800
513.350	54	51	1.800
517.150	54	50	1.800
520.980	54	51	1.800
525.210	54	51	1.800
528.660	54	52	1.800
532.350	53	51	1.800
536.140	53	53	1.800
539.940	53	52	1.800

Impinger gain by weight (g):			
#	Initial	Final	Gain
1	760.0	763.7	3.7
2	779.7	780.8	1.1
3	616.1	616.6	0.5
Silica Gel	897.2	904.65	7.4
Impinger Totals:	3,053.0	3,065.8	5.3

Moisture Field Data Entry			
Run 3			
Leak Checks:		Pre-test	Post-test
Train leak rate, dcf		0.000	0.000
Leak check vacuum, "Hg		19	8
Start Time		16:50	
End Time		17:50	
Bp, "Hg		30.00	

Meter Volume	Meter °F	Condenser °F	Delta H
540.685			
544.460	52	41	1.800
548.220	51	42	1.800
552.000	51	42	1.800
555.730	51	44	1.800
559.520	50	44	1.800
563.260	50	44	1.800
567.040	50	46	1.800
570.760	50	45	1.800
574.510	50	46	1.800
578.260	50	45	1.800
582.000	50	46	1.800
585.750	50	46	1.800

Impinger gain by weight (g):			
#	Initial	Final	Gain
1	800.7	807.2	6.5
2	774.9	776.4	1.5
3	699.2	700.0	0.8
Silica Gel	1007.5	1013.4	5.9
Impinger Totals:	3,282.3	3,297.0	8.8

**Bison Engineering, Inc.**  
**Method 4 Moisture Calculations**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 1  
**Location:** Corvallis, OR  
**Source:** CFU 108  
**Test date:** 12/13/2022

Method 4 -Moisture Determination					
Run Number	#	1	2	3	
Start Time	hh:mm	14:30	15:40	16:50	
Meter Box Identification	#	Box 11	Box 11	Box 11	
Meter "Y" Factor	Factor	0.9690	0.9690	0.9690	
Barometric Pressure	in Hg	30.00	30.00	30.00	
Sample Duration	hh:mm	1:00	1:00	1:00	
Average Meter Temperature	Deg F	58.4	54.2	50.4	
Average Condenser Temperature	Deg F	50.8	49.9	44.3	
Average Delta H	in H2O	1.800	1.800	1.800	
Average Meter Pressure	in Hg	30.132	30.132	30.132	
Meter Volume Start	dcf	447.135	494.300	540.685	
Meter Volume End	dcf	493.605	539.940	585.750	
Meter Volume	dcf	46.470	45.640	45.065	
Corrected Meter Volume	dscf	46.187	45.738	45.493	
Impinger Gain	g	15.5	5.3	8.8	
Silica Gel Gain	g	16.2	7.4	5.9	Average
Volume of Condensed Water Vapor	scf	1.495	0.601	0.693	0.930
Moisture Calculation	Bws	0.0314	0.0130	0.0150	0.020
Percent Moisture	Bws%	3.14	1.30	1.50	1.98



**Bison Engineering, Inc.**  
**Method 3A Oxygen**  
**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU 108</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 1</b>	Date: <b>December 13, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values				System Drift % of span	Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference Gas
		Analyzer Cal. Response	System Cal Response	Pre test		System Cal Response	Post test							
				System Cal. Bias % of span	pass/fail		System Cal. Bias % of span	pass/fail						
Run 1	zero	-0.02	0.11	0.59	pass	0.10	0.55	pass	0.05	pass				
	upscale	10.01	10.08	0.32	pass	10.08	0.32	pass	0.00	pass	21.94	20.07	20.12	10.05
Run 2	zero	-0.02	0.10	0.55	pass	0.12	0.64	pass	0.09	pass				
	upscale	10.01	10.08	0.32	pass	10.08	0.32	pass	0.00	pass	21.94	20.08	20.13	10.05
Run 3	zero	-0.02	0.12	0.64	pass	0.10	0.55	pass	0.09	pass				
	upscale	10.01	10.08	0.32	pass	10.08	0.32	pass	0.00	pass	21.94	20.07	20.12	10.05
				<b>&lt; 5%*</b>		<b>&lt; 5%*</b>		<b>&lt; 3%*</b>						

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	10.05	21.94
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	-0.02	10.01	22.00
Analyzer Calibration Error	-0.09	-0.18	0.27
Analyzer Calibration Error < 2%*	pass	pass	pass

System Response Time	
30	seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %  
 \*Or < 0.5 % absolute difference

**Bison Engineering, Inc.**

**Method 3A CO<sub>2</sub>**

**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU 108</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 1</b>	Date: <b>December 13, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values				Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference Gas
		Analyzer Cal. Response	System Cal Response	Pre test System Cal. Bias		System Cal Response	Post test System Cal. Bias		System Drift				
				% of span	pass/fail		% of span	pass/fail	% of span	pass/fail			
Run 1	zero	-0.01	0.04	0.23	pass	0.05	0.28	pass	0.05	pass			
	upscale	9.82	9.96	0.65	pass	9.94	0.55	pass	0.09	pass	21.70	0.62	0.58
Run 2	zero	-0.01	0.05	0.28	pass	0.05	0.28	pass	0.00	pass			
	upscale	9.82	9.94	0.55	pass	10.02	0.92	pass	0.37	pass	21.70	0.62	0.57
Run 3	zero	-0.01	0.05	0.28	pass	0.04	0.23	pass	0.05	pass			
	upscale	9.82	10.02	0.92	pass	10.09	1.24	pass	0.32	pass	21.70	0.63	0.58
				<b>&lt; 5%*</b>		<b>&lt; 5%*</b>		<b>&lt; 3%*</b>					

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	9.951	21.70
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	-0.01	9.82	21.89
Analyzer Calibration Error	-0.05	-0.60	0.88
Analyzer Calibration Error < 2% *	pass	pass	pass

System Response Time
31 seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %

\*Or < 0.5 % absolute difference

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	6:07:36	8.05	0.01	
12/13/2022	6:08:36	-0.02	-0.01	<b>O2/CO2 Analyzer Zero</b>
12/13/2022	6:09:36	12.81	13.78	
12/13/2022	6:10:36	22.00	21.89	<b>O2/CO2 Analyzer Span</b>
12/13/2022	6:11:36	19.29	18.71	
12/13/2022	6:12:36	10.03	9.76	
12/13/2022	6:13:36	10.01	9.82	<b>O2/CO2 Analyzer Mid</b>
12/13/2022	6:14:36	10.39	9.02	
12/13/2022	6:15:36	6.97	0.29	
12/13/2022	6:16:36	0.13	0.04	
12/13/2022	6:17:36	0.08	0.03	<b>O2/CO2 System Zero</b>
12/13/2022	6:18:36	2.68	2.71	
12/13/2022	6:19:36	9.80	9.71	
12/13/2022	6:20:36	9.98	9.92	<b>O2/CO2 System Upscale</b>
12/13/2022	6:21:36	11.45	8.51	
12/13/2022	6:22:36	19.87	1.11	

**CFU 113**

12/13/2022	6:55:36	20.32	0.78	<b>Start Run 1</b>
12/13/2022	6:56:36	20.29	0.78	
12/13/2022	6:57:36	20.26	0.74	
12/13/2022	6:58:36	20.33	0.77	
12/13/2022	6:59:36	20.33	0.79	
12/13/2022	7:00:36	20.33	0.80	
12/13/2022	7:01:36	20.33	0.79	
12/13/2022	7:02:36	20.34	0.79	
12/13/2022	7:03:36	20.33	0.79	
12/13/2022	7:04:36	20.33	0.80	
12/13/2022	7:05:36	20.33	0.80	
12/13/2022	7:06:36	20.34	0.79	
12/13/2022	7:07:36	20.34	0.78	
12/13/2022	7:08:36	20.33	0.79	
12/13/2022	7:09:36	20.33	0.79	
12/13/2022	7:10:36	20.34	0.79	
12/13/2022	7:11:36	20.34	0.79	
12/13/2022	7:12:36	20.34	0.79	
12/13/2022	7:13:36	20.34	0.78	
12/13/2022	7:14:36	20.35	0.78	
12/13/2022	7:15:36	20.34	0.78	

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	7:16:36	20.34	0.79	
12/13/2022	7:17:36	20.34	0.79	
12/13/2022	7:18:36	20.34	0.79	
12/13/2022	7:19:36	20.34	0.78	
12/13/2022	7:20:36	20.34	0.79	
12/13/2022	7:21:36	20.35	0.79	
12/13/2022	7:22:36	20.35	0.79	
12/13/2022	7:23:36	20.36	0.79	
12/13/2022	7:24:36	20.37	0.80	
12/13/2022	7:25:36	20.41	0.81	
12/13/2022	7:26:36	20.43	0.81	
12/13/2022	7:27:36	20.44	0.81	
12/13/2022	7:28:36	20.44	0.82	
12/13/2022	7:29:36	20.45	0.82	
12/13/2022	7:30:36	20.47	0.79	
12/13/2022	7:31:36	20.46	0.80	
12/13/2022	7:32:36	20.46	0.81	
12/13/2022	7:33:36	20.46	0.80	
12/13/2022	7:34:36	20.47	0.79	
12/13/2022	7:35:36	20.46	0.79	
12/13/2022	7:36:36	20.46	0.79	
12/13/2022	7:37:36	20.46	0.78	
12/13/2022	7:38:36	20.47	0.77	
12/13/2022	7:39:36	20.46	0.78	
12/13/2022	7:40:36	20.47	0.78	
12/13/2022	7:41:36	20.47	0.78	
12/13/2022	7:42:36	20.47	0.78	
12/13/2022	7:43:36	20.47	0.78	
12/13/2022	7:44:36	20.47	0.78	
12/13/2022	7:45:36	20.47	0.78	
12/13/2022	7:46:36	20.47	0.78	
12/13/2022	7:47:36	20.47	0.77	
12/13/2022	7:48:36	20.48	0.78	
12/13/2022	7:49:36	20.47	0.78	
12/13/2022	7:50:36	20.47	0.79	

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	7:51:36	20.47	0.80	
12/13/2022	7:52:36	20.48	0.79	
12/13/2022	7:53:36	20.48	0.78	
12/13/2022	7:54:36	20.48	0.80	<b>End Run 1</b>
		<b>20.40</b>	<b>0.79</b>	<b>Average</b>
12/13/2022	7:55:36	20.48	0.79	
12/13/2022	7:56:36	8.37	0.51	
12/13/2022	7:57:36	0.17	0.03	
12/13/2022	7:58:36	0.09	0.02	<b>O2/CO2 System Zero</b>
12/13/2022	7:59:36	4.09	4.00	
12/13/2022	8:00:36	9.98	9.70	
12/13/2022	8:01:36	10.08	9.83	<b>O2/CO2 System Upscale</b>
12/13/2022	8:02:36	14.76	5.58	
12/13/2022	8:03:36	20.36	0.88	
12/13/2022	8:04:36	20.45	0.81	
12/13/2022	8:05:36	20.46	0.80	<b>Start Run 2</b>
12/13/2022	8:06:36	20.47	0.79	
12/13/2022	8:07:36	20.48	0.78	
12/13/2022	8:08:36	20.48	0.78	
12/13/2022	8:09:36	20.48	0.78	
12/13/2022	8:10:36	20.48	0.78	
12/13/2022	8:11:36	20.48	0.78	
12/13/2022	8:12:36	20.48	0.78	
12/13/2022	8:13:36	20.48	0.80	
12/13/2022	8:14:36	20.48	0.80	
12/13/2022	8:15:36	20.49	0.79	
12/13/2022	8:16:36	20.49	0.79	
12/13/2022	8:17:36	20.49	0.78	
12/13/2022	8:18:36	20.49	0.80	
12/13/2022	8:19:36	20.48	0.81	
12/13/2022	8:20:36	20.48	0.81	
12/13/2022	8:21:36	20.48	0.80	
12/13/2022	8:22:36	20.48	0.81	
12/13/2022	8:23:36	20.48	0.80	
12/13/2022	8:24:36	20.49	0.79	
12/13/2022	8:25:36	20.49	0.80	
12/13/2022	8:26:36	20.48	0.80	

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	8:27:36	20.49	0.79	
12/13/2022	8:28:36	20.48	0.79	
12/13/2022	8:29:36	20.48	0.79	
12/13/2022	8:30:36	20.48	0.80	
12/13/2022	8:31:36	20.48	0.79	
12/13/2022	8:32:36	20.48	0.80	
12/13/2022	8:33:36	20.48	0.80	
12/13/2022	8:34:36	20.48	0.80	
12/13/2022	8:35:36	20.49	0.80	
12/13/2022	8:36:36	20.49	0.80	
12/13/2022	8:37:36	20.49	0.79	
12/13/2022	8:38:36	20.49	0.80	
12/13/2022	8:39:36	20.50	0.79	
12/13/2022	8:40:36	20.50	0.80	
12/13/2022	8:41:36	20.50	0.79	
12/13/2022	8:42:36	20.50	0.81	
12/13/2022	8:43:36	20.50	0.82	
12/13/2022	8:44:36	20.50	0.81	
12/13/2022	8:45:36	20.50	0.81	
12/13/2022	8:46:36	20.50	0.82	
12/13/2022	8:47:36	20.50	0.81	
12/13/2022	8:48:36	20.50	0.81	
12/13/2022	8:49:36	20.50	0.81	
12/13/2022	8:50:36	20.50	0.82	
12/13/2022	8:51:36	20.50	0.81	
12/13/2022	8:52:36	20.50	0.81	
12/13/2022	8:53:36	20.50	0.81	
12/13/2022	8:54:36	20.50	0.81	
12/13/2022	8:55:36	20.50	0.80	
12/13/2022	8:56:36	20.51	0.79	
12/13/2022	8:57:36	20.51	0.78	
12/13/2022	8:58:36	20.51	0.80	
12/13/2022	8:59:36	20.51	0.80	
12/13/2022	9:00:36	20.51	0.80	
12/13/2022	9:01:36	20.51	0.80	
12/13/2022	9:02:36	20.51	0.80	
12/13/2022	9:03:36	20.52	0.80	
12/13/2022	9:04:36	20.51	0.79	<b>End Run 2</b>
		<b>20.49</b>	<b>0.80</b>	<b>Average</b>

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	9:05:36	20.51	0.81	
12/13/2022	9:06:36	20.51	0.81	
12/13/2022	9:07:36	20.51	0.82	
12/13/2022	9:08:36	20.51	0.82	
12/13/2022	9:09:36	14.93	0.77	
12/13/2022	9:10:36	0.48	0.07	
12/13/2022	9:11:36	0.11	0.04	
12/13/2022	9:12:36	0.09	0.04	<b>O2/CO2 System Zero</b>
12/13/2022	9:13:36	0.08	0.03	
12/13/2022	9:14:36	9.88	9.73	
12/13/2022	9:15:36	10.08	10.03	<b>O2/CO2 System Upscale</b>
12/13/2022	9:16:36	12.33	4.13	
12/13/2022	9:17:36	19.42	0.77	
12/13/2022	9:18:36	20.47	0.81	
12/13/2022	9:19:36	20.49	0.82	
12/13/2022	9:20:36	20.50	0.83	<b>Start Run 3</b>
12/13/2022	9:21:36	20.51	0.82	
12/13/2022	9:22:36	20.52	0.81	
12/13/2022	9:23:36	20.52	0.81	
12/13/2022	9:24:36	20.52	0.82	
12/13/2022	9:25:36	20.52	0.82	
12/13/2022	9:26:36	20.52	0.82	
12/13/2022	9:27:36	20.52	0.83	
12/13/2022	9:28:36	20.52	0.83	
12/13/2022	9:29:36	20.53	0.83	
12/13/2022	9:30:36	20.53	0.83	
12/13/2022	9:31:36	20.52	0.84	
12/13/2022	9:32:36	20.52	0.84	
12/13/2022	9:33:36	20.52	0.84	
12/13/2022	9:34:36	20.51	0.85	
12/13/2022	9:35:36	20.51	0.84	
12/13/2022	9:36:36	20.51	0.85	
12/13/2022	9:37:36	20.51	0.85	
12/13/2022	9:38:36	20.51	0.85	
12/13/2022	9:39:36	20.51	0.84	
12/13/2022	9:40:36	20.51	0.85	
12/13/2022	9:41:36	20.51	0.84	

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	9:42:36	20.51	0.84	
12/13/2022	9:43:36	20.51	0.84	
12/13/2022	9:44:36	20.50	0.85	
12/13/2022	9:45:36	20.50	0.85	
12/13/2022	9:46:36	20.51	0.85	
12/13/2022	9:47:36	20.51	0.84	
12/13/2022	9:48:36	20.51	0.84	
12/13/2022	9:49:36	20.51	0.84	
12/13/2022	9:50:36	20.51	0.84	
12/13/2022	9:51:36	20.51	0.85	
12/13/2022	9:52:36	20.51	0.84	
12/13/2022	9:53:36	20.51	0.84	
12/13/2022	9:54:36	20.51	0.84	
12/13/2022	9:55:36	20.50	0.85	
12/13/2022	9:56:36	20.50	0.86	
12/13/2022	9:57:36	20.50	0.86	
12/13/2022	9:58:36	20.50	0.86	
12/13/2022	9:59:36	20.50	0.87	
12/13/2022	10:00:36	20.50	0.87	
12/13/2022	10:01:36	20.50	0.86	
12/13/2022	10:02:36	20.50	0.87	
12/13/2022	10:03:36	20.50	0.86	
12/13/2022	10:04:36	20.50	0.87	
12/13/2022	10:05:36	20.50	0.87	
12/13/2022	10:06:36	20.50	0.87	
12/13/2022	10:07:36	20.50	0.87	
12/13/2022	10:08:36	20.50	0.87	
12/13/2022	10:09:36	20.50	0.86	
12/13/2022	10:10:36	20.50	0.85	
12/13/2022	10:11:36	20.50	0.85	
12/13/2022	10:12:36	20.50	0.85	
12/13/2022	10:13:36	20.50	0.85	
12/13/2022	10:14:36	20.49	0.85	
12/13/2022	10:15:36	20.50	0.84	
12/13/2022	10:16:36	20.49	0.85	
12/13/2022	10:17:36	20.49	0.85	
12/13/2022	10:18:36	20.50	0.84	
12/13/2022	10:19:36	20.49	0.84	<b>End Run 3</b>
		<b>20.51</b>	<b>0.85</b>	<b>Average</b>



**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	10:20:36	20.49	0.85	
12/13/2022	10:21:36	13.55	0.59	
12/13/2022	10:22:36	0.36	0.03	
12/13/2022	10:23:36	0.11	0.02	
12/13/2022	10:24:36	0.09	0.02	<b>O2/CO2 System Zero</b>
12/13/2022	10:25:36	1.75	1.74	
12/13/2022	10:26:36	9.74	9.61	
12/13/2022	10:27:36	10.08	10.01	<b>O2/CO2 System Upscale</b>
12/13/2022	10:28:36	14.86	5.41	
12/13/2022	10:29:36	20.28	0.57	
12/13/2022	10:30:36	20.36	0.50	
12/13/2022	10:31:36	20.36	0.50	
12/13/2022	10:32:36	20.36	0.49	
12/13/2022	10:33:36	20.36	0.49	
12/13/2022	10:34:36	20.37	0.49	
<b>CFU 112</b>				
12/13/2022	10:35:36	20.38	0.48	<b>Start Run 1</b>
12/13/2022	10:36:36	20.36	0.49	
12/13/2022	10:37:36	20.37	0.48	
12/13/2022	10:38:36	20.36	0.49	
12/13/2022	10:39:36	20.36	0.48	
12/13/2022	10:40:36	20.35	0.48	
12/13/2022	10:41:36	20.37	0.47	
12/13/2022	10:42:36	20.37	0.47	
12/13/2022	10:43:36	20.38	0.47	
12/13/2022	10:44:36	20.37	0.47	
12/13/2022	10:45:36	20.37	0.47	
12/13/2022	10:46:36	20.37	0.47	
12/13/2022	10:47:36	20.35	0.48	
12/13/2022	10:48:36	20.36	0.48	
12/13/2022	10:49:36	20.36	0.48	
12/13/2022	10:50:36	20.37	0.48	
12/13/2022	10:51:36	20.35	0.49	
12/13/2022	10:52:36	20.35	0.49	
12/13/2022	10:53:36	20.34	0.49	
12/13/2022	10:54:36	20.36	0.49	
12/13/2022	10:55:36	20.36	0.48	
12/13/2022	10:56:36	20.36	0.49	

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	10:57:36	20.36	0.48	
12/13/2022	10:58:36	20.36	0.48	
12/13/2022	10:59:36	20.36	0.48	
12/13/2022	11:00:36	20.35	0.49	
12/13/2022	11:01:36	20.36	0.48	
12/13/2022	11:02:36	20.35	0.48	
12/13/2022	11:03:36	20.36	0.48	
12/13/2022	11:04:36	20.35	0.48	
12/13/2022	11:05:36	20.36	0.47	
12/13/2022	11:06:36	20.35	0.47	
12/13/2022	11:07:36	20.37	0.46	
12/13/2022	11:08:36	20.36	0.47	
12/13/2022	11:09:36	20.36	0.47	
12/13/2022	11:10:36	20.35	0.48	
12/13/2022	11:11:36	20.35	0.48	
12/13/2022	11:12:36	20.35	0.48	
12/13/2022	11:13:36	20.34	0.48	
12/13/2022	11:14:36	20.36	0.47	
12/13/2022	11:15:36	20.36	0.48	
12/13/2022	11:16:36	20.37	0.48	
12/13/2022	11:17:36	20.36	0.48	
12/13/2022	11:18:36	20.36	0.48	
12/13/2022	11:19:36	20.36	0.49	
12/13/2022	11:20:36	20.36	0.49	
12/13/2022	11:21:36	20.35	0.49	
12/13/2022	11:22:36	20.35	0.49	
12/13/2022	11:23:36	20.35	0.49	
12/13/2022	11:24:36	20.35	0.49	
12/13/2022	11:25:36	20.35	0.49	
12/13/2022	11:26:36	20.35	0.49	
12/13/2022	11:27:36	20.36	0.48	
12/13/2022	11:28:36	20.34	0.49	
12/13/2022	11:29:36	20.35	0.48	
12/13/2022	11:30:36	20.35	0.48	
12/13/2022	11:31:36	20.36	0.47	
12/13/2022	11:32:36	20.35	0.48	
12/13/2022	11:33:36	20.35	0.47	
12/13/2022	11:34:36	20.35	0.48	<b>End Run 1</b>
		<b>20.36</b>	<b>0.48</b>	<b>Average</b>

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	11:35:36	20.35	0.47	
12/13/2022	11:36:36	16.00	0.55	
12/13/2022	11:37:36	0.61	0.06	
12/13/2022	11:38:36	0.10	0.02	<b>O2/CO2 System Zero</b>
12/13/2022	11:39:36	2.27	2.28	
12/13/2022	11:40:36	9.83	9.76	
12/13/2022	11:41:36	10.07	10.06	<b>O2/CO2 System Upscale</b>
12/13/2022	11:42:36	12.07	8.05	
12/13/2022	11:43:36	20.01	0.76	
12/13/2022	11:44:36	20.33	0.52	
12/13/2022	11:45:36	20.33	0.50	<b>Start Run 2</b>
12/13/2022	11:46:36	20.34	0.50	
12/13/2022	11:47:36	20.34	0.50	
12/13/2022	11:48:36	20.34	0.50	
12/13/2022	11:49:36	20.34	0.49	
12/13/2022	11:50:36	20.34	0.49	
12/13/2022	11:51:36	20.35	0.48	
12/13/2022	11:52:36	20.34	0.49	
12/13/2022	11:53:36	20.35	0.48	
12/13/2022	11:54:36	20.35	0.48	
12/13/2022	11:55:36	20.36	0.47	
12/13/2022	11:56:36	20.35	0.47	
12/13/2022	11:57:36	20.37	0.46	
12/13/2022	11:58:36	20.35	0.47	
12/13/2022	11:59:36	20.35	0.47	
12/13/2022	12:00:36	20.34	0.47	
12/13/2022	12:01:36	20.34	0.48	
12/13/2022	12:02:36	20.34	0.48	
12/13/2022	12:03:36	20.34	0.48	
12/13/2022	12:04:36	20.35	0.47	
12/13/2022	12:05:36	20.34	0.48	
12/13/2022	12:06:36	20.34	0.48	
12/13/2022	12:07:36	20.34	0.48	
12/13/2022	12:08:36	20.35	0.48	
12/13/2022	12:09:36	20.33	0.50	
12/13/2022	12:10:36	20.34	0.49	
12/13/2022	12:11:36	20.34	0.49	

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	12:12:36	20.34	0.49	
12/13/2022	12:13:36	20.34	0.48	
12/13/2022	12:14:36	20.34	0.49	
12/13/2022	12:15:36	20.35	0.48	
12/13/2022	12:16:36	20.35	0.48	
12/13/2022	12:17:36	20.35	0.48	
12/13/2022	12:18:36	20.33	0.49	
12/13/2022	12:19:36	20.35	0.48	
12/13/2022	12:20:36	20.33	0.48	
12/13/2022	12:21:36	20.34	0.47	
12/13/2022	12:22:36	20.34	0.47	
12/13/2022	12:23:36	20.34	0.47	
12/13/2022	12:24:36	20.34	0.48	
12/13/2022	12:25:36	20.35	0.48	
12/13/2022	12:26:36	20.35	0.47	
12/13/2022	12:27:36	20.33	0.48	
12/13/2022	12:28:36	20.35	0.47	
12/13/2022	12:29:36	20.34	0.48	
12/13/2022	12:30:36	20.35	0.48	
12/13/2022	12:31:36	20.34	0.48	
12/13/2022	12:32:36	20.35	0.48	
12/13/2022	12:33:36	20.34	0.49	
12/13/2022	12:34:36	20.36	0.49	
12/13/2022	12:35:36	20.34	0.49	
12/13/2022	12:36:36	20.35	0.49	
12/13/2022	12:37:36	20.35	0.49	
12/13/2022	12:38:36	20.35	0.49	
12/13/2022	12:39:36	20.35	0.49	
12/13/2022	12:40:36	20.34	0.49	
12/13/2022	12:41:36	20.36	0.48	
12/13/2022	12:42:36	20.35	0.49	
12/13/2022	12:43:36	20.36	0.48	
12/13/2022	12:44:36	20.35	0.48	<b>End Run 2</b>
		<b>20.34</b>	<b>0.48</b>	<b>Average</b>
12/13/2022	12:45:36	16.14	0.56	
12/13/2022	12:46:36	0.61	0.06	
12/13/2022	12:47:36	0.10	0.02	
12/13/2022	12:48:36	0.08	0.02	<b>O2/CO2 System Zero</b>

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	12:49:36	3.32	3.33	
12/13/2022	12:50:36	9.94	9.86	
12/13/2022	12:51:36	10.07	10.03	<b>O2/CO2 System Upscale</b>
12/13/2022	12:52:36	11.09	8.99	
12/13/2022	12:53:36	19.74	0.96	
12/13/2022	12:54:36	20.31	0.51	
12/13/2022	12:55:36	20.33	0.50	
12/13/2022	12:56:36	20.35	0.49	
12/13/2022	12:57:36	20.35	0.49	
12/13/2022	12:58:36	20.35	0.49	
12/13/2022	12:59:36	20.34	0.50	
12/13/2022	13:00:36	20.34	0.49	<b>Start Run 3</b>
12/13/2022	13:01:36	20.34	0.50	
12/13/2022	13:02:36	20.35	0.49	
12/13/2022	13:03:36	20.34	0.49	
12/13/2022	13:04:36	20.34	0.50	
12/13/2022	13:05:36	20.35	0.49	
12/13/2022	13:06:36	20.35	0.49	
12/13/2022	13:07:36	20.35	0.48	
12/13/2022	13:08:36	20.34	0.49	
12/13/2022	13:09:36	20.35	0.48	
12/13/2022	13:10:36	20.33	0.49	
12/13/2022	13:11:36	20.35	0.48	
12/13/2022	13:12:36	20.35	0.48	
12/13/2022	13:13:36	20.35	0.48	
12/13/2022	13:14:36	20.34	0.48	
12/13/2022	13:15:36	20.34	0.49	
12/13/2022	13:16:36	20.35	0.48	
12/13/2022	13:17:36	20.34	0.48	
12/13/2022	13:18:36	20.34	0.48	
12/13/2022	13:19:36	20.33	0.49	
12/13/2022	13:20:36	20.35	0.48	
12/13/2022	13:21:36	20.34	0.48	
12/13/2022	13:22:36	20.35	0.48	
12/13/2022	13:23:36	20.34	0.49	
12/13/2022	13:24:36	20.34	0.49	
12/13/2022	13:25:36	20.33	0.50	
12/13/2022	13:26:36	20.34	0.49	

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	13:27:36	20.35	0.49	
12/13/2022	13:28:36	20.34	0.49	
12/13/2022	13:29:36	20.34	0.49	
12/13/2022	13:30:36	20.34	0.49	
12/13/2022	13:31:36	20.34	0.49	
12/13/2022	13:32:36	20.33	0.49	
12/13/2022	13:33:36	20.34	0.48	
12/13/2022	13:34:36	20.34	0.49	
12/13/2022	13:35:36	20.34	0.48	
12/13/2022	13:36:36	20.34	0.48	
12/13/2022	13:37:36	20.34	0.48	
12/13/2022	13:38:36	20.34	0.48	
12/13/2022	13:39:36	20.34	0.48	
12/13/2022	13:40:36	20.34	0.48	
12/13/2022	13:41:36	20.34	0.48	
12/13/2022	13:42:36	20.34	0.48	
12/13/2022	13:43:36	20.33	0.49	
12/13/2022	13:44:36	20.35	0.48	
12/13/2022	13:45:36	20.34	0.48	
12/13/2022	13:46:36	20.35	0.48	
12/13/2022	13:47:36	20.34	0.49	
12/13/2022	13:48:36	20.35	0.49	
12/13/2022	13:49:36	20.34	0.49	
12/13/2022	13:50:36	20.35	0.49	
12/13/2022	13:51:36	20.33	0.50	
12/13/2022	13:52:36	20.34	0.49	
12/13/2022	13:53:36	20.35	0.49	
12/13/2022	13:54:36	20.35	0.49	
12/13/2022	13:55:36	20.36	0.49	
12/13/2022	13:56:36	20.34	0.49	
12/13/2022	13:57:36	20.35	0.49	
12/13/2022	13:58:36	20.35	0.48	
12/13/2022	13:59:36	20.36	0.48	<b>End Run 3</b>
		<b>20.34</b>	<b>0.49</b>	<b>Average</b>
12/13/2022	14:00:36	20.34	0.49	
12/13/2022	14:01:36	8.67	0.42	
12/13/2022	14:02:36	0.17	0.03	
12/13/2022	14:03:36	0.09	0.03	<b>O2/CO2 System Zero</b>

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	14:04:36	0.08	0.03	
12/13/2022	14:05:36	7.00	7.00	
12/13/2022	14:06:36	10.05	10.00	O2/CO2 System Upscale
12/13/2022	14:07:36	12.06	8.09	
12/13/2022	14:08:36	20.69	0.39	
12/13/2022	14:09:36	21.04	0.10	
12/13/2022	14:10:36	21.05	0.09	
12/13/2022	14:11:36	21.05	0.10	
12/13/2022	14:12:36	21.05	0.09	
12/13/2022	14:13:36	21.05	0.09	
12/13/2022	14:14:36	21.05	0.09	
12/13/2022	14:15:36	20.75	0.26	
12/13/2022	14:16:36	20.08	0.61	
12/13/2022	14:17:36	10.86	0.55	
12/13/2022	14:18:36	0.25	0.05	
12/13/2022	14:19:36	0.11	0.04	O2/CO2 System Zero
12/13/2022	14:20:36	3.77	3.75	
12/13/2022	14:21:36	9.96	9.80	
12/13/2022	14:22:36	10.08	9.96	O2/CO2 System Upscale
12/13/2022	14:23:36	16.96	3.37	
12/13/2022	14:24:36	20.01	0.68	
12/13/2022	14:25:36	20.04	0.64	
12/13/2022	14:26:36	20.05	0.63	
12/13/2022	14:27:36	20.05	0.63	
12/13/2022	14:28:36	20.06	0.63	
12/13/2022	14:29:36	20.06	0.63	
<b>CFU108</b>				
12/13/2022	14:30:36	20.06	0.62	<b>Start Run 1</b>
12/13/2022	14:31:36	20.06	0.62	
12/13/2022	14:32:36	20.07	0.62	
12/13/2022	14:33:36	20.07	0.63	
12/13/2022	14:34:36	20.07	0.62	
12/13/2022	14:35:36	20.07	0.62	
12/13/2022	14:36:36	20.07	0.63	
12/13/2022	14:37:36	20.07	0.63	
12/13/2022	14:38:36	20.06	0.63	
12/13/2022	14:39:36	20.06	0.64	
12/13/2022	14:40:36	20.06	0.64	
12/13/2022	14:41:36	20.07	0.63	

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	14:42:36	20.07	0.63	
12/13/2022	14:43:36	20.08	0.63	
12/13/2022	14:44:36	20.07	0.63	
12/13/2022	14:45:36	20.07	0.63	
12/13/2022	14:46:36	20.06	0.63	
12/13/2022	14:47:36	20.06	0.63	
12/13/2022	14:48:36	20.07	0.62	
12/13/2022	14:49:36	20.07	0.62	
12/13/2022	14:50:36	20.07	0.62	
12/13/2022	14:51:36	20.07	0.62	
12/13/2022	14:52:36	20.07	0.62	
12/13/2022	14:53:36	20.07	0.62	
12/13/2022	14:54:36	20.07	0.62	
12/13/2022	14:55:36	20.07	0.62	
12/13/2022	14:56:36	20.07	0.62	
12/13/2022	14:57:36	20.07	0.62	
12/13/2022	14:58:36	20.07	0.62	
12/13/2022	14:59:36	20.07	0.62	
12/13/2022	15:00:36	20.07	0.63	
12/13/2022	15:01:36	20.07	0.62	
12/13/2022	15:02:36	20.07	0.63	
12/13/2022	15:03:36	20.07	0.63	
12/13/2022	15:04:36	20.07	0.63	
12/13/2022	15:05:36	20.08	0.63	
12/13/2022	15:06:36	20.07	0.63	
12/13/2022	15:07:36	20.07	0.63	
12/13/2022	15:08:36	20.07	0.63	
12/13/2022	15:09:36	20.07	0.63	
12/13/2022	15:10:36	20.07	0.63	
12/13/2022	15:11:36	20.06	0.63	
12/13/2022	15:12:36	20.06	0.62	
12/13/2022	15:13:36	20.06	0.62	
12/13/2022	15:14:36	20.06	0.62	
12/13/2022	15:15:36	20.06	0.62	
12/13/2022	15:16:36	20.06	0.61	
12/13/2022	15:17:36	20.06	0.61	
12/13/2022	15:18:36	20.06	0.61	
12/13/2022	15:19:36	20.06	0.61	
12/13/2022	15:20:36	20.06	0.61	



**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	15:21:36	20.06	0.62	
12/13/2022	15:22:36	20.06	0.62	
12/13/2022	15:23:36	20.06	0.62	
12/13/2022	15:24:36	20.06	0.61	
12/13/2022	15:25:36	20.07	0.62	
12/13/2022	15:26:36	20.08	0.62	
12/13/2022	15:27:36	20.07	0.62	
12/13/2022	15:28:36	20.07	0.62	
12/13/2022	15:29:36	20.07	0.63	<b>End Run 1</b>
		<b>20.07</b>	<b>0.62</b>	<b>Average</b>
12/13/2022	15:30:36	20.07	0.63	
12/13/2022	15:31:36	18.23	0.81	
12/13/2022	15:32:36	1.30	0.20	
12/13/2022	15:33:36	0.12	0.05	
12/13/2022	15:34:36	0.10	0.05	<b>O2/CO2 System Zero</b>
12/13/2022	15:35:36	5.21	5.16	
12/13/2022	15:36:36	10.02	9.85	
12/13/2022	15:37:36	10.08	9.94	<b>O2/CO2 System Upscale</b>
12/13/2022	15:38:36	14.45	5.68	
12/13/2022	15:39:36	19.95	0.72	
12/13/2022	15:40:36	20.04	0.64	<b>Start Run 2</b>
12/13/2022	15:41:36	20.05	0.63	
12/13/2022	15:42:36	20.06	0.62	
12/13/2022	15:43:36	20.07	0.62	
12/13/2022	15:44:36	20.07	0.62	
12/13/2022	15:45:36	20.07	0.62	
12/13/2022	15:46:36	20.07	0.62	
12/13/2022	15:47:36	20.07	0.61	
12/13/2022	15:48:36	20.08	0.61	
12/13/2022	15:49:36	20.08	0.62	
12/13/2022	15:50:36	20.07	0.63	
12/13/2022	15:51:36	20.07	0.62	
12/13/2022	15:52:36	20.07	0.62	
12/13/2022	15:53:36	20.07	0.63	
12/13/2022	15:54:36	20.07	0.63	
12/13/2022	15:55:36	20.07	0.63	
12/13/2022	15:56:36	20.08	0.63	

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	15:57:36	20.07	0.63	
12/13/2022	15:58:36	20.07	0.63	
12/13/2022	15:59:36	20.08	0.63	
12/13/2022	16:00:36	20.08	0.63	
12/13/2022	16:01:36	20.08	0.63	
12/13/2022	16:02:36	20.08	0.63	
12/13/2022	16:03:36	20.08	0.62	
12/13/2022	16:04:36	20.08	0.62	
12/13/2022	16:05:36	20.08	0.62	
12/13/2022	16:06:36	20.08	0.62	
12/13/2022	16:07:36	20.07	0.62	
12/13/2022	16:08:36	20.08	0.62	
12/13/2022	16:09:36	20.09	0.61	
12/13/2022	16:10:36	20.09	0.61	
12/13/2022	16:11:36	20.08	0.61	
12/13/2022	16:12:36	20.07	0.62	
12/13/2022	16:13:36	20.08	0.62	
12/13/2022	16:14:36	20.08	0.62	
12/13/2022	16:15:36	20.08	0.62	
12/13/2022	16:16:36	20.08	0.62	
12/13/2022	16:17:36	20.08	0.63	
12/13/2022	16:18:36	20.08	0.63	
12/13/2022	16:19:36	20.08	0.63	
12/13/2022	16:20:36	20.08	0.63	
12/13/2022	16:21:36	20.08	0.63	
12/13/2022	16:22:36	20.08	0.63	
12/13/2022	16:23:36	20.08	0.63	
12/13/2022	16:24:36	20.08	0.63	
12/13/2022	16:25:36	20.08	0.63	
12/13/2022	16:26:36	20.08	0.63	
12/13/2022	16:27:36	20.08	0.63	
12/13/2022	16:28:36	20.07	0.63	
12/13/2022	16:29:36	20.07	0.62	
12/13/2022	16:30:36	20.08	0.62	
12/13/2022	16:31:36	20.08	0.61	
12/13/2022	16:32:36	20.08	0.61	
12/13/2022	16:33:36	20.08	0.62	
12/13/2022	16:34:36	20.07	0.62	
12/13/2022	16:35:36	20.08	0.62	

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	16:36:36	20.08	0.62	
12/13/2022	16:37:36	20.07	0.62	
12/13/2022	16:38:36	20.08	0.62	
12/13/2022	16:39:36	20.08	0.62	<b>End Run 2</b>
		<b>20.08</b>	<b>0.62</b>	<b>Average</b>
12/13/2022	16:40:36	20.07	0.62	
12/13/2022	16:41:36	20.09	0.61	
12/13/2022	16:42:36	11.47	0.83	
12/13/2022	16:43:36	0.28	0.08	
12/13/2022	16:44:36	0.12	0.05	<b>O2/CO2 System Zero</b>
12/13/2022	16:45:36	2.14	2.15	
12/13/2022	16:46:36	9.80	9.66	
12/13/2022	16:47:36	10.08	10.02	<b>O2/CO2 System Upscale</b>
12/13/2022	16:48:36	12.84	7.30	
12/13/2022	16:49:36	19.85	0.82	
12/13/2022	16:50:36	20.04	0.67	<b>Start Run 3</b>
12/13/2022	16:51:36	20.05	0.65	
12/13/2022	16:52:36	20.06	0.64	
12/13/2022	16:53:36	20.07	0.63	
12/13/2022	16:54:36	20.07	0.63	
12/13/2022	16:55:36	20.07	0.62	
12/13/2022	16:56:36	20.08	0.62	
12/13/2022	16:57:36	20.08	0.62	
12/13/2022	16:58:36	20.08	0.62	
12/13/2022	16:59:36	20.07	0.62	
12/13/2022	17:00:36	20.06	0.62	
12/13/2022	17:01:36	20.06	0.62	
12/13/2022	17:02:36	20.06	0.62	
12/13/2022	17:03:36	20.07	0.62	
12/13/2022	17:04:36	20.07	0.62	
12/13/2022	17:05:36	20.07	0.62	
12/13/2022	17:06:36	20.07	0.62	
12/13/2022	17:07:36	20.07	0.63	
12/13/2022	17:08:36	20.07	0.63	
12/13/2022	17:09:36	20.07	0.63	
12/13/2022	17:10:36	20.07	0.63	
12/13/2022	17:11:36	20.07	0.63	

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	17:12:36	20.07	0.63	
12/13/2022	17:13:36	20.08	0.63	
12/13/2022	17:14:36	20.09	0.63	
12/13/2022	17:15:36	20.08	0.63	
12/13/2022	17:16:36	20.07	0.63	
12/13/2022	17:17:36	20.07	0.63	
12/13/2022	17:18:36	20.07	0.63	
12/13/2022	17:19:36	20.07	0.62	
12/13/2022	17:20:36	20.07	0.63	
12/13/2022	17:21:36	20.07	0.62	
12/13/2022	17:22:36	20.07	0.63	
12/13/2022	17:23:36	20.06	0.63	
12/13/2022	17:24:36	20.06	0.63	
12/13/2022	17:25:36	20.06	0.63	
12/13/2022	17:26:36	20.07	0.63	
12/13/2022	17:27:36	20.07	0.63	
12/13/2022	17:28:36	20.07	0.63	
12/13/2022	17:29:36	20.07	0.63	
12/13/2022	17:30:36	20.07	0.63	
12/13/2022	17:31:36	20.07	0.63	
12/13/2022	17:32:36	20.07	0.64	
12/13/2022	17:33:36	20.06	0.64	
12/13/2022	17:34:36	20.07	0.64	
12/13/2022	17:35:36	20.08	0.63	
12/13/2022	17:36:36	20.09	0.63	
12/13/2022	17:37:36	20.08	0.64	
12/13/2022	17:38:36	20.08	0.64	
12/13/2022	17:39:36	20.07	0.64	
12/13/2022	17:40:36	20.07	0.63	
12/13/2022	17:41:36	20.08	0.64	
12/13/2022	17:42:36	20.08	0.64	
12/13/2022	17:43:36	20.07	0.63	
12/13/2022	17:44:36	20.07	0.63	
12/13/2022	17:45:36	20.08	0.63	
12/13/2022	17:46:36	20.08	0.63	
12/13/2022	17:47:36	20.08	0.62	
12/13/2022	17:48:36	20.08	0.62	
12/13/2022	17:49:36	20.07	0.63	<b>End Run 3</b>
		<b>20.07</b>	<b>0.63</b>	<b>Average</b>

**Hollingsworth & Vose - Glass Plant 1**  
**CFUs 113, 112, and 108**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>NOTES</b>
12/13/2022	17:50:36	20.08	0.63	
12/13/2022	17:51:36	19.40	0.56	
12/13/2022	17:52:36	1.69	0.22	
12/13/2022	17:53:36	0.13	0.04	
12/13/2022	17:54:36	0.10	0.04	<b>O2/CO2 System Zero</b>
12/13/2022	17:55:36	2.60	2.62	
12/13/2022	17:56:36	9.88	9.84	
12/13/2022	17:57:36	10.08	10.09	<b>O2/CO2 System Upscale</b>
12/13/2022	17:58:36	15.94	4.60	
12/13/2022	17:59:36	20.88	0.25	

## **APPENDIX D: CFU 115 TEST DATA**

---

Hollingsworth & Vose  
 Corvallis, OR  
 CFU 115 Speciated Organic Toxic Air Contaminants (TAC)

Run Number	1	2	3
Sample Collection Date	12/14/2022	12/14/2022	12/14/2022
Volumetric Flow Rate Measured by Bison (dscfm)	18,896	18,897	19,230

Analyte	Molecular Weight g/mol	CFU 115-1			CFU 115-2			CFU 115-3			CI		
		ppb	ppm	lb/hr	ppb	ppm	lb/hr	ppb	ppm	lb/hr	ppb	ppm	lb/hr
Dichlorodifluoromethane	120.9129	< 0.5	< 5.0E-04	< 1.78E-04	< 0.5	< 5.0E-04	< 1.78E-04	< 0.5	< 5.0E-04	< 1.81E-04	< 0.50	< 5.0E-04	< 1.79E-04
<i>Chloromethane</i>	50.4872	<b>0.67</b>	<b>6.7E-04</b>	<b>9.96E-05</b>	<b>0.51</b>	<b>5.1E-04</b>	<b>7.58E-05</b>	<b>0.56</b>	<b>5.6E-04</b>	<b>8.47E-05</b>	<b>0.58</b>	<b>5.8E-04</b>	<b>8.67E-05</b>
Freon 114	170.92	< 0.5	< 5.0E-04	< 2.52E-04	< 0.5	< 5.0E-04	< 2.52E-04	< 0.5	< 5.0E-04	< 2.56E-04	< 0.50	< 5.0E-04	< 2.53E-04
Vinyl chloride	62.50	< 0.5	< 5.0E-04	< 9.20E-05	< 0.5	< 5.0E-04	< 9.20E-05	< 0.5	< 5.0E-04	< 9.36E-05	< 0.50	< 5.0E-04	< 9.25E-05
1,3-Butadiene	54.0904	< 0.5	< 5.0E-04	< 7.96E-05	< 0.5	< 5.0E-04	< 7.96E-05	< 0.5	< 5.0E-04	< 8.10E-05	< 0.50	< 5.0E-04	< 8.01E-05
Bromomethane	94.94	< 0.5	< 5.0E-04	< 1.40E-04	< 0.5	< 5.0E-04	< 1.40E-04	< 0.5	< 5.0E-04	< 1.42E-04	< 0.50	< 5.0E-04	< 1.41E-04
Chloroethane	64.51	< 0.5	< 5.0E-04	< 9.50E-05	< 0.5	< 5.0E-04	< 9.50E-05	< 0.5	< 5.0E-04	< 9.66E-05	< 0.50	< 5.0E-04	< 9.55E-05
Freon 11	137.3672	< 0.5	< 5.0E-04	< 2.02E-04	< 0.5	< 5.0E-04	< 2.02E-04	< 0.5	< 5.0E-04	< 2.06E-04	< 0.50	< 5.0E-04	< 2.03E-04
Freon 113	187.38	< 0.5	< 5.0E-04	< 2.76E-04	< 0.5	< 5.0E-04	< 2.76E-04	< 0.5	< 5.0E-04	< 2.81E-04	< 0.50	< 5.0E-04	< 2.77E-04
1,1-Dichloroethene	96.9427	< 0.5	< 5.0E-04	< 1.43E-04	< 0.5	< 5.0E-04	< 1.43E-04	< 0.5	< 5.0E-04	< 1.45E-04	< 0.50	< 5.0E-04	< 1.44E-04
Acetone	58.08	<b>54</b>	<b>5.4E-02</b>	<b>9.23E-03</b>	<b>25</b>	<b>2.5E-02</b>	<b>4.27E-03</b>	<b>22</b>	<b>2.2E-02</b>	<b>3.83E-03</b>	<b>33.67</b>	<b>3.4E-02</b>	<b>5.78E-03</b>
Carbon disulfide	76.143	< 0.5	< 5.0E-04	< 1.12E-04	< 0.5	< 5.0E-04	< 1.12E-04	< 0.5	< 5.0E-04	< 1.14E-04	< 0.50	< 5.0E-04	< 1.13E-04
Methylene chloride	84.9320	< 0.5	< 5.0E-04	< 1.25E-04	< 0.5	< 5.0E-04	< 1.25E-04	< 0.5	< 5.0E-04	< 1.27E-04	< 0.50	< 5.0E-04	< 1.26E-04
trans-1,2-Dichloroethene	96.9427	< 0.5	< 5.0E-04	< 1.43E-04	< 0.5	< 5.0E-04	< 1.43E-04	< 0.5	< 5.0E-04	< 1.45E-04	< 0.50	< 5.0E-04	< 1.44E-04
Methyl t-butyl ether	88.1482	< 0.5	< 5.0E-04	< 1.30E-04	< 0.5	< 5.0E-04	< 1.30E-04	< 0.5	< 5.0E-04	< 1.32E-04	< 0.50	< 5.0E-04	< 1.31E-04
Vinyl acetate	86.0892	< 0.5	< 5.0E-04	< 1.27E-04	< 0.5	< 5.0E-04	< 1.27E-04	< 0.5	< 5.0E-04	< 1.29E-04	< 0.50	< 5.0E-04	< 1.27E-04
2-Butanone	72.1057	<b>1.1</b>	<b>1.1E-03</b>	<b>2.34E-04</b>	<b>0.69</b>	<b>6.9E-04</b>	<b>1.46E-04</b>	<b>0.87</b>	<b>8.7E-04</b>	<b>1.88E-04</b>	<b>0.89</b>	<b>8.9E-04</b>	<b>1.89E-04</b>
cis-1,2-Dichloroethene	96.9427	< 0.5	< 5.0E-04	< 1.43E-04	< 0.5	< 5.0E-04	< 1.43E-04	< 0.5	< 5.0E-04	< 1.45E-04	< 0.50	< 5.0E-04	< 1.44E-04
1,1-Dichloroethane	98.9586	< 0.5	< 5.0E-04	< 1.46E-04	< 0.5	< 5.0E-04	< 1.46E-04	< 0.5	< 5.0E-04	< 1.48E-04	< 0.50	< 5.0E-04	< 1.47E-04
Ethyl acetate	88.1051	< 1.0	< 1.0E-03	< 2.59E-04	< 1.0	< 1.0E-03	< 2.59E-04	< 1.0	< 1.0E-03	< 2.64E-04	< 1.00	< 1.0E-03	< 2.61E-04
Hexane	86.1754	<b>32</b>	<b>3.2E-02</b>	<b>8.12E-03</b>	<b>13</b>	<b>1.3E-02</b>	<b>3.30E-03</b>	<b>8.3</b>	<b>8.3E-03</b>	<b>2.14E-03</b>	<b>17.77</b>	<b>1.8E-02</b>	<b>4.52E-03</b>
Chloroform	119.3767	< 0.5	< 5.0E-04	< 1.76E-04	< 0.5	< 5.0E-04	< 1.76E-04	< 0.5	< 5.0E-04	< 1.79E-04	< 0.50	< 5.0E-04	< 1.77E-04
Tetrahydrofuran	72.1057	< 0.5	< 5.0E-04	< 1.06E-04	< 0.5	< 5.0E-04	< 1.06E-04	< 0.5	< 5.0E-04	< 1.08E-04	< 0.50	< 5.0E-04	< 1.07E-04
1,2-Dichloroethane	98.9586	< 0.5	< 5.0E-04	< 1.46E-04	< 0.5	< 5.0E-04	< 1.46E-04	< 0.5	< 5.0E-04	< 1.48E-04	< 0.50	< 5.0E-04	< 1.47E-04
1,1,1-Trichloroethane	133.4033	< 0.5	< 5.0E-04	< 1.96E-04	< 0.5	< 5.0E-04	< 1.96E-04	< 0.5	< 5.0E-04	< 2.00E-04	< 0.50	< 5.0E-04	< 1.98E-04
Carbon tetrachloride	153.8215	< 0.5	< 5.0E-04	< 2.26E-04	< 0.5	< 5.0E-04	< 2.26E-04	< 0.5	< 5.0E-04	< 2.30E-04	< 0.50	< 5.0E-04	< 2.28E-04
Benzene	78.1118	<b>9.5</b>	<b>9.5E-03</b>	<b>2.18E-03</b>	<b>4.8</b>	<b>4.8E-03</b>	<b>1.10E-03</b>	<b>3.8</b>	<b>3.8E-03</b>	<b>8.89E-04</b>	<b>6.03</b>	<b>6.0E-03</b>	<b>1.39E-03</b>
Cyclohexane	84.1595	< 0.5	< 5.0E-04	< 1.24E-04	< 0.5	< 5.0E-04	< 1.24E-04	< 0.5	< 5.0E-04	< 1.26E-04	< 0.50	< 5.0E-04	< 1.25E-04
Trichloroethene	131.3874	< 0.5	< 5.0E-04	< 1.93E-04	< 0.5	< 5.0E-04	< 1.93E-04	< 0.5	< 5.0E-04	< 1.97E-04	< 0.50	< 5.0E-04	< 1.95E-04
1,2-Dichloropropane	112.9851	< 0.5	< 5.0E-04	< 1.66E-04	< 0.5	< 5.0E-04	< 1.66E-04	< 0.5	< 5.0E-04	< 1.69E-04	< 0.50	< 5.0E-04	< 1.67E-04
Bromodichloromethane	163.8228	< 0.5	< 5.0E-04	< 2.41E-04	< 0.5	< 5.0E-04	< 2.41E-04	< 0.5	< 5.0E-04	< 2.45E-04	< 0.50	< 5.0E-04	< 2.43E-04
Heptane	100.2019	<b>3.6</b>	<b>3.6E-03</b>	<b>1.06E-03</b>	<b>2.3</b>	<b>2.3E-03</b>	<b>6.79E-04</b>	<b>1.5</b>	<b>1.5E-03</b>	<b>4.50E-04</b>	<b>2.47</b>	<b>2.5E-03</b>	<b>7.30E-04</b>
cis-1,3-Dichloropropene	110.9693	< 0.5	< 5.0E-04	< 1.63E-04	< 0.5	< 5.0E-04	< 1.63E-04	< 0.5	< 5.0E-04	< 1.66E-04	< 0.50	< 5.0E-04	< 1.64E-04
4-Methyl-2-pentanone	100.1589	< 0.5	< 5.0E-04	< 1.47E-04	< 0.5	< 5.0E-04	< 1.47E-04	< 0.5	< 5.0E-04	< 1.50E-04	< 0.50	< 5.0E-04	< 1.48E-04
trans-1,3-Dichloropropene	110.9693	< 0.5	< 5.0E-04	< 1.63E-04	< 0.5	< 5.0E-04	< 1.63E-04	< 0.5	< 5.0E-04	< 1.66E-04	< 0.50	< 5.0E-04	< 1.64E-04
1,1,2-Trichloroethane	133.4033	< 0.5	< 5.0E-04	< 1.96E-04	< 0.5	< 5.0E-04	< 1.96E-04	< 0.5	< 5.0E-04	< 2.00E-04	< 0.50	< 5.0E-04	< 1.98E-04
Toluene	92.1384	<b>23.0</b>	<b>2.3E-02</b>	<b>6.24E-03</b>	<b>18</b>	<b>1.8E-02</b>	<b>4.88E-03</b>	<b>15</b>	<b>1.5E-02</b>	<b>4.14E-03</b>	<b>18.67</b>	<b>1.9E-02</b>	<b>5.09E-03</b>
2-Hexanone	100.1589	< 1.0	< 1.0E-03	< 2.95E-04	< 1.0	< 1.0E-03	< 2.95E-04	< 1.0	< 1.0E-03	< 3.00E-04	< 1.00	< 1.0E-03	< 2.97E-04
Tetrachloroethene	163.833	< 0.5	< 5.0E-04	< 2.44E-04	< 0.5	< 5.0E-04	< 2.44E-04	< 0.5	< 5.0E-04	< 2.48E-04	< 0.50	< 5.0E-04	< 2.46E-04
Dibromochloromethane	208.279	< 0.5	< 5.0E-04	< 3.07E-04	< 0.5	< 5.0E-04	< 3.07E-04	< 0.5	< 5.0E-04	< 3.12E-04	< 0.50	< 5.0E-04	< 3.08E-04
1,2-Dibromoethane	187.861	< 0.5	< 5.0E-04	< 2.77E-04	< 0.5	< 5.0E-04	< 2.77E-04	< 0.5	< 5.0E-04	< 2.81E-04	< 0.50	< 5.0E-04	< 2.78E-04
Chlorobenzene	112.5566	< 0.5	< 5.0E-04	< 1.66E-04	< 0.5	< 5.0E-04	< 1.66E-04	< 0.5	< 5.0E-04	< 1.69E-04	< 0.50	< 5.0E-04	< 1.67E-04
Ethyl benzene	106.1650	<b>1.00</b>	<b>1.0E-03</b>	<b>3.13E-04</b>	<b>0.97</b>	<b>9.7E-04</b>	<b>3.03E-04</b>	<b>0.91</b>	<b>9.1E-04</b>	<b>2.89E-04</b>	<b>0.96</b>	<b>9.6E-04</b>	<b>3.02E-04</b>
m,p-Xylene	106.1650	<b>3.2</b>	<b>3.2E-03</b>	<b>1.00E-03</b>	<b>2.7</b>	<b>2.7E-03</b>	<b>8.44E-04</b>	<b>2.9</b>	<b>2.9E-03</b>	<b>9.22E-04</b>	<b>2.93</b>	<b>2.9E-03</b>	<b>9.22E-04</b>
o-Xylene	106.1650	<b>1.1</b>	<b>1.1E-03</b>	<b>3.44E-04</b>	<b>0.94</b>	<b>9.4E-04</b>	<b>2.94E-04</b>	<b>1.0</b>	<b>1.0E-03</b>	<b>3.18E-04</b>	<b>1.01</b>	<b>1.0E-03</b>	<b>3.19E-04</b>
Styrene	104.1491	< 1.0	< 1.0E-03	< 3.07E-04	< 1.0	< 1.0E-03	< 3.07E-04	< 1.0	< 1.0E-03	< 3.12E-04	< 1.00	< 1.0E-03	< 3.08E-04
Bromoform	252.731	< 1.0	< 1.0E-03	< 7.44E-04	< 1.0	< 1.0E-03	< 7.44E-04	< 1.0	< 1.0E-03	< 7.57E-04	< 1.00	< 1.0E-03	< 7.48E-04
1,1,2,2-Tetrachloroethane	167.8481	< 0.5	< 5.0E-04	< 2.47E-04	< 0.5	< 5.0E-04	< 2.47E-04	< 0.5	< 5.0E-04	< 2.51E-04	< 0.50	< 5.0E-04	< 2.49E-04
4-Ethyl toluene	120.1916	< 1.0	< 1.0E-03	< 3.54E-04	< 1.0	< 1.0E-03	< 3.54E-04	< 1.0	< 1.0E-03	< 3.60E-04	< 1.00	< 1.0E-03	< 3.56E-04
1,3,5-Trimethylbenzene	120.1916	< 1.0	< 1.0E-03	< 3.54E-04	< 1.0	< 1.0E-03	< 3.54E-04	< 1.0	< 1.0E-03	< 3.60E-04	< 1.00	< 1.0E-03	< 3.56E-04
1,2,4-Trimethylbenzene	120.195	< 1.0	< 1.0E-03	< 3.54E-04	< 1.0	< 1.0E-03	< 3.54E-04	< 1.0	< 1.0E-03	< 3.60E-04	< 1.00	< 1.0E-03	< 3.56E-04
1,3-Dichlorobenzene	147.0014	< 1.0	< 1.0E-03	< 4.33E-04	< 1.0	< 1.0E-03	< 4.33E-04	< 1.0	< 1.0E-03	< 4.40E-04	< 1.00	< 1.0E-03	< 4.35E-04
1,4-Dichlorobenzene	147.0014	< 1.0	< 1.0E-03	< 4.33E-04	< 1.0	< 1.0E-03	< 4.33E-04	< 1.0	< 1.0E-03	< 4.40E-04	< 1.00	< 1.0E-03	< 4.35E-04
Benzyl chloride	126.5832	< 1.0	< 1.0E-03	< 3.73E-04	< 1.0	< 1.0E-03	< 3.73E-04	< 1.0	< 1.0E-03	< 3.79E-04	< 1.00	< 1.0E-03	< 3.75E-04
1,2-Dichlorobenzene	147.0014	< 1.0	< 1.0E-03	< 4.33E-04	< 1.0	< 1.0E-03	< 4.33E-04	< 1.0	< 1.0E-03	< 4.40E-04	< 1.00	< 1.0E-03	

Hollingsworth & Vose  
 Corvallis, OR  
 CFU 115 Tentatively Identified Compounds (TIC)

Run Number	1	2	3
Sample Collection Date	12/14/2022	12/14/2022	12/14/2022
Volumetric Flow Rate measured by Bison (dscfm)	18,896	18,897	19,230

Analyte	Molecular Weight g/mol	CFU 115-1			CFU 115-2			CFU 115-3			CF		
		ppb	ppm	lb/hr	ppb	ppm	lb/hr	ppb	ppm	lb/hr	ppb	ppm	lb/hr
Propane	44.097	24	2.4E-02	3.12E-03	20	2.0E-02	2.60E-03	25	2.5E-02	3.30E-03	23.00	2.3E-02	3.01E-03
Isobutane	58.124	18	1.8E-02	3.08E-03	12	1.2E-02	2.05E-03	12	1.2E-02	2.09E-03	14.00	1.4E-02	2.41E-03
Butane	58.12	18	1.8E-02	3.08E-03	10	1.0E-02	1.71E-03	8.6	8.6E-03	1.50E-03	12.20	1.2E-02	2.10E-03
Pentane	72.150	34	3.4E-02	7.22E-03	15	1.5E-02	3.19E-03	11	1.1E-02	2.38E-03	20.00	2.0E-02	4.26E-03
Pentane, 2-methyl-	86.175	18	1.8E-02	4.57E-03	7.7	7.7E-03	1.95E-03	5.5	5.5E-03	1.42E-03	10.40	1.0E-02	2.65E-03
Pentane, 3-methyl-	86.175	6.5	6.5E-03	1.65E-03							6.50	6.5E-03	1.65E-03
Pentane, 2,4-dimethyl-	100.20	16	1.6E-02	4.72E-03	6.6	6.6E-03	1.95E-03	4.8	4.8E-03	1.44E-03	9.13	9.1E-03	2.70E-03
Pentane, 2,3-dimethyl-	100.20	14	1.4E-02	4.13E-03	6.5	6.5E-03	1.92E-03	4.5	4.5E-03	1.35E-03	8.33	8.3E-03	2.47E-03
Butane, 2,2,3,3-tetramethyl-	114.2285	14	1.4E-02	4.71E-03	6.8			4.9	4.9E-03	1.68E-03	8.57	9.5E-03	3.19E-03
C6 Hydrocarbon*	86.1754		0.0E+00	0.00E+00	2.9			2.1	2.1E-03		2.50	1.1E-03	0.00E+00
Hexane, 2-methyl-	100.205	5.4	5.4E-03	1.59E-03	2.7	2.7E-03	7.97E-04				4.05	4.1E-03	1.19E-03

Note: Concentrations listed for all TICs are estimated values.

\* Molecular weight used is the molecular weight of hexane

ALS Lab data identified an unknown compound in the amount of 2 ppb in the sample for CFU 115, run 3.





Hollingsworth & Vose  
 Corvallis, OR  
 CFU 115 Tentatively Identified Compounds (TIC)

Run Number	4	5	6
Sample Collection Date	12/14/2022	12/14/2022	12/14/2022
Glass Production Rate Supplied by H&V (lb/hr)	63.0	63.0	63.0
Volumetric Flow Rate measured by Bison (dscfm)	19,219	19,187	18,996

Analyte	Molecular Weight g/mol	CFU 115-4				CFU 115-5				CFU 115-6				CFU 115 Averages			
		ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass
Propane	44.097		0.0E+00	0.00E+00	0.00E+00	34	3.4E-02	4.48E-03	1.42E-01	30	3.0E-02	3.92E-03	1.24E-01	32	2.1E-02	2.80E-03	8.89E-02
Isobutane	58.124		0.0E+00	0.00E+00	0.00E+00	28	2.8E-02	4.87E-03	1.54E-01	29	2.9E-02	4.99E-03	1.58E-01	29	1.9E-02	3.28E-03	1.04E-01
Butane	58.12		0.0E+00	0.00E+00	0.00E+00	26	2.6E-02	4.52E-03	1.43E-01	22	2.2E-02	3.78E-03	1.20E-01	24	1.6E-02	2.77E-03	8.78E-02
Butane, 2-Methyl	72.1488	11	1.1E-02	2.38E-03	7.54E-02	37	3.7E-02	7.98E-03	2.53E-01	23	2.3E-02	4.91E-03	1.56E-01	24	2.4E-02	5.09E-03	1.62E-01
Butane, 2,3-dimethyl	86.1754		0.0E+00	0.00E+00	0.00E+00	19	1.9E-02	4.89E-03	1.55E-01	12	1.2E-02	3.06E-03	9.72E-02	16	1.0E-02	2.65E-03	8.42E-02
Pentane	72.150	19	1.9E-02	4.10E-03	1.30E-01	73	7.3E-02	1.57E-02	5.00E-01	45	4.5E-02	9.61E-03	3.05E-01	46	4.6E-02	9.82E-03	3.12E-01
Pentane, 2-methyl-	86.175	8.8	8.8E-03	2.27E-03	7.21E-02	42	4.2E-02	1.08E-02	3.43E-01	25	2.5E-02	6.38E-03	2.02E-01	25	2.5E-02	6.49E-03	2.06E-01
Pentane, 2,4-dimethyl-	100.20	6.4	6.4E-03	1.92E-03	6.10E-02	44	4.4E-02	1.32E-02	4.18E-01	40	4.0E-02	1.19E-02	3.77E-01	30	3.0E-02	8.99E-03	2.85E-01
Pentane, 2,3-dimethyl-	100.20	31	3.1E-02	9.30E-03	2.95E-01	31	3.1E-02	9.29E-03	2.95E-01	32	3.2E-02	9.49E-03	3.01E-01	31	3.1E-02	9.36E-03	2.97E-01
Hexane, 2,2-dimethyl-	114.2285		0.0E+00	0.00E+00	0.00E+00	39	3.9E-02	1.33E-02	4.23E-01					39	2.0E-02	6.66E-03	2.11E-01
Butane, 2,2,3,3-tetramethyl-	114.2285	40	4.0E-02	1.37E-02	4.34E-01					53	5.3E-02	1.79E-02	5.69E-01	47	4.7E-02	1.58E-02	5.02E-01
Disulfide, dimethyl	94.1990	19	1.9E-02	5.36E-03	1.70E-01									19	1.9E-02	5.36E-03	1.70E-01
O-Cymene	134.218	41	4.1E-02	1.65E-02	5.23E-01									41	4.1E-02	1.65E-02	5.23E-01

Note: Concentrations listed for all TICs are estimated values.

**Bison Engineering, Inc.**  
**Gaseous Testing Summary**

Client: **Hollingsworth & Vose**  
 Facility: **Glass Plant 2**  
 Location: **Corvallis, OR**

Source: **CFU 115**  
 Test Date: **December 14, 2022**

Environmental Conditions / Test Notes: 34 °F and Partly Sunny

Run	1	2	3	Average
Date	12/14/2022	12/14/2022	12/14/2022	
Run Start Time	8:00	9:10	10:20	
Run End Time	8:59	10:09	11:19	
Duration, min.	60	60	60	
Stack Diameter, in.	36.00	36.00	36.00	
Stack Area, sq.ft.	7.069	7.069	7.069	
Barometric Pressure, "Hg	30.15	30.15	30.15	30.15
Static Pressure, "H <sub>2</sub> O	-0.74	-0.74	-0.74	-0.74
Stack Temperature, °F	269	271	270	270
CO <sub>2</sub> , %vd	0.65	0.63	0.63	0.64
O <sub>2</sub> , %vd	20.06	20.07	20.05	20.06
H <sub>2</sub> O, %v	1.64	1.73	1.71	1.69
Wet Molecular Weight, lb/lb-mole	28.73	28.71	28.71	28.72
Velocity, FPS	62.15	62.39	63.42	62.65
WSCFM	19,211	19,230	19,565	19,335
DSCFM	18,896	18,897	19,230	19,008

Note: Negative concentrations are reported as zero.

**Bison Engineering, Inc.**  
**Gaseous Testing Summary**

Client: **Hollingsworth & Vose**  
 Facility: **Glass Plant 2**  
 Location: **Corvallis, OR**

Source: **CFU 115 - Round 2**  
 Test Date: **December 14, 2022**

Environmental Conditions / Test Notes: 34 °F and Partly Sunny

Run		4	5	6	Average
Date		12/14/2022	12/14/2022	12/14/2022	
Run Start Time		13:05	14:15	15:25	
Run End Time		14:04	15:14	16:24	
Duration, min.		60	60	60	
Stack Diameter, in.		36.00	36.00	36.00	
Stack Area, sq.ft.		7.069	7.069	7.069	
Barometric Pressure, "Hg		30.15	30.15	30.15	30.15
Static Pressure, "H <sub>2</sub> O		-0.72	-0.72	-0.72	-0.72
Stack Temperature, °F		272	269	272	271
CO <sub>2</sub> , %vd		0.64	0.64	0.63	0.63
O <sub>2</sub> , %vd		20.04	20.04	20.04	20.04
H <sub>2</sub> O, %v		1.96	2.08	1.78	1.94
Wet Molecular Weight, lb/lb-mole		28.69	28.67	28.71	28.69
Velocity, FPS		63.73	63.41	62.82	63.32
WSCFM		19,603	19,595	19,341	19,513
DSCFM		19,219	19,187	18,996	19,134
Production Data, Total Flameblown	lb/hr	63.0	63.0	63.0	63.0
Production Data, L4R3	lb/hr	31.5	31.5	31.5	31.5
Production Data, L4R4	lb/hr	31.5	31.5	31.5	31.5

Note: Negative concentrations are reported as zero.

**Bison Engineering, Inc.**  
**Pre-Test Traverse**

**Client:** Hollingsworth & Vose  
**Location:** Corvallis, OR  
**Source:** CFU 115

**Stack Temp:** NA °F

Traverse Point	Velocity ΔP ("H <sub>2</sub> O)	Null Angle
1	NA	2
2	NA	1
3	NA	6
4	NA	4
5	NA	5
6	NA	3
7	NA	0
8	NA	0
9	NA	0
10	NA	1
11	NA	2
12	NA	5
13	NA	3
14	NA	9
15	NA	8
16	NA	2

Average: NA 3  
 Flow is found to be: Non-cyclonic

No nozzle was needed for flow measurements, therefore no pre-velocity measurements or stack temperature was recorded prior to testing.

**Bison Engineering, Inc.**  
**EPA Method 1**  
**Stack Parameters and Traverse Points**

**Client:** Hollingsworth & Vose  
**Location:** Corvallis, OR  
**Source:** CFU 115  
**Facility:** Glass Plant 2

Type of Testing: V V for Velocity/Nonparticulate)  
 Type of Duct: C (C for circular; R for rectangular)

Number of ports available: 2  
 Number of ports to be used: 2  
 Port diameter: 5 inches  
 Sampling location height (approx.): 40.00 feet  
 Stack height (approx.): 8.00 feet

Circular ID (Rectangular Depth): 36.00 inches  
 Port depth and/or wall thickness: 5.00 inches  
 Stack width (Rectangular only): inches

Equivalent Diameter  
 If rectangular =  $\frac{2 * \text{Depth} * \text{Width}}{\text{Depth} + \text{Width}} = 36.00$  inches (If circular = duct ID)

Stack/duct area = 7.069 sq. feet 1017.9 sq. inches


Sample Port Location:	Downstream flow disturbance from process B	Upstream flow disturbance toward exit A
Number of Inches:	134.00	45.00
Number of Diameters:	3.72	1.25

Minimum Number of Traverse Points: 16

Traverse points less than 1.0 inch from the stack wall are relocated to a distance of 1.0 inch.

Points	% of diameter	Distance from inside wall (in.)	Distance including port (in.)
1	3.2	1.15	6 1/8
2	10.5	3.78	8 3/4
3	19.4	6.98	12
4	32.3	11.63	16 5/8
5	67.7	24.37	29 3/8
6	80.6	29.02	34
7	89.5	32.22	37 1/4
8	96.8	34.85	39 7/8

**Reference Diagram**



Drawing NOT to scale and NOT an accurate representation of stack.

**Bison Engineering, Inc.**

**Method 2**

**Stack Gas Velocity and Volumetric Flow Rate**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 2  
**Location:** Corvallis, OR

**Source:** CFU 115  
**Test Date:** 12/14/22

Molecular Weight		
Choose One by "x" below		
Measured	Ambient	Combustion
x		

Pitot ID	4E
----------	----

Leak Checks:	Run 1		Run 2		Run 3	
	Pre	Post	Pre	Post	Pre	Post
<b>Pitot</b>	x	x	x	x	x	x
<b>Barometric Pressure ("Hg)</b>	30.15		30.15		30.15	

Traverse	Sample Point	Run 1		Run 2		Run 3	
		Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)
A	1	1.20	268	0.99	270	0.98	271
	2	1.10	269	0.94	270	0.84	272
	3	0.83	269	0.84	271	0.95	271
	4	0.97	270	0.87	271	1.00	271
	5	0.94	270	0.92	271	1.10	270
	6	0.96	270	0.87	272	0.90	270
	7	0.99	271	0.97	271	0.92	272
	8	0.88	270	0.97	269	0.85	270
B	1	1.00	265	0.95	268	1.10	270
	2	0.98	266	0.98	270	0.90	269
	3	0.82	268	0.96	271	0.92	269
	4	0.82	269	0.88	272	0.95	268
	5	0.82	269	0.84	272	0.96	269
	6	0.79	269	0.83	272	0.82	269
	7	0.77	269	0.76	271	0.81	269
	8	0.47	265	0.74	271	0.80	270

Method 2 -Flow Calculations							
Static Pressure, "H <sub>2</sub> O			-0.74		-0.74		-0.74
Pitot tube cp			0.84		0.84		0.84
Stack Area, ft <sup>3</sup>			7.069		7.069		7.069
H <sub>2</sub> O, %v			1.64		1.73		1.71
Average √ΔP			0.943		0.945		0.961
Average Absolute Temp. (°R)			728.2		730.4		729.7
Stack Pressure (in. Hg)			30.10		30.10		30.10
Stack Velocity (ft/sec)			62.15		62.39		63.42
Actual Flow Rate (acfm)			26,357		26,462		26,897
Standard Flow Rate (wscf/hr)			1,152,665		1,153,771		1,173,887
Dry Standard Flow Rate (dscf/hr)			1,133,761		1,133,811		1,153,814
Dry Standard Flow Rate (dscfm)			18,896		18,897		19,230

	O <sub>2</sub>	CO <sub>2</sub>	Calculated N <sub>2</sub>
Run 1	20.06	0.65	79.29
Run 2	20.07	0.63	79.30
Run 3	20.05	0.63	79.32

	Molecular Weight (lb/lb-mole)					
	Calculated		Ambient		Combustion	
Run 1	M <sub>d</sub>	28.91	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.73	M <sub>s</sub>		M <sub>s</sub>	
Run 2	M <sub>d</sub>	28.90	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.71	M <sub>s</sub>		M <sub>s</sub>	
Run 3	M <sub>d</sub>	28.90	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.71	M <sub>s</sub>		M <sub>s</sub>	

**Bison Engineering, Inc.**

**Method 2**

**Stack Gas Velocity and Volumetric Flow Rate**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 2  
**Location:** Corvallis, OR

**Source:** CFU 115 - Round 2  
**Test Date:** 12/14/22

Molecular Weight		
Choose One by "x" below		
Measured	Ambient	Combustion
x		

Pitot ID	4E
----------	----

Leak Checks:	Run 4		Run 5		Run 6	
	Pre	Post	Pre	Post	Pre	Post
<b>Pitot</b>	x	x	x	x	x	x
<b>Barometric Pressure ("Hg)</b>	30.15		30.15		30.15	

Traverse	Sample Point	Run 4		Run 5		Run 6	
		Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)
A	1	1.10	272	1.00	265	1.10	270
	2	1.10	273	1.00	267	1.10	271
	3	0.95	273	0.99	268	0.94	272
	4	0.95	274	0.98	269	0.90	272
	5	0.98	274	0.90	270	0.97	272
	6	0.92	275	0.88	271	1.00	272
	7	0.91	274	0.93	271	1.00	271
	8	0.90	274	0.94	270	1.10	270
B	1	1.10	273	1.10	266	0.88	271
	2	0.94	272	0.99	267	0.92	272
	3	0.86	271	0.92	268	0.96	272
	4	0.84	270	0.83	269	0.96	273
	5	0.83	271	0.81	270	0.89	272
	6	0.85	271	0.82	270	0.82	272
	7	0.84	271	0.90	270	0.71	272
	8	0.83	268	0.82	271	0.39	271

Method 2 -Flow Calculations							
Static Pressure, "H <sub>2</sub> O			-0.72				-0.72
Pitot tube cp			0.84				0.84
Stack Area, ft <sup>3</sup>			7.069				7.069
H <sub>2</sub> O, %v			1.96				1.78
Average √ΔP			0.964				0.951
Average Absolute Temp. (°R)			731.9				731.2
Stack Pressure (in. Hg)			30.10				30.10
Stack Velocity (ft/sec)			63.73				62.82
Actual Flow Rate (acfm)			27,031				26,643
Standard Flow Rate (wscf/hr)			1,176,191				1,160,435
Dry Standard Flow Rate (dscf/hr)			1,153,138				1,139,779
Dry Standard Flow Rate (dscfm)			19,219				18,996

	O <sub>2</sub>	CO <sub>2</sub>	Calculated N <sub>2</sub>
Run 1	20.04	0.64	79.32
Run 2	20.04	0.64	79.32
Run 3	20.04	0.63	79.33

	Molecular Weight (lb/lb-mole)					
	Calculated		Ambient		Combustion	
Run 1	M <sub>d</sub>	28.9	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.69	M <sub>s</sub>		M <sub>s</sub>	
Run 2	M <sub>d</sub>	28.90	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.67	M <sub>s</sub>		M <sub>s</sub>	
Run 3	M <sub>d</sub>	28.90	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.71	M <sub>s</sub>		M <sub>s</sub>	



**Bison Engineering, Inc.**  
**Moisture Field Data**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 2  
**Location:** Corvallis, OR  
**Source:** CFU 115  
**Test date:** 12/14/2022

**Meterbox ID:** Box 11  
**Meter "Y"-Factor** 0.9690

Moisture Field Data Entry			
Run 1			
Leak Checks:		Pre-test	Post-test
Train leak rate, dcf		0.000	0.000
Leak check vacuum, "Hg		15	16
Start Time		8:00	
End Time		9:00	
Bp, "Hg		30.15	

Minutes	Meter Volume	Meter °F	Condenser °F	Delta H
	591.315			
5	594.980	36	40	1.800
10	598.730	36	44	1.800
15	602.580	37	48	1.800
20	606.240	37	50	1.800
25	610.010	38	52	1.800
30	613.910	39	54	1.800
35	617.620	40	55	1.800
40	621.430	40	56	1.800
45	625.210	41	56	1.800
50	628.850	41	58	1.800
55	632.340	42	60	1.800
60	636.560	42	60	1.800

Impinger gain by weight (g):			
#	Initial	Final	Gain
1	807.1	811.7	4.6
2	776.1	778.2	2.1
3	700.0	700.4	0.4
Silica Gel	919	928.5	9.5
Impinger Totals:	3,202.2	3,218.8	7.1

Moisture Field Data Entry			
Run 2			
Leak Checks:		Pre-test	Post-test
Train leak rate, dcf		0.000	0.000
Leak check vacuum, "Hg		15	8
Start Time		9:10	
End Time		10:10	
Bp, "Hg		30.15	

Meter Volume	Meter °F	Condenser °F	Delta H
639.175			
643.015	43	45	1.800
646.470	43	45	1.800
650.200	44	50	1.800
654.120	44	51	1.800
657.630	44	52	1.800
661.160	44	53	1.800
664.950	44	51	1.800
668.850	44	51	1.800
672.210	44	51	1.800
675.880	44	52	1.800
679.520	43	51	1.800
683.325	43	51	1.800

Impinger gain by weight (g):			
#	Initial	Final	Gain
1	811.7	815.1	3.4
2	780.8	783.6	2.8
3	616.8	617.6	0.8
Silica Gel	913	922.9	9.9
Impinger Totals:	3,122.3	3,139.2	7.0

Moisture Field Data Entry			
Run 3			
Leak Checks:		Pre-test	Post-test
Train leak rate, dcf		0.000	0.000
Leak check vacuum, "Hg		15	7
Start Time		10:20	
End Time		11:20	
Bp, "Hg		30.15	

Meter Volume	Meter °F	Condenser °F	Delta H
683.825			
687.770	43	59	1.800
691.300	43	58	1.800
695.020	43	55	1.800
698.750	43	58	1.800
701.450	43	58	1.800
704.560	43	60	1.800
708.690	43	61	1.800
712.420	44	64	1.800
716.080	44	64	1.800
718.540	44	62	1.800
723.450	45	59	1.800
727.130	45	60	1.800

Impinger gain by weight (g):			
#	Initial	Final	Gain
1	815.1	819.9	4.8
2	778.2	780.2	2.0
3	700.4	700.7	0.3
Silica Gel	928.5	937.8	9.3
Impinger Totals:	3,222.2	3,238.6	7.1

**Bison Engineering, Inc.**  
**Moisture Field Data**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 2  
**Location:** Corvallis, OR  
**Source:** CFU 115 - Round 2  
**Test date:** 12/14/2022

**Meterbox ID:** Box 11  
**Meter "Y"-Factor:** 0.9690

Moisture Field Data Entry				
Run 4				
Leak Checks:		Pre-test	Post-test	
Train leak rate, dcf		0.000	0.000	
Leak check vacuum, "Hg		15	5	
Start Time		13:05		
End Time		14:05		
Bp, "Hg		30.15		
Minutes	Meter Volume	Meter °F	Condenser °F	Delta H
	730.580			
5	734.520	48	59	1.800
10	738.380	49	65	1.800
15	742.120	50	67	1.800
20	745.890	51	66	1.800
25	749.720	51	61	1.800
30	753.520	53	60	1.800
35	758.320	54	57	1.800
40	761.170	54	58	1.800
45	764.850	55	57	1.800
50	768.520	56	58	1.800
55	772.680	57	58	1.800
60	776.495	57	55	1.800
Impinger gain by weight (g):				
#	Initial	Final	Gain	
1	819.9	824.1	4.2	
2	783.6	784.4	0.8	
3	617.6	619.5	1.9	
Silica Gel	922.9	935.7	12.8	
Impinger Totals:	3,144.0	3,163.7	6.9	

Moisture Field Data Entry				
Run 5				
Leak Checks:		Pre-test	Post-test	
Train leak rate, dcf		0.000	0.000	
Leak check vacuum, "Hg		16	6	
Start Time		14:15		
End Time		15:15		
Bp, "Hg		30.15		
Meter Volume	Meter °F	Condenser °F	Delta H	
777.180				
780.060	58	52	1.800	
784.800	58	61	1.800	
788.680	58	66	1.800	
792.280	59	64	1.800	
796.080	59	59	1.800	
799.860	59	56	1.800	
803.790	59	54	1.800	
807.840	60	55	1.800	
811.270	60	55	1.800	
815.120	60	55	1.800	
818.830	60	54	1.800	
822.630	61	53	1.800	
Impinger gain by weight (g):				
#	Initial	Final	Gain	
1	820.1	824.9	4.8	
2	818.5	822.0	3.5	
3	681.1	682.6	1.5	
Silica Gel	854.8	865.4	10.6	
Impinger Totals:	3,174.5	3,194.9	9.8	

Moisture Field Data Entry				
Run 6				
Leak Checks:		Pre-test	Post-test	
Train leak rate, dcf		0.000	0.000	
Leak check vacuum, "Hg		15	7	
Start Time		15:25		
End Time		16:25		
Bp, "Hg		30.15		
Meter Volume	Meter °F	Condenser °F	Delta H	
823.000				
826.730	59	50	1.800	
830.470	52	53	1.800	
834.260	59	58	1.800	
838.070	59	59	1.800	
841.790	59	61	1.800	
845.600	60	62	1.800	
849.570	60	64	1.800	
853.190	60	65	1.800	
857.000	60	65	1.800	
860.830	60	66	1.800	
864.640	60	65	1.800	
868.465	59	65	1.800	
Impinger gain by weight (g):				
#	Initial	Final	Gain	
1	824.9	829.6	4.7	
2	784.4	788.1	3.7	
3	619.5	618.7	-0.8	
Silica Gel	935.7	945.5	9.8	
Impinger Totals:	3,164.5	3,181.9	7.6	

**Bison Engineering, Inc.**  
**Method 4 Moisture Calculations**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 2  
**Location:** Corvallis, OR  
**Source:** CFU 115  
**Test date:** 12/14/2022

Method 4 -Moisture Determination					
Run Number	#	1	2	3	
Start Time	hh:mm	8:00	9:10	10:20	
Meter Box Identification	#	Box 11	Box 11	Box 11	
Meter "Y" Factor	Factor	0.9690	0.9690	0.9690	
Barometric Pressure	in Hg	30.15	30.15	30.15	
Sample Duration	hh:mm	1:00	1:00	1:00	
Average Meter Temperature	Deg F	39.1	43.7	43.6	
Average Condenser Temperature	Deg F	52.8	50.3	59.8	
Average Delta H	in H2O	1.800	1.800	1.800	
Average Meter Pressure	in Hg	30.282	30.282	30.282	
Meter Volume Start	dcf	591.315	639.175	683.825	
Meter Volume End	dcf	636.560	683.325	727.130	
Meter Volume	dcf	45.245	44.150	43.305	
Corrected Meter Volume	dscf	46.945	45.392	44.531	
Impinger Gain	g	7.1	7.0	7.1	
Silica Gel Gain	g	9.5	9.9	9.3	Average
Volume of Condensed Water Vapor	scf	0.783	0.797	0.773	0.784
Moisture Calculation	Bws	0.0164	0.0173	0.0171	0.017
Percent Moisture	Bws%	1.64	1.73	1.71	1.69

**Bison Engineering, Inc.**  
**Method 4 Moisture Calculations**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 2  
**Location:** Corvallis, OR  
**Source:** CFU 115 - Round 2  
**Test date:** 12/14/2022

Method 4 -Moisture Determination					
Run Number	#	4	5	6	
Start Time	hh:mm	13:05	14:15	15:25	
Meter Box Identification	#	Box 11	Box 11	Box 11	
Meter "Y" Factor	Factor	0.9690	0.9690	0.9690	
Barometric Pressure	in Hg	30.15	30.15	30.15	
Sample Duration	hh:mm	1:00	1:00	1:00	
Average Meter Temperature	Deg F	52.9	59.3	58.9	
Average Condenser Temperature	Deg F	60.1	57.0	61.1	
Average Delta H	in H2O	1.800	1.800	1.800	
Average Meter Pressure	in Hg	30.282	30.282	30.282	
Meter Volume Start	dcf	730.580	777.180	823.000	
Meter Volume End	dcf	776.495	822.630	868.465	
Meter Volume	dcf	45.915	45.450	45.465	
Corrected Meter Volume	dscf	46.355	45.326	45.370	
Impinger Gain	g	6.9	9.8	7.6	
Silica Gel Gain	g	12.8	10.6	9.8	Average
Volume of Condensed Water Vapor	scf	0.929	0.962	0.821	0.904
Moisture Calculation	Bws	0.0196	0.0208	0.0178	0.019
Percent Moisture	Bws%	1.96	2.08	1.78	1.94

**Bison Engineering, Inc.**  
**Method 3A Oxygen**  
**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU 115</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 2</b>	Date: <b>December 14, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values				System Drift % of span	Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference Gas
		Analyzer Cal. Response	System Cal Response	Pre test System Cal. Bias		System Cal Response	Post test System Cal. Bias		pass/fail					
				% of span	pass/fail		% of span	pass/fail						
Run 1	zero	-0.04	0.07	0.50	pass	0.07	0.50	pass	0.00	pass				
	upscale	10.03	10.00	-0.14	pass	9.94	-0.41	pass	0.27	pass	21.94	19.83	20.06	10.05
Run 2	zero	-0.04	0.07	0.50	pass	0.05	0.41	pass	0.09	pass				
	upscale	10.03	9.94	-0.41	pass	9.96	-0.32	pass	0.09	pass	21.94	19.81	20.07	10.05
Run 3	zero	-0.04	0.05	0.41	pass	0.04	0.36	pass	0.05	pass				
	upscale	10.03	9.96	-0.32	pass	9.93	-0.46	pass	0.14	pass	21.94	19.80	20.05	10.05
				< 5%*				< 5%*		< 3%*				

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	10.05	21.94
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	-0.04	10.03	22.00
Analyzer Calibration Error	-0.18	-0.09	0.27
Analyzer Calibration Error < 2%*	pass	pass	pass

System Response Time	
29	seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %  
 \*Or < 0.5 % absolute difference

**Bison Engineering, Inc.**  
**Method 3A Oxygen**  
**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU 115 - Round 2</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 2</b>	Date: <b>December 14, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values				System Drift % of span	Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference Gas
		Analyzer Cal. Response	System Cal Response	Pre test		System Cal Response	Post test							
				System Cal. Bias % of span	pass/fail		System Cal. Bias % of span	pass/fail						
Run 4	zero	-0.04	0.04	0.36	pass	0.05	0.41	pass	0.05	pass				
	upscale	10.03	9.93	-0.46	pass	9.95	-0.36	pass	0.09	pass	21.94	19.78	20.04	10.05
Run 5	zero	-0.04	0.05	0.41	pass	0.05	0.41	pass	0.00	pass				
	upscale	10.03	9.95	-0.36	pass	9.94	-0.41	pass	0.05	pass	21.94	19.78	20.04	10.05
Run 6	zero	-0.04	0.05	0.41	pass	0.05	0.41	pass	0.00	pass				
	upscale	10.03	9.94	-0.41	pass	9.96	-0.32	pass	0.09	pass	21.94	19.79	20.04	10.05
				<b>&lt; 5%*</b>		<b>&lt; 5%*</b>		<b>&lt; 3%*</b>						

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	10.05	21.94
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	-0.04	10.03	22.00
Analyzer Calibration Error	-0.18	-0.09	0.27
Analyzer Calibration Error < 2%*	pass	pass	pass

System Response Time	
30	seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %  
 \*Or < 0.5 % absolute difference

**Bison Engineering, Inc.**

**Method 3A CO<sub>2</sub>**

**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU 115</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 2</b>	Date: <b>December 14, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values									
		Analyzer Cal. Response	System Cal Response	Pre test		System Cal Response	Post test		System Drift		Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference Gas	
				% of span	pass/fail		% of span	pass/fail	% of span	pass/fail					
Run 1	zero	0.03	0.03	0.00	pass	0.04	0.05	pass	0.05	pass					
	upscale	9.87	10.05	0.83	pass	9.95	0.37	pass	0.46	pass	21.70	0.69	0.65	9.951	
Run 2	zero	0.03	0.04	0.05	pass	0.05	0.09	pass	0.05	pass					
	upscale	9.87	9.95	0.37	pass	10.06	0.88	pass	0.51	pass	21.70	0.68	0.63	9.951	
Run 3	zero	0.03	0.05	0.09	pass	0.04	0.05	pass	0.05	pass					
	upscale	9.87	10.06	0.88	pass	10.08	0.97	pass	0.09	pass	21.70	0.68	0.63	9.951	
				<b>&lt; 5%*</b>		<b>&lt; 5%*</b>		<b>&lt; 3%*</b>							

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	9.951	21.70
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	0.03	9.87	21.98
Analyzer Calibration Error	0.14	-0.37	1.29
Analyzer Calibration Error < 2% *	pass	pass	pass

System Response Time
30 seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %

\*Or < 0.5 % absolute difference

**Bison Engineering, Inc.**

**Method 3A CO<sub>2</sub>**

**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU 115 - Round 2</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 2</b>	Date: <b>December 14, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values				Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference Gas	
		Analyzer Cal. Response	System Cal Response	Pre test		System Cal Response	Post test		System Drift					
				System Cal. Bias % of span	pass/fail		System Cal. Bias % of span	pass/fail	System Drift % of span					pass/fail
Run 4	zero	0.03	0.04	0.05	pass	0.04	0.05	pass	0.00	pass				
	upscale	9.87	10.08	0.97	pass	9.98	0.51	pass	0.46	pass	21.70	0.68	0.64	9.951
Run 5	zero	0.03	0.04	0.05	pass	0.05	0.09	pass	0.05	pass				
	upscale	9.87	9.98	0.51	pass	9.96	0.41	pass	0.09	pass	21.70	0.68	0.64	9.951
Run 6	zero	0.03	0.05	0.09	pass	0.05	0.09	pass	0.00	pass				
	upscale	9.87	9.96	0.41	pass	10.15	1.29	pass	0.88	pass	21.70	0.68	0.63	9.951
				<b>&lt; 5%*</b>		<b>&lt; 5%*</b>		<b>&lt; 3%*</b>						

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	9.951	21.70
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	0.03	9.87	21.98
Analyzer Calibration Error	0.14	-0.37	1.29
Analyzer Calibration Error < 2% *	pass	pass	pass

System Response Time
28 seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %

\*Or < 0.5 % absolute difference



## Hollingsworth & Vose - Glass Plant 2

### CFU 115

#### Calibrations and Test Runs

Date	Time	O2 [%]	CO2 [%]	Notes
12/14/2022	7:13:52	0.04	0.04	
12/14/2022	7:14:52	-0.02	0.04	
12/14/2022	7:15:52	-0.04	0.03	O2/CO2 Analyzer Zero
12/14/2022	7:16:52	-0.05	0.03	
12/14/2022	7:17:52	-0.06	0.03	
12/14/2022	7:18:52	-0.07	0.02	
12/14/2022	7:19:52	-0.07	0.02	
12/14/2022	7:20:52	-0.08	0.02	
12/14/2022	7:21:52	-0.08	0.02	
12/14/2022	7:22:52	-0.09	0.02	
12/14/2022	7:23:52	-0.09	0.02	
12/14/2022	7:24:52	-0.10	0.01	
12/14/2022	7:25:52	-0.10	0.01	
12/14/2022	7:26:52	-0.10	0.01	
12/14/2022	7:27:52	16.27	16.35	
12/14/2022	7:28:52	22.00	21.98	O2/CO2 Analyzer Span
12/14/2022	7:29:52	18.10	18.06	
12/14/2022	7:30:52	10.05	9.88	
12/14/2022	7:31:52	10.04	9.87	
12/14/2022	7:32:52	10.04	9.87	
12/14/2022	7:33:52	10.04	9.87	
12/14/2022	7:34:52	10.04	9.87	
12/14/2022	7:35:52	10.03	9.87	O2/CO2 Analyzer Mid
12/14/2022	7:36:52	10.03	9.87	
12/14/2022	7:37:52	10.03	9.87	
12/14/2022	7:38:52	10.01	9.59	
12/14/2022	7:39:52	20.50	0.21	
12/14/2022	7:40:52	20.94	0.14	
12/14/2022	7:41:52	20.92	0.15	
12/14/2022	7:42:52	20.07	0.62	
12/14/2022	7:43:52	8.23	0.30	
12/14/2022	7:44:52	0.15	0.04	
12/14/2022	7:45:52	0.07	0.03	O2/CO2 System Zero
12/14/2022	7:46:52	4.38	4.47	
12/14/2022	7:47:52	9.94	9.97	
12/14/2022	7:48:52	10.00	10.05	O2/CO2 System Upscale
12/14/2022	7:49:52	10.00	10.07	
12/14/2022	7:50:52	14.44	5.67	
12/14/2022	7:51:52	19.77	0.76	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 115**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/14/2022	7:52:52	19.82	0.71	
12/14/2022	7:53:52	19.83	0.70	
12/14/2022	7:54:52	19.83	0.70	
12/14/2022	7:55:52	19.84	0.70	
12/14/2022	7:56:52	19.84	0.70	
12/14/2022	7:57:52	19.83	0.70	
12/14/2022	7:58:52	19.83	0.70	
12/14/2022	7:59:52	19.83	0.70	
				<b>CFU 115</b>
12/14/2022	8:00:52	19.82	0.71	<b>Start Run 1</b>
12/14/2022	8:01:52	19.83	0.71	
12/14/2022	8:02:52	19.83	0.71	
12/14/2022	8:03:52	19.83	0.71	
12/14/2022	8:04:52	19.83	0.70	
12/14/2022	8:05:52	19.83	0.71	
12/14/2022	8:06:52	19.82	0.70	
12/14/2022	8:07:52	19.82	0.70	
12/14/2022	8:08:52	19.83	0.70	
12/14/2022	8:09:52	19.83	0.70	
12/14/2022	8:10:52	19.84	0.69	
12/14/2022	8:11:52	19.84	0.69	
12/14/2022	8:12:52	19.84	0.69	
12/14/2022	8:13:52	19.84	0.69	
12/14/2022	8:14:52	19.83	0.68	
12/14/2022	8:15:52	19.84	0.68	
12/14/2022	8:16:52	19.84	0.68	
12/14/2022	8:17:52	19.84	0.68	
12/14/2022	8:18:52	19.83	0.69	
12/14/2022	8:19:52	19.83	0.69	
12/14/2022	8:20:52	19.83	0.69	
12/14/2022	8:21:52	19.83	0.69	
12/14/2022	8:22:52	19.83	0.69	
12/14/2022	8:23:52	19.83	0.69	
12/14/2022	8:24:52	19.83	0.69	
12/14/2022	8:25:52	19.83	0.69	
12/14/2022	8:26:52	19.83	0.69	
12/14/2022	8:27:52	19.83	0.69	
12/14/2022	8:28:52	19.83	0.69	
12/14/2022	8:29:52	19.83	0.69	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 115**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/14/2022	8:30:52	19.82	0.69	
12/14/2022	8:31:52	19.83	0.69	
12/14/2022	8:32:52	19.82	0.69	
12/14/2022	8:33:52	19.82	0.69	
12/14/2022	8:34:52	19.82	0.70	
12/14/2022	8:35:52	19.82	0.69	
12/14/2022	8:36:52	19.82	0.69	
12/14/2022	8:37:52	19.82	0.69	
12/14/2022	8:38:52	19.82	0.69	
12/14/2022	8:39:52	19.82	0.69	
12/14/2022	8:40:52	19.82	0.69	
12/14/2022	8:41:52	19.83	0.68	
12/14/2022	8:42:52	19.83	0.68	
12/14/2022	8:43:52	19.83	0.68	
12/14/2022	8:44:52	19.83	0.68	
12/14/2022	8:45:52	19.83	0.68	
12/14/2022	8:46:52	19.82	0.69	
12/14/2022	8:47:52	19.82	0.69	
12/14/2022	8:48:52	19.82	0.69	
12/14/2022	8:49:52	19.82	0.69	
12/14/2022	8:50:52	19.83	0.69	
12/14/2022	8:51:52	19.83	0.69	
12/14/2022	8:52:52	19.82	0.69	
12/14/2022	8:53:52	19.82	0.70	
12/14/2022	8:54:52	19.82	0.69	
12/14/2022	8:55:52	19.82	0.70	
12/14/2022	8:56:52	19.82	0.69	
12/14/2022	8:57:52	19.82	0.69	
12/14/2022	8:58:52	19.83	0.69	
12/14/2022	8:59:52	19.82	0.69	<b>End Run 1</b>
		<b>19.83</b>	<b>0.69</b>	<b>Average</b>
12/14/2022	9:00:52	19.82	0.69	
12/14/2022	9:01:52	19.82	0.69	
12/14/2022	9:02:52	19.81	0.69	
12/14/2022	9:03:52	19.79	0.71	
12/14/2022	9:04:52	3.42	0.30	
12/14/2022	9:05:52	0.07	0.04	<b>O2/CO2 System Zero</b>
12/14/2022	9:06:52	4.72	4.77	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 115**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/14/2022	9:07:52	9.94	9.95	<b>O2/CO2 System Upscale</b>
12/14/2022	9:08:52	12.34	7.61	
12/14/2022	9:09:52	19.61	0.85	
12/14/2022	9:10:52	19.79	0.71	<b>Start Run 2</b>
12/14/2022	9:11:52	19.80	0.70	
12/14/2022	9:12:52	19.80	0.69	
12/14/2022	9:13:52	19.80	0.69	
12/14/2022	9:14:52	19.81	0.69	
12/14/2022	9:15:52	19.81	0.68	
12/14/2022	9:16:52	19.82	0.69	
12/14/2022	9:17:52	19.82	0.69	
12/14/2022	9:18:52	19.82	0.69	
12/14/2022	9:19:52	19.82	0.69	
12/14/2022	9:20:52	19.82	0.69	
12/14/2022	9:21:52	19.81	0.70	
12/14/2022	9:22:52	19.81	0.70	
12/14/2022	9:23:52	19.81	0.70	
12/14/2022	9:24:52	19.81	0.70	
12/14/2022	9:25:52	19.81	0.69	
12/14/2022	9:26:52	19.81	0.69	
12/14/2022	9:27:52	19.81	0.69	
12/14/2022	9:28:52	19.81	0.69	
12/14/2022	9:29:52	19.81	0.69	
12/14/2022	9:30:52	19.80	0.69	
12/14/2022	9:31:52	19.80	0.68	
12/14/2022	9:32:52	19.81	0.68	
12/14/2022	9:33:52	19.81	0.68	
12/14/2022	9:34:52	19.80	0.68	
12/14/2022	9:35:52	19.81	0.68	
12/14/2022	9:36:52	19.82	0.68	
12/14/2022	9:37:52	19.82	0.68	
12/14/2022	9:38:52	19.82	0.68	
12/14/2022	9:39:52	19.82	0.68	
12/14/2022	9:40:52	19.82	0.68	
12/14/2022	9:41:52	19.82	0.68	
12/14/2022	9:42:52	19.82	0.68	
12/14/2022	9:43:52	19.82	0.69	
12/14/2022	9:44:52	19.81	0.69	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 115**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/14/2022	9:45:52	19.81	0.69	
12/14/2022	9:46:52	19.81	0.69	
12/14/2022	9:47:52	19.81	0.69	
12/14/2022	9:48:52	19.81	0.69	
12/14/2022	9:49:52	19.81	0.69	
12/14/2022	9:50:52	19.81	0.69	
12/14/2022	9:51:52	19.81	0.69	
12/14/2022	9:52:52	19.82	0.68	
12/14/2022	9:53:52	19.82	0.68	
12/14/2022	9:54:52	19.82	0.68	
12/14/2022	9:55:52	19.81	0.68	
12/14/2022	9:56:52	19.81	0.68	
12/14/2022	9:57:52	19.81	0.67	
12/14/2022	9:58:52	19.81	0.67	
12/14/2022	9:59:52	19.81	0.67	
12/14/2022	10:00:52	19.82	0.67	
12/14/2022	10:01:52	19.82	0.67	
12/14/2022	10:02:52	19.81	0.67	
12/14/2022	10:03:52	19.81	0.67	
12/14/2022	10:04:52	19.81	0.68	
12/14/2022	10:05:52	19.82	0.67	
12/14/2022	10:06:52	19.81	0.68	
12/14/2022	10:07:52	19.81	0.68	
12/14/2022	10:08:52	19.81	0.68	
12/14/2022	10:09:52	19.81	0.69	<b>End Run 2</b>
		<b>19.81</b>	<b>0.68</b>	<b>Average</b>
12/14/2022	10:10:52	19.81	0.69	
12/14/2022	10:11:52	10.51	0.57	
12/14/2022	10:12:52	0.14	0.06	
12/14/2022	10:13:52	0.05	0.05	<b>O2/CO2 System Zero</b>
12/14/2022	10:14:52	6.91	7.03	
12/14/2022	10:15:52	9.96	10.06	<b>O2/CO2 System Upscale</b>
12/14/2022	10:16:52	10.23	9.78	
12/14/2022	10:17:52	18.82	1.51	
12/14/2022	10:18:52	19.78	0.71	
12/14/2022	10:19:52	19.79	0.70	
12/14/2022	10:20:52	19.79	0.69	<b>Start Run 3</b>

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 115**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/14/2022	10:21:52	19.80	0.68	
12/14/2022	10:22:52	19.80	0.68	
12/14/2022	10:23:52	19.79	0.68	
12/14/2022	10:24:52	19.79	0.68	
12/14/2022	10:25:52	19.79	0.68	
12/14/2022	10:26:52	19.80	0.68	
12/14/2022	10:27:52	19.80	0.68	
12/14/2022	10:28:52	19.80	0.68	
12/14/2022	10:29:52	19.80	0.67	
12/14/2022	10:30:52	19.80	0.68	
12/14/2022	10:31:52	19.80	0.68	
12/14/2022	10:32:52	19.80	0.68	
12/14/2022	10:33:52	19.80	0.68	
12/14/2022	10:34:52	19.80	0.68	
12/14/2022	10:35:52	19.80	0.68	
12/14/2022	10:36:52	19.81	0.69	
12/14/2022	10:37:52	19.81	0.68	
12/14/2022	10:38:52	19.81	0.68	
12/14/2022	10:39:52	19.81	0.68	
12/14/2022	10:40:52	19.80	0.68	
12/14/2022	10:41:52	19.81	0.68	
12/14/2022	10:42:52	19.81	0.68	
12/14/2022	10:43:52	19.80	0.68	
12/14/2022	10:44:52	19.81	0.68	
12/14/2022	10:45:52	19.81	0.67	
12/14/2022	10:46:52	19.80	0.67	
12/14/2022	10:47:52	19.80	0.67	
12/14/2022	10:48:52	19.80	0.67	
12/14/2022	10:49:52	19.80	0.67	
12/14/2022	10:50:52	19.80	0.67	
12/14/2022	10:51:52	19.81	0.66	
12/14/2022	10:52:52	19.81	0.66	
12/14/2022	10:53:52	19.81	0.66	
12/14/2022	10:54:52	19.81	0.66	
12/14/2022	10:55:52	19.81	0.67	
12/14/2022	10:56:52	19.81	0.67	
12/14/2022	10:57:52	19.81	0.67	
12/14/2022	10:58:52	19.81	0.68	
12/14/2022	10:59:52	19.81	0.68	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 115**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/14/2022	11:00:52	19.81	0.68	
12/14/2022	11:01:52	19.81	0.68	
12/14/2022	11:02:52	19.81	0.69	
12/14/2022	11:03:52	19.81	0.68	
12/14/2022	11:04:52	19.81	0.68	
12/14/2022	11:05:52	19.81	0.68	
12/14/2022	11:06:52	19.81	0.68	
12/14/2022	11:07:52	19.81	0.68	
12/14/2022	11:08:52	19.81	0.68	
12/14/2022	11:09:52	19.80	0.68	
12/14/2022	11:10:52	19.80	0.68	
12/14/2022	11:11:52	19.80	0.68	
12/14/2022	11:12:52	19.80	0.68	
12/14/2022	11:13:52	19.80	0.67	
12/14/2022	11:14:52	19.80	0.67	
12/14/2022	11:15:52	19.80	0.67	
12/14/2022	11:16:52	19.80	0.67	
12/14/2022	11:17:52	19.80	0.67	
12/14/2022	11:18:52	19.79	0.68	
12/14/2022	11:19:52	19.80	0.67	<b>End Run 3</b>
		<b>19.80</b>	<b>0.68</b>	<b>Average</b>
12/14/2022	11:20:52	19.80	0.68	
12/14/2022	11:21:52	19.80	0.67	
12/14/2022	11:22:52	19.80	0.68	
12/14/2022	11:23:52	19.80	0.68	
12/14/2022	11:24:52	19.79	0.68	
12/14/2022	11:25:52	19.79	0.68	
12/14/2022	11:26:52	19.79	0.69	
12/14/2022	11:27:52	19.79	0.69	
12/14/2022	11:28:52	19.80	0.68	
12/14/2022	11:29:52	19.80	0.68	
12/14/2022	11:30:52	19.75	0.71	
12/14/2022	11:31:52	3.12	0.31	
12/14/2022	11:32:52	0.06	0.05	
12/14/2022	11:33:52	0.04	0.04	<b>O2/CO2 System Zero</b>
12/14/2022	11:34:52	0.02	0.04	
12/14/2022	11:35:52	0.02	0.04	
12/14/2022	11:36:52	7.49	7.64	

## Hollingsworth & Vose - Glass Plant 2

### CFU 115

#### Calibrations and Test Runs

Date	Time	O2 [%]	CO2 [%]	Notes
12/14/2022	11:37:52	9.93	10.08	O2/CO2 System Upscale
12/14/2022	11:38:52	9.95	10.11	
12/14/2022	11:39:52	9.95	10.12	
12/14/2022	11:40:52	9.95	10.12	
12/14/2022	11:41:52	10.54	9.47	
12/14/2022	11:42:52	19.10	1.25	
				<b>CFU 115 Retest</b>
12/14/2022	13:05:52	19.79	0.68	<b>Start Run 4</b>
12/14/2022	13:06:52	19.79	0.69	
12/14/2022	13:07:52	19.79	0.69	
12/14/2022	13:08:52	19.78	0.69	
12/14/2022	13:09:52	19.78	0.69	
12/14/2022	13:10:52	19.78	0.69	
12/14/2022	13:11:52	19.78	0.69	
12/14/2022	13:12:52	19.79	0.68	
12/14/2022	13:13:52	19.80	0.68	
12/14/2022	13:14:52	19.79	0.68	
12/14/2022	13:15:52	19.79	0.68	
12/14/2022	13:16:52	19.79	0.68	
12/14/2022	13:17:52	19.78	0.68	
12/14/2022	13:18:52	19.79	0.67	
12/14/2022	13:19:52	19.79	0.67	
12/14/2022	13:20:52	19.78	0.67	
12/14/2022	13:21:52	19.78	0.68	
12/14/2022	13:22:52	19.78	0.67	
12/14/2022	13:23:52	19.77	0.68	
12/14/2022	13:24:52	19.77	0.68	
12/14/2022	13:25:52	19.77	0.68	
12/14/2022	13:26:52	19.77	0.68	
12/14/2022	13:27:52	19.77	0.68	
12/14/2022	13:28:52	19.78	0.68	
12/14/2022	13:29:52	19.77	0.68	
12/14/2022	13:30:52	19.77	0.69	
12/14/2022	13:31:52	19.78	0.69	
12/14/2022	13:32:52	19.77	0.70	
12/14/2022	13:33:52	19.77	0.70	
12/14/2022	13:34:52	19.77	0.70	
12/14/2022	13:35:52	19.77	0.69	



**Hollingsworth & Vose - Glass Plant 2**  
**CFU 115**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/14/2022	13:36:52	19.77	0.69	
12/14/2022	13:37:52	19.78	0.69	
12/14/2022	13:38:52	19.78	0.69	
12/14/2022	13:39:52	19.79	0.68	
12/14/2022	13:40:52	19.79	0.68	
12/14/2022	13:41:52	19.79	0.68	
12/14/2022	13:42:52	19.79	0.67	
12/14/2022	13:43:52	19.78	0.68	
12/14/2022	13:44:52	19.78	0.67	
12/14/2022	13:45:52	19.78	0.67	
12/14/2022	13:46:52	19.78	0.67	
12/14/2022	13:47:52	19.79	0.67	
12/14/2022	13:48:52	19.79	0.68	
12/14/2022	13:49:52	19.79	0.68	
12/14/2022	13:50:52	19.79	0.68	
12/14/2022	13:51:52	19.79	0.68	
12/14/2022	13:52:52	19.79	0.68	
12/14/2022	13:53:52	19.78	0.68	
12/14/2022	13:54:52	19.78	0.69	
12/14/2022	13:55:52	19.79	0.69	
12/14/2022	13:56:52	19.79	0.69	
12/14/2022	13:57:52	19.79	0.69	
12/14/2022	13:58:52	19.79	0.69	
12/14/2022	13:59:52	19.79	0.69	
12/14/2022	14:00:52	19.79	0.69	
12/14/2022	14:01:52	19.80	0.70	
12/14/2022	14:02:52	19.80	0.70	
12/14/2022	14:03:52	19.80	0.70	
12/14/2022	14:04:52	19.79	0.68	<b>End Run 4</b>
		<b>19.78</b>	<b>0.68</b>	<b>Average</b>
12/14/2022	14:05:52	19.79	0.69	
12/14/2022	14:06:52	13.79	0.65	
12/14/2022	14:07:52	0.28	0.07	
12/14/2022	14:08:52	0.05	0.04	<b>O2/CO2 System Zero</b>
12/14/2022	14:09:52	1.96	2.04	
12/14/2022	14:10:52	9.72	9.71	
12/14/2022	14:11:52	9.95	9.98	<b>O2/CO2 System Upscale</b>
12/14/2022	14:12:52	13.38	6.56	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 115**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/14/2022	14:13:52	19.66	0.78	
12/14/2022	14:14:52	19.75	0.70	
12/14/2022	14:15:52	19.76	0.69	<b>Start Run 5</b>
12/14/2022	14:16:52	19.78	0.69	
12/14/2022	14:17:52	19.78	0.68	
12/14/2022	14:18:52	19.78	0.68	
12/14/2022	14:19:52	19.78	0.69	
12/14/2022	14:20:52	19.78	0.69	
12/14/2022	14:21:52	19.78	0.69	
12/14/2022	14:22:52	19.78	0.69	
12/14/2022	14:23:52	19.78	0.69	
12/14/2022	14:24:52	19.77	0.69	
12/14/2022	14:25:52	19.77	0.69	
12/14/2022	14:26:52	19.77	0.70	
12/14/2022	14:27:52	19.78	0.69	
12/14/2022	14:28:52	19.78	0.69	
12/14/2022	14:29:52	19.78	0.69	
12/14/2022	14:30:52	19.78	0.69	
12/14/2022	14:31:52	19.77	0.69	
12/14/2022	14:32:52	19.77	0.68	
12/14/2022	14:33:52	19.78	0.68	
12/14/2022	14:34:52	19.78	0.68	
12/14/2022	14:35:52	19.77	0.68	
12/14/2022	14:36:52	19.77	0.68	
12/14/2022	14:37:52	19.77	0.68	
12/14/2022	14:38:52	19.77	0.68	
12/14/2022	14:39:52	19.77	0.68	
12/14/2022	14:40:52	19.78	0.68	
12/14/2022	14:41:52	19.78	0.68	
12/14/2022	14:42:52	19.77	0.68	
12/14/2022	14:43:52	19.77	0.68	
12/14/2022	14:44:52	19.77	0.69	
12/14/2022	14:45:52	19.77	0.68	
12/14/2022	14:46:52	19.78	0.68	
12/14/2022	14:47:52	19.78	0.69	
12/14/2022	14:48:52	19.78	0.69	
12/14/2022	14:49:52	19.78	0.69	
12/14/2022	14:50:52	19.78	0.69	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 115**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/14/2022	14:51:52	19.78	0.69	
12/14/2022	14:52:52	19.78	0.69	
12/14/2022	14:53:52	19.79	0.69	
12/14/2022	14:54:52	19.79	0.69	
12/14/2022	14:55:52	19.79	0.69	
12/14/2022	14:56:52	19.78	0.68	
12/14/2022	14:57:52	19.79	0.68	
12/14/2022	14:58:52	19.79	0.68	
12/14/2022	14:59:52	19.79	0.68	
12/14/2022	15:00:52	19.79	0.67	
12/14/2022	15:01:52	19.79	0.67	
12/14/2022	15:02:52	19.78	0.68	
12/14/2022	15:03:52	19.78	0.68	
12/14/2022	15:04:52	19.78	0.68	
12/14/2022	15:05:52	19.79	0.68	
12/14/2022	15:06:52	19.78	0.68	
12/14/2022	15:07:52	19.79	0.68	
12/14/2022	15:08:52	19.79	0.68	
12/14/2022	15:09:52	19.79	0.68	
12/14/2022	15:10:52	19.79	0.68	
12/14/2022	15:11:52	19.80	0.68	
12/14/2022	15:12:52	19.80	0.68	
12/14/2022	15:13:52	19.80	0.68	
12/14/2022	15:14:52	19.80	0.68	<b>End Run 5</b>
		<b>19.78</b>	<b>0.68</b>	<b>Average</b>
12/14/2022	15:15:52	19.80	0.69	
12/14/2022	15:16:52	19.80	0.68	
12/14/2022	15:17:52	19.80	0.69	
12/14/2022	15:18:52	10.73	0.58	
12/14/2022	15:19:52	0.15	0.06	
12/14/2022	15:20:52	0.05	0.05	<b>O2/CO2 System Zero</b>
12/14/2022	15:21:52	6.05	6.14	
12/14/2022	15:22:52	9.94	9.96	<b>O2/CO2 System Upscale</b>
12/14/2022	15:23:52	12.22	7.69	
12/14/2022	15:24:52	19.58	0.85	
12/14/2022	15:25:52	19.78	0.69	<b>Start Run 6</b>
12/14/2022	15:26:52	19.78	0.68	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 115**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/14/2022	15:27:52	19.79	0.68	
12/14/2022	15:28:52	19.79	0.68	
12/14/2022	15:29:52	19.79	0.68	
12/14/2022	15:30:52	19.80	0.67	
12/14/2022	15:31:52	19.80	0.68	
12/14/2022	15:32:52	19.80	0.68	
12/14/2022	15:33:52	19.80	0.67	
12/14/2022	15:34:52	19.80	0.67	
12/14/2022	15:35:52	19.80	0.67	
12/14/2022	15:36:52	19.79	0.68	
12/14/2022	15:37:52	19.79	0.69	
12/14/2022	15:38:52	19.79	0.69	
12/14/2022	15:39:52	19.80	0.69	
12/14/2022	15:40:52	19.80	0.69	
12/14/2022	15:41:52	19.79	0.69	
12/14/2022	15:42:52	19.80	0.69	
12/14/2022	15:43:52	19.80	0.69	
12/14/2022	15:44:52	19.79	0.69	
12/14/2022	15:45:52	19.79	0.69	
12/14/2022	15:46:52	19.79	0.69	
12/14/2022	15:47:52	19.79	0.68	
12/14/2022	15:48:52	19.80	0.68	
12/14/2022	15:49:52	19.79	0.68	
12/14/2022	15:50:52	19.79	0.68	
12/14/2022	15:51:52	19.79	0.68	
12/14/2022	15:52:52	19.79	0.68	
12/14/2022	15:53:52	19.79	0.68	
12/14/2022	15:54:52	19.79	0.67	
12/14/2022	15:55:52	19.79	0.67	
12/14/2022	15:56:52	19.79	0.68	
12/14/2022	15:57:52	19.78	0.68	
12/14/2022	15:58:52	19.78	0.68	
12/14/2022	15:59:52	19.79	0.68	
12/14/2022	16:00:52	19.79	0.68	
12/14/2022	16:01:52	19.79	0.69	
12/14/2022	16:02:52	19.80	0.69	
12/14/2022	16:03:52	19.79	0.70	
12/14/2022	16:04:52	19.79	0.69	
12/14/2022	16:05:52	19.80	0.69	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 115**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/14/2022	16:06:52	19.80	0.69	
12/14/2022	16:07:52	19.79	0.69	
12/14/2022	16:08:52	19.80	0.69	
12/14/2022	16:09:52	19.80	0.69	
12/14/2022	16:10:52	19.80	0.69	
12/14/2022	16:11:52	19.80	0.69	
12/14/2022	16:12:52	19.80	0.70	
12/14/2022	16:13:52	19.80	0.69	
12/14/2022	16:14:52	19.80	0.69	
12/14/2022	16:15:52	19.80	0.69	
12/14/2022	16:16:52	19.80	0.68	
12/14/2022	16:17:52	19.79	0.68	
12/14/2022	16:18:52	19.79	0.69	
12/14/2022	16:19:52	19.79	0.69	
12/14/2022	16:20:52	19.79	0.69	
12/14/2022	16:21:52	19.79	0.69	
12/14/2022	16:22:52	19.79	0.69	
12/14/2022	16:23:52	19.80	0.68	
12/14/2022	16:24:52	19.80	0.69	<b>End Run 6</b>
		<b>19.79</b>	<b>0.68</b>	<b>Average</b>
12/14/2022	16:25:52	19.80	0.69	
12/14/2022	16:26:52	13.03	0.50	
12/14/2022	16:27:52	0.23	0.07	
12/14/2022	16:28:52	0.05	0.05	<b>O2/CO2 System Zero</b>
12/14/2022	16:29:52	3.12	3.24	
12/14/2022	16:30:52	9.86	10.01	
12/14/2022	16:31:52	9.96	10.15	<b>O2/CO2 System Upscale</b>
12/14/2022	16:32:52	9.97	10.17	
12/14/2022	16:33:52	16.21	4.25	
12/14/2022	16:34:52	20.82	0.18	
12/14/2022	16:35:52	20.82	0.17	
12/14/2022	16:36:52	20.82	0.16	
12/14/2022	16:37:52	20.83	0.16	
12/14/2022	16:38:52	20.83	0.15	
12/14/2022	16:39:52	20.83	0.15	

## **APPENDIX E: CFU 118 TEST DATA**

---



Hollingsworth & Vose  
 Corvallis, OR  
 CFU 118 Tentatively Identified Compounds (TIC)

Run Number	1	2	3
Sample Collection Date	12/15/2022	12/15/2022	12/15/2022
Glass Production Rate Supplied by H&V (lb/hr)	108.7	110.3	110.3
Volumetric Flow Rate measured by Bison (dscfm)	17,146	17,895	17,410

Analyte	Molecular Weight g/mol	CFU 118-1				CFU 118-2				CFU 118-3				CFU 118 Averages			
		ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass	ppb	ppm	lb/hr	lb/ton glass
Propane	44.097	32	3.2E-02	3.77E-03	6.94E-02	19	1.9E-02	2.34E-03	4.24E-02	23	2.3E-02	2.75E-03	4.99E-02	24.67	2.5E-02	2.95E-03	5.39E-02
Isobutane	58.124	12	1.2E-02	1.86E-03	3.43E-02	10	1.0E-02	1.62E-03	2.94E-02	9.1	9.1E-03	1.43E-03	2.60E-02	10.37	1.0E-02	1.64E-03	2.99E-02
Butane	58.12	10	1.0E-02	1.55E-03	2.86E-02	7	7.0E-03	1.13E-03	2.06E-02	6.2	6.2E-03	9.77E-04	1.77E-02	7.73	7.7E-03	1.22E-03	2.23E-02
Butane, 2-Methyl	72.1488	8.9	8.9E-03	1.72E-03	3.16E-02									8.90	8.9E-03	1.72E-03	3.16E-02
Butane, 2,3-dimethyl	86.1754	3.2	3.2E-03	7.37E-04	1.36E-02									3.20	3.2E-03	7.37E-04	1.36E-02
Pentane	72.150	15	1.5E-02	2.89E-03	5.32E-02	6.9	6.9E-03	1.39E-03	2.52E-02	6.7	6.7E-03	1.31E-03	2.38E-02	9.53	9.5E-03	1.86E-03	3.40E-02
Pentane, 2-methyl-	86.175	6.1	6.1E-03	1.40E-03	2.58E-02	2.6	2.6E-03	6.25E-04	1.13E-02	3.2	3.2E-03	7.48E-04	1.36E-02	3.97	4.0E-03	9.26E-04	1.69E-02
Pentane, 2,4-dimethyl-	100.20	8.2	8.2E-03	2.19E-03	4.04E-02	3.2	3.2E-03	8.94E-04	1.62E-02					5.70	5.7E-03	1.54E-03	2.83E-02
Pentane, 2,3-dimethyl-	100.20	7.2	7.2E-03	1.93E-03	3.55E-02	3.3	3.3E-03	9.22E-04	1.67E-02	6.1	6.1E-03	1.66E-03	3.01E-02	5.53	5.5E-03	1.50E-03	2.74E-02
Pentane, 2,3,4-trimethyl	114.229									2.8	2.8E-03	8.68E-04	1.57E-02	2.80	2.8E-03	8.68E-04	1.57E-02
Butane, 2,2,3,3-tetramethyl-	114.2285	8.9	8.9E-03	2.72E-03	5.00E-02	4.0	4.0E-03	1.27E-03	2.31E-02	14	1.4E-02	4.34E-03	7.87E-02	8.97	9.0E-03	2.78E-03	5.06E-02
1-Pentene, 4-methyl-	84.1595									5.2	5.2E-03	1.19E-03	2.15E-02	5.20	5.2E-03	1.19E-03	2.15E-02
Heptane, 2,4-dimethyl	128.2551									2.6	2.6E-03	9.05E-04	1.64E-02	2.60	2.6E-03	9.05E-04	1.64E-02

Note: Concentrations listed for all TICs are estimated values.



**Bison Engineering, Inc.**  
**Gaseous Testing Summary**

Client: **Hollingsworth & Vose**  
 Facility: **Glass Plant 2**  
 Location: **Corvallis, OR**

Source: **CFU 118**  
 Test Date: **December 15, 2022**

Environmental Conditions / Test Notes: 25 °F

Run		1	2	3	Average
Date		12/15/2022	12/15/2022	12/15/2022	
Run Start Time		8:20	9:30	10:40	
Run End Time		9:19	10:29	11:39	
Duration, min.		60	60	60	
Stack Diameter, in.		30.00	30.00	30.00	
Stack Area, sq.ft.		4.909	4.909	4.909	
Barometric Pressure, "Hg		30.21	30.21	30.21	30.21
Static Pressure, "H <sub>2</sub> O		-0.73	-0.73	-0.73	-0.73
Stack Temperature, °F		222	225	226	224
CO <sub>2</sub> , %vd		0.54	0.55	0.54	0.54
O <sub>2</sub> , %vd		20.19	20.21	20.23	20.21
H <sub>2</sub> O, %v		1.13	1.39	1.17	1.23
Wet Molecular Weight, lb/lb-mole		28.77	28.75	28.76	28.76
Velocity, FPS		75.52	79.33	76.08	76.97
WSCFM		17,342	18,147	17,392	17,627
DSCFM		17,146	17,895	17,188	17,410
Production Data, Total Rotary Fine	lb/hr	108.7	110.3	110.3	109.8
Production Data, L4R8	lb/hr	55.5	56.3	56.3	56.1
Production Data L4R9	lb/hr	53.2	54.0	54.0	53.7

Note: Negative concentrations are reported as zero.

**Bison Engineering, Inc.**  
**Pre-Test Traverse**

**Client:** Hollingsworth & Vose  
**Location:** Corvallis, OR  
**Source:** CFU 118

**Stack Temp:** NA °F

Traverse Point	Velocity ΔP ("H <sub>2</sub> O)	Null Angle
1	NA	2
2	NA	4
3	NA	3
4	NA	5
5	NA	0
6	NA	1
7	NA	0
8	NA	0
9	NA	1
10	NA	4
11	NA	6
12	NA	8
13	NA	0
14	NA	1
15	NA	3
16	NA	0

Average: NA 2  
 Flow is found to be: Non-cyclonic

No nozzle was needed for flow measurements, therefore no pre-velocity measurements or stack temperature was recorded prior to testing.

**Bison Engineering, Inc.**  
**EPA Method 1**  
**Stack Parameters and Traverse Points**

**Client:** Hollingsworth & Vose  
**Location:** Corvallis, OR  
**Source:** CFU 118  
**Facility:** Glass Plant 2

Type of Testing: V V for Velocity/Nonparticulate)  
 Type of Duct: C (C for circular; R for rectangular)

Number of ports available: 2  
 Number of ports to be used: 2  
 Port diameter: 5 inches  
 Sampling location height (approx.): 40.00 feet  
 Stack height (approx.): 8.00 feet

Circular ID (Rectangular Depth): 30.00 inches  
 Port depth and/or wall thickness: 6.00 inches  
 Stack width (Rectangular only): inches

Equivalent Diameter  
 If rectangular =  $\frac{2 * \text{Depth} * \text{Width}}{\text{Depth} + \text{Width}} =$  30.00 inches (If circular = duct ID)

Stack/duct area = 4.909 sq. feet 706.9 sq. inches


Sample Port Location:	Downstream flow disturbance from process	Upstream flow disturbance toward exit
	B	A
Number of Inches:	142.00	52.00
Number of Diameters:	4.73	1.73

Minimum Number of Traverse Points: 16

Traverse points less than 1.0 inch from the stack wall are relocated to a distance of 1.0 inch.

Points	% of diameter	Distance from inside wall (in.)	Distance including port (in.)
1	3.2	0.96	7
2	10.5	3.15	9 1/8
3	19.4	5.82	11 7/8
4	32.3	9.69	15 3/4
5	67.7	20.31	26 1/4
6	80.6	24.18	30 1/8
7	89.5	26.85	32 7/8
8	96.8	29.04	35

**Reference Diagram**



Drawing NOT to scale and NOT an accurate representation of stack.

**Bison Engineering, Inc.**

**Method 2**

**Stack Gas Velocity and Volumetric Flow Rate**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 2  
**Location:** Corvallis, OR

**Source:** CFU 118  
**Test Date:** 12/15/22

Molecular Weight		
Choose One by "x" below		
Measured	Ambient	Combustion
x		

Pitot ID	4E
----------	----

Leak Checks:	Run 1		Run 2		Run 3	
	Pre	Post	Pre	Post	Pre	Post
<b>Pitot</b>	x	x	x	x	x	x
<b>Barometric Pressure ("Hg)</b>	30.21		30.21		30.21	

Traverse	Sample Point	Run 1		Run 2		Run 3	
		Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)	Velocity ΔP ("H <sub>2</sub> O)	Stack Temperature (°F)
A	1	1.60	219	1.50	225	1.50	220
	2	1.50	222	1.40	225	1.40	221
	3	1.50	223	1.60	225	1.60	224
	4	1.30	223	1.60	226	1.60	225
	5	1.50	223	1.70	227	1.60	226
	6	1.60	223	1.80	228	1.40	227
	7	1.60	223	1.70	228	1.20	227
	8	1.50	222	1.80	227	1.60	227
B	1	1.20	221	1.40	220	1.60	226
	2	1.60	223	1.60	221	1.20	226
	3	1.70	222	1.70	222	1.10	226
	4	1.30	223	1.50	224	1.40	226
	5	1.20	223	1.50	225	1.50	227
	6	1.30	223	1.40	225	1.30	227
	7	1.20	223	1.40	225	1.30	227
	8	1.00	223	1.20	228	1.50	227

Method 2 -Flow Calculations							
Static Pressure, "H <sub>2</sub> O			-0.73			-0.73	
Pitot tube cp			0.84			0.84	
Stack Area, ft <sup>3</sup>			4.909			4.909	
H <sub>2</sub> O, %v			1.13			1.39	
Average √ΔP			1.186			1.243	
Average Absolute Temp. (°R)			682.1			684.7	
Stack Pressure (in. Hg)			30.16			30.16	
Stack Velocity (ft/sec)			75.52			79.33	
Actual Flow Rate (acfm)			22,242			23,363	
Standard Flow Rate (wscf/hr)			1,040,508			1,088,822	
Dry Standard Flow Rate (dscf/hr)			1,028,750			1,073,687	
Dry Standard Flow Rate (dscfm)			17,146			17,895	

	O <sub>2</sub>	CO <sub>2</sub>	Calculated N <sub>2</sub>
Run 1	20.19	0.54	79.27
Run 2	20.21	0.55	79.24
Run 3	20.23	0.54	79.24

	Molecular Weight (lb/lb-mole)					
	Calculated		Ambient		Combustion	
Run1	M <sub>d</sub>	28.89	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.77	M <sub>s</sub>		M <sub>s</sub>	
Run 2	M <sub>d</sub>	28.90	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.75	M <sub>s</sub>		M <sub>s</sub>	
Run 3	M <sub>d</sub>	28.89	M <sub>d</sub>		M <sub>d</sub>	
	M <sub>s</sub>	28.76	M <sub>s</sub>		M <sub>s</sub>	

**Bison Engineering, Inc.**  
**Moisture Field Data**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 2  
**Location:** Corvallis, OR  
**Source:** CFU 118  
**Test date:** 12/15/2022

**Meterbox ID:** Box 11  
**Meter "Y"-Factor:** 0.9690

Moisture Field Data Entry				
Run 1				
Leak Checks:		Pre-test	Post-test	
Train leak rate, dcf		0.000	0.000	
Leak check vacuum, "Hg		15	4	
Start Time		8:20		
End Time		9:20		
Bp, "Hg		30.21		
Minutes	Meter Volume	Meter °F	Condenser °F	Delta H
	896.200			
5	899.850	34	30	1.800
10	903.450	34	34	1.800
15	907.040	35	35	1.800
20	910.640	35	36	1.800
25	914.260	36	37	1.800
30	917.860	36	38	1.800
35	921.480	36	37	1.800
40	924.990	37	39	1.800
45	928.710	37	38	1.800
50	932.330	38	40	1.800
55	935.950	38	39	1.800
60	939.595	38	40	1.800
Impinger gain by weight (g):				
#	Initial	Final	Gain	
1	823.4	829.7	6.3	
2	822.0	822.5	0.5	
3	682.6	681.5	-1.1	
Silica Gel	865.4	870.7	5.3	
Impinger Totals:	3,193.4	3,204.4	5.7	

Moisture Field Data Entry				
Run 2				
Leak Checks:		Pre-test	Post-test	
Train leak rate, dcf		0.000	0.000	
Leak check vacuum, "Hg		17	5	
Start Time		9:30		
End Time		10:30		
Bp, "Hg		30.21		
Meter Volume	Meter °F	Condenser °F	Delta H	
939.975				
943.720	38	35	1.800	
947.450	39	39	1.800	
951.200	39	40	1.800	
954.930	39	41	1.800	
958.720	40	42	1.800	
962.400	40	41	1.800	
966.130	40	43	1.800	
969.860	40	42	1.800	
973.610	41	44	1.800	
977.330	41	44	1.800	
981.030	42	45	1.800	
984.790	43	44	1.800	
Impinger gain by weight (g):				
#	Initial	Final	Gain	
1	829.7	835.4	5.7	
2	785.5	787.4	1.9	
3	619.2	620.0	0.8	
Silica Gel	946.8	952.3	5.5	
Impinger Totals:	3,181.2	3,195.1	8.4	

Moisture Field Data Entry				
Run 3				
Leak Checks:		Pre-test	Post-test	
Train leak rate, dcf		0.000	0.000	
Leak check vacuum, "Hg		16	4	
Start Time		10:40		
End Time		11:40		
Bp, "Hg		30.21		
Meter Volume	Meter °F	Condenser °F	Delta H	
985.250				
988.810	45	40	1.800	
992.580	45	41	1.800	
996.250	46	43	1.800	
999.930	47	46	1.800	
1003.610	47	45	1.800	
1007.280	47	46	1.800	
1011.020	47	46	1.800	
1014.660	47	46	1.800	
1018.350	47	48	1.800	
1022.010	47	48	1.800	
1025.720	47	47	1.800	
1029.395	47	48	1.800	
Impinger gain by weight (g):				
#	Initial	Final	Gain	
1	835.4	840.1	4.7	
2	822.5	824.0	1.5	
3	681.5	682.1	0.6	
Silica Gel	870.7	875.2	4.5	
Impinger Totals:	3,210.1	3,221.4	6.8	

**Bison Engineering, Inc.**  
**Method 4 Moisture Calculations**

**Client:** Hollingsworth & Vose  
**Facility:** Glass Plant 2  
**Location:** Corvallis, OR  
**Source:** CFU 118  
**Test date:** 12/15/2022

Method 4 -Moisture Determination					
Run Number	#	1	2	3	
Start Time	hh:mm	8:20	9:30	10:40	
Meter Box Identification	#	Box 11	Box 11	Box 11	
Meter "Y" Factor	Factor	0.9690	0.9690	0.9690	
Barometric Pressure	in Hg	30.21	30.21	30.21	
Sample Duration	hh:mm	1:00	1:00	1:00	
Average Meter Temperature	Deg F	36.2	40.2	46.6	
Average Condenser Temperature	Deg F	36.9	41.7	45.3	
Average Delta H	in H2O	1.800	1.800	1.800	
Average Meter Pressure	in Hg	30.342	30.342	30.342	
Meter Volume Start	dcf	896.200	939.975	985.250	
Meter Volume End	dcf	939.595	984.790	1029.395	
Meter Volume	dcf	43.395	44.815	44.145	
Corrected Meter Volume	dscf	45.381	46.490	45.215	
Impinger Gain	g	5.7	8.4	6.8	
Silica Gel Gain	g	5.3	5.5	4.5	Average
Volume of Condensed Water Vapor	scf	0.519	0.655	0.533	0.569
Moisture Calculation	Bws	0.0113	0.0139	0.0117	0.012
Percent Moisture	Bws%	1.13	1.39	1.17	1.23

**Bison Engineering, Inc.**  
**Method 3A Oxygen**  
**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU 118</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 2</b>	Date: <b>December 15, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values				System Drift % of span	Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference Gas
		Analyzer Cal. Response	System Cal Response	Pre test		System Cal Response	Post test							
				System Cal. Bias % of span	pass/fail		System Cal. Bias % of span	pass/fail						
Run 1	zero	-0.01	0.01	0.09	pass	0.02	0.14	pass	0.05	pass				
	upscale	9.97	9.95	-0.09	pass	9.93	-0.18	pass	0.09	pass	21.94	19.95	20.19	10.05
Run 2	zero	-0.01	0.02	0.14	pass	0.02	0.14	pass	0.00	pass				
	upscale	9.97	9.93	-0.18	pass	9.92	-0.23	pass	0.05	pass	21.94	19.94	20.21	10.05
Run 3	zero	-0.01	0.02	0.14	pass	0.05	0.27	pass	0.14	pass				
	upscale	9.97	9.92	-0.23	pass	9.92	-0.23	pass	0.00	pass	21.94	19.93	20.23	10.05
				<b>&lt; 5%*</b>		<b>&lt; 5%*</b>		<b>&lt; 3%*</b>						

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	10.05	21.94
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	-0.01	9.97	21.98
Analyzer Calibration Error	-0.05	-0.36	0.18
Analyzer Calibration Error < 2%*	pass	pass	pass

System Response Time	
30	seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %  
 \*Or < 0.5 % absolute difference

**Bison Engineering, Inc.**  
**Method 3A CO<sub>2</sub>**  
**Calibration Error, System Bias and System Drift**

Client: <b>Hollingsworth &amp; Vose</b>	Source: <b>CFU 118</b>	Instrument Make: <b>Servomex</b>
Facility: <b>Glass Plant 2</b>	Date: <b>December 15, 2022</b>	Instrument Model: <b>1440</b>
Location: <b>Corvallis, OR</b>		Instrument Serial #: <b>01440D1-5041</b>

		Initial Values				Final Values				Analyzer Span	Raw Avg Gas Conc	Corrected Gas Conc	Instrument Cal. Reference Gas
		Analyzer Cal. Response	System Cal Response	Pre test System Cal. Bias		System Cal Response	Post test System Cal. Bias		System Drift				
				% of span	pass/fail		% of span	pass/fail	% of span	pass/fail			
Run 1	zero	0.04	0.06	0.09	pass	0.05	0.05	pass	0.05	pass			
	upscale	9.85	9.88	0.14	pass	9.85	0.00	pass	0.14	pass	21.70	0.59	0.54
Run 2	zero	0.04	0.05	0.05	pass	0.05	0.05	pass	0.00	pass			
	upscale	9.85	9.85	0.00	pass	9.87	0.09	pass	0.09	pass	21.70	0.59	0.55
Run 3	zero	0.04	0.05	0.05	pass	0.07	0.14	pass	0.09	pass			
	upscale	9.85	9.87	0.09	pass	9.96	0.51	pass	0.41	pass	21.70	0.59	0.54
				<b>&lt; 5%*</b>		<b>&lt; 5%*</b>		<b>&lt; 3%*</b>					

Analyzer Calibration Error	Zero	Mid	High
Calibration Gas Standards	0	9.951	21.70
Cylinder Number		CC503830	SA20406
Calibration Gas Analyzer Response	0.04	9.85	21.93
Analyzer Calibration Error	0.18	-0.47	1.06
Analyzer Calibration Error < 2% *	pass	pass	pass

System Response Time
28 seconds

System Leak Check		
	Completed	Pass/Fail
Pre-test	Yes	Pass
Post-test	Yes	Pass

Note: All units are in %  
 \*Or < 0.5 % absolute difference



**Bison Engineering, Inc.**  
**Stratification Check**

Client:	<b>Hollingsworth &amp; Vose</b>	Source:	<b>CFU 118</b>
Facility:	<b>Glass Plant 2</b>	Test Date:	<b>December 15, 2022</b>
Location:	<b>Corvallis, OR</b>		

Stack Diameter: 30 inches  
 Port Depth: 6 inches

<b>3 POINT METHOD</b>						
<u>% of diameter</u>	<u>Pt</u>	<u>Pt location</u>	<u>O2%</u>	<u>Diff (+/- 5%)</u>	<u>Pass/Fail</u>	
16.7%	S1	11.01	19.95	0.00%	PASS	
50.0%	S2	21.00	19.95	0.00%	PASS	
83.3%	S3	30.99	19.95	0.00%	PASS	
		AVERAGE:	19.95			

## Hollingsworth & Vose - Glass Plant 2

### CFU 118

#### Calibrations and Test Runs

Date	Time	O2 [%]	CO2 [%]	Notes
12/15/2022	6:10:50	0.07	0.05	
12/15/2022	6:11:50	-0.01	0.04	O2/CO2 Analyzer Zero
12/15/2022	6:12:50	14.06	14.48	
12/15/2022	6:13:50	21.98	21.93	O2/CO2 Analyzer Span
12/15/2022	6:14:50	15.44	15.20	
12/15/2022	6:15:50	9.97	9.85	O2/CO2 Analyzer Mid
12/15/2022	6:16:50	11.65	2.37	
12/15/2022	6:17:50	0.22	0.09	
12/15/2022	6:18:50	0.01	0.06	O2/CO2 System Zero
12/15/2022	6:19:50	3.35	3.42	
12/15/2022	6:20:50	9.86	9.72	
12/15/2022	6:21:50	9.95	9.88	O2/CO2 System Upscale
12/15/2022	6:22:50	13.62	6.35	
12/15/2022	6:23:50	20.02	0.61	
12/15/2022	8:04:50	19.95	0.59	Stratification Check
12/15/2022	8:05:50	19.95	0.59	S1 19.95
12/15/2022	8:06:50	19.95	0.59	
12/15/2022	8:07:50	19.95	0.59	
12/15/2022	8:08:50	19.95	0.59	
12/15/2022	8:09:50	19.95	0.59	
12/15/2022	8:10:50	19.95	0.60	S2 19.95
12/15/2022	8:11:50	19.95	0.60	
12/15/2022	8:12:50	19.95	0.60	
12/15/2022	8:13:50	19.95	0.59	
12/15/2022	8:14:50	19.95	0.60	
12/15/2022	8:15:50	19.95	0.60	S3 19.95
12/15/2022	8:16:50	19.95	0.60	
12/15/2022	8:17:50	19.95	0.60	
12/15/2022	8:18:50	19.95	0.60	
12/15/2022	8:19:50	19.95	0.60	
				<b>CFU 118</b>
12/15/2022	8:20:50	19.95	0.60	Start Run 1
12/15/2022	8:21:50	19.96	0.60	
12/15/2022	8:22:50	19.95	0.60	
12/15/2022	8:23:50	19.95	0.60	
12/15/2022	8:24:50	19.95	0.59	
12/15/2022	8:25:50	19.95	0.60	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 118**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/15/2022	8:26:50	19.95	0.59	
12/15/2022	8:27:50	19.95	0.59	
12/15/2022	8:28:50	19.95	0.59	
12/15/2022	8:29:50	19.95	0.59	
12/15/2022	8:30:50	19.95	0.59	
12/15/2022	8:31:50	19.95	0.59	
12/15/2022	8:32:50	19.95	0.59	
12/15/2022	8:33:50	19.95	0.59	
12/15/2022	8:34:50	19.95	0.59	
12/15/2022	8:35:50	19.95	0.59	
12/15/2022	8:36:50	19.95	0.59	
12/15/2022	8:37:50	19.95	0.60	
12/15/2022	8:38:50	19.95	0.59	
12/15/2022	8:39:50	19.94	0.60	
12/15/2022	8:40:50	19.94	0.60	
12/15/2022	8:41:50	19.95	0.60	
12/15/2022	8:42:50	19.95	0.59	
12/15/2022	8:43:50	19.95	0.59	
12/15/2022	8:44:50	19.95	0.59	
12/15/2022	8:45:50	19.95	0.59	
12/15/2022	8:46:50	19.95	0.59	
12/15/2022	8:47:50	19.95	0.59	
12/15/2022	8:48:50	19.95	0.59	
12/15/2022	8:49:50	19.94	0.59	
12/15/2022	8:50:50	19.95	0.59	
12/15/2022	8:51:50	19.95	0.59	
12/15/2022	8:52:50	19.95	0.58	
12/15/2022	8:53:50	19.94	0.58	
12/15/2022	8:54:50	19.94	0.58	
12/15/2022	8:55:50	19.94	0.58	
12/15/2022	8:56:50	19.95	0.58	
12/15/2022	8:57:50	19.94	0.58	
12/15/2022	8:58:50	19.95	0.58	
12/15/2022	8:59:50	19.95	0.58	
12/15/2022	9:00:50	19.95	0.58	
12/15/2022	9:01:50	19.95	0.58	
12/15/2022	9:02:50	19.95	0.59	
12/15/2022	9:03:50	19.95	0.59	
12/15/2022	9:04:50	19.95	0.59	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 118**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/15/2022	9:05:50	19.95	0.59	
12/15/2022	9:06:50	19.95	0.60	
12/15/2022	9:07:50	19.95	0.60	
12/15/2022	9:08:50	19.95	0.60	
12/15/2022	9:09:50	19.95	0.60	
12/15/2022	9:10:50	19.95	0.59	
12/15/2022	9:11:50	19.94	0.59	
12/15/2022	9:12:50	19.94	0.60	
12/15/2022	9:13:50	19.94	0.59	
12/15/2022	9:14:50	19.94	0.59	
12/15/2022	9:15:50	19.94	0.59	
12/15/2022	9:16:50	19.94	0.59	
12/15/2022	9:17:50	19.94	0.58	
12/15/2022	9:18:50	19.94	0.58	
12/15/2022	9:19:50	19.94	0.58	<b>End Run 1</b>
		<b>19.95</b>	<b>0.59</b>	<b>Average</b>
12/15/2022	9:20:50	19.94	0.59	
12/15/2022	9:21:50	12.25	0.65	
12/15/2022	9:22:50	0.16	0.06	
12/15/2022	9:23:50	0.02	0.05	<b>O2/CO2 System Zero</b>
12/15/2022	9:24:50	3.95	3.97	
12/15/2022	9:25:50	9.88	9.76	
12/15/2022	9:26:50	9.93	9.85	<b>O2/CO2 System Upscale</b>
12/15/2022	9:27:50	16.34	3.74	
12/15/2022	9:28:50	19.89	0.63	
12/15/2022	9:29:50	19.92	0.61	
12/15/2022	9:30:50	19.93	0.61	<b>Start Run 2</b>
12/15/2022	9:31:50	19.93	0.61	
12/15/2022	9:32:50	19.94	0.61	
12/15/2022	9:33:50	19.94	0.61	
12/15/2022	9:34:50	19.94	0.60	
12/15/2022	9:35:50	19.95	0.60	
12/15/2022	9:36:50	19.95	0.60	
12/15/2022	9:37:50	19.95	0.59	
12/15/2022	9:38:50	19.95	0.59	
12/15/2022	9:39:50	19.94	0.59	
12/15/2022	9:40:50	19.94	0.59	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 118**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/15/2022	9:41:50	19.95	0.59	
12/15/2022	9:42:50	19.94	0.59	
12/15/2022	9:43:50	19.94	0.59	
12/15/2022	9:44:50	19.94	0.58	
12/15/2022	9:45:50	19.93	0.58	
12/15/2022	9:46:50	19.93	0.58	
12/15/2022	9:47:50	19.93	0.58	
12/15/2022	9:48:50	19.93	0.58	
12/15/2022	9:49:50	19.93	0.58	
12/15/2022	9:50:50	19.93	0.58	
12/15/2022	9:51:50	19.93	0.58	
12/15/2022	9:52:50	19.93	0.58	
12/15/2022	9:53:50	19.93	0.59	
12/15/2022	9:54:50	19.93	0.58	
12/15/2022	9:55:50	19.92	0.59	
12/15/2022	9:56:50	19.94	0.60	
12/15/2022	9:57:50	19.94	0.60	
12/15/2022	9:58:50	19.93	0.59	
12/15/2022	9:59:50	19.93	0.59	
12/15/2022	10:00:50	19.93	0.59	
12/15/2022	10:01:50	19.93	0.59	
12/15/2022	10:02:50	19.94	0.59	
12/15/2022	10:03:50	19.94	0.59	
12/15/2022	10:04:50	19.94	0.59	
12/15/2022	10:05:50	19.94	0.59	
12/15/2022	10:06:50	19.94	0.58	
12/15/2022	10:07:50	19.94	0.58	
12/15/2022	10:08:50	19.93	0.58	
12/15/2022	10:09:50	19.94	0.58	
12/15/2022	10:10:50	19.94	0.58	
12/15/2022	10:11:50	19.94	0.58	
12/15/2022	10:12:50	19.94	0.58	
12/15/2022	10:13:50	19.94	0.58	
12/15/2022	10:14:50	19.95	0.58	
12/15/2022	10:15:50	19.95	0.58	
12/15/2022	10:16:50	19.95	0.58	
12/15/2022	10:17:50	19.95	0.59	
12/15/2022	10:18:50	19.95	0.58	
12/15/2022	10:19:50	19.95	0.59	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 118**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/15/2022	10:20:50	19.95	0.59	
12/15/2022	10:21:50	19.95	0.59	
12/15/2022	10:22:50	19.95	0.59	
12/15/2022	10:23:50	19.95	0.60	
12/15/2022	10:24:50	19.95	0.59	
12/15/2022	10:25:50	19.95	0.59	
12/15/2022	10:26:50	19.95	0.59	
12/15/2022	10:27:50	19.95	0.59	
12/15/2022	10:28:50	19.95	0.59	
12/15/2022	10:29:50	19.95	0.59	<b>End Run 2</b>
		<b>19.94</b>	<b>0.59</b>	<b>Average</b>
12/15/2022	10:30:50	19.95	0.59	
12/15/2022	10:31:50	19.95	0.58	
12/15/2022	10:32:50	13.96	0.87	
12/15/2022	10:33:50	0.24	0.09	
12/15/2022	10:34:50	0.02	0.05	<b>O2/CO2 System Zero</b>
12/15/2022	10:35:50	0.78	0.88	
12/15/2022	10:36:50	9.41	9.31	
12/15/2022	10:37:50	9.92	9.85	
12/15/2022	10:38:50	9.92	9.87	<b>O2/CO2 System Upscale</b>
12/15/2022	10:39:50	17.32	2.83	
12/15/2022	10:40:50	19.89	0.62	<b>Start Run 3</b>
12/15/2022	10:41:50	19.91	0.60	
12/15/2022	10:42:50	19.93	0.60	
12/15/2022	10:43:50	19.93	0.59	
12/15/2022	10:44:50	19.93	0.60	
12/15/2022	10:45:50	19.93	0.60	
12/15/2022	10:46:50	19.94	0.59	
12/15/2022	10:47:50	19.94	0.59	
12/15/2022	10:48:50	19.94	0.60	
12/15/2022	10:49:50	19.94	0.60	
12/15/2022	10:50:50	19.94	0.59	
12/15/2022	10:51:50	19.93	0.59	
12/15/2022	10:52:50	19.93	0.58	
12/15/2022	10:53:50	19.93	0.59	
12/15/2022	10:54:50	19.93	0.59	
12/15/2022	10:55:50	19.93	0.59	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 118**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/15/2022	10:56:50	19.93	0.58	
12/15/2022	10:57:50	19.93	0.58	
12/15/2022	10:58:50	19.92	0.58	
12/15/2022	10:59:50	19.92	0.58	
12/15/2022	11:00:50	19.92	0.57	
12/15/2022	11:01:50	19.92	0.58	
12/15/2022	11:02:50	19.92	0.57	
12/15/2022	11:03:50	19.92	0.57	
12/15/2022	11:04:50	19.93	0.57	
12/15/2022	11:05:50	19.93	0.58	
12/15/2022	11:06:50	19.93	0.58	
12/15/2022	11:07:50	19.93	0.58	
12/15/2022	11:08:50	19.93	0.58	
12/15/2022	11:09:50	19.93	0.59	
12/15/2022	11:10:50	19.93	0.59	
12/15/2022	11:11:50	19.94	0.59	
12/15/2022	11:12:50	19.93	0.60	
12/15/2022	11:13:50	19.93	0.59	
12/15/2022	11:14:50	19.93	0.60	
12/15/2022	11:15:50	19.93	0.60	
12/15/2022	11:16:50	19.93	0.60	
12/15/2022	11:17:50	19.94	0.60	
12/15/2022	11:18:50	19.94	0.59	
12/15/2022	11:19:50	19.94	0.59	
12/15/2022	11:20:50	19.94	0.59	
12/15/2022	11:21:50	19.94	0.59	
12/15/2022	11:22:50	19.94	0.59	
12/15/2022	11:23:50	19.94	0.58	
12/15/2022	11:24:50	19.94	0.58	
12/15/2022	11:25:50	19.94	0.58	
12/15/2022	11:26:50	19.94	0.58	
12/15/2022	11:27:50	19.94	0.58	
12/15/2022	11:28:50	19.94	0.58	
12/15/2022	11:29:50	19.94	0.59	
12/15/2022	11:30:50	19.94	0.59	
12/15/2022	11:31:50	19.94	0.59	
12/15/2022	11:32:50	19.93	0.59	
12/15/2022	11:33:50	19.93	0.59	
12/15/2022	11:34:50	19.93	0.59	

**Hollingsworth & Vose - Glass Plant 2**  
**CFU 118**  
**Calibrations and Test Runs**

<b>Date</b>	<b>Time</b>	<b>O2 [%]</b>	<b>CO2 [%]</b>	<b>Notes</b>
12/15/2022	11:35:50	19.93	0.60	
12/15/2022	11:36:50	19.93	0.60	
12/15/2022	11:37:50	19.94	0.60	
12/15/2022	11:38:50	19.93	0.60	
12/15/2022	11:39:50	19.93	0.60	<b>End Run 3</b>
		<b>19.93</b>	<b>0.59</b>	<b>Average</b>
12/15/2022	11:40:50	19.94	0.60	
12/15/2022	11:41:50	4.90	0.66	
12/15/2022	11:42:50	0.05	0.07	<b>O2/CO2 System Zero</b>
12/15/2022	11:43:50	0.02	0.07	
12/15/2022	11:44:50	4.64	4.72	
12/15/2022	11:45:50	9.88	9.89	
12/15/2022	11:46:50	9.92	9.96	<b>O2/CO2 System Upscale</b>
12/15/2022	11:47:50	14.98	5.24	
12/15/2022	11:48:50	20.72	0.22	



**Hollingsworth & Vose**  
**Corvallis, OR**  
**Summary of Speciated Organic Toxic Air Contaminants (TAC)**

Analyte	CFU 108	CFU 112	CFU 113	CFU 115	CFU 118
	lb/ton glass				
<b>Dichlorodifluoromethane</b>	< 8.82E-04	< 4.70E-04	< 4.05E-05	< 5.72E-03	< 2.99E-03
<i>Chloromethane</i>	< 3.68E-04	< 1.96E-04	< 1.69E-05	4.08E-02	3.84E-03
<b>Freon 114</b>	< 1.25E-03	< 6.64E-04	< 5.72E-05	< 8.09E-03	< 4.22E-03
<i>Vinyl chloride</i>	< 4.56E-04	< 2.43E-04	< 2.09E-05	< 2.96E-03	< 1.54E-03
<i>1,3-Butadiene</i>	< 3.95E-04	< 2.21E-04	5.79E-04	< 2.56E-03	< 1.34E-03
<i>Bromomethane</i>	< 6.93E-04	< 3.69E-04	< 3.18E-05	< 4.49E-03	< 2.35E-03
<b>Chloroethane</b>	< 4.71E-04	< 2.51E-04	< 2.16E-05	< 3.05E-03	< 1.59E-03
<b>Freon 11</b>	< 1.00E-03	< 5.34E-04	< 4.60E-05	< 6.50E-03	< 3.39E-03
<b>Freon 113</b>	< 1.37E-03	< 7.28E-04	< 6.27E-05	< 8.87E-03	< 4.63E-03
<b>1,1-Dichloroethene</b>	< 7.07E-04	< 3.77E-04	< 3.25E-05	< 4.59E-03	< 2.40E-03
Acetone	1.24E-02	1.92E-02	5.48E-03	4.31E-01	4.97E-02
<i>Carbon disulfide</i>	< 5.56E-04	< 2.96E-04	3.82E-05	< 3.60E-03	< 1.88E-03
<i>Methylene chloride</i>	< 6.20E-04	< 3.30E-04	< 2.84E-05	< 4.02E-03	< 2.10E-03
<b>trans-1,2-Dichloroethene</b>	< 7.07E-04	< 3.77E-04	< 3.25E-05	< 4.59E-03	< 2.40E-03
<b>Methyl t-butyl ether</b>	< 6.43E-04	< 3.42E-04	< 2.95E-05	< 4.17E-03	< 2.18E-03
<b>Vinyl acetate</b>	< 6.28E-04	< 3.34E-04	< 2.88E-05	< 4.07E-03	< 2.13E-03
<b>2-Butanone</b>	< 5.71E-04	< 7.83E-04	7.24E-05	1.37E-02	< 1.88E-03
cis-1,2-Dichloroethene	< 7.07E-04	< 3.77E-04	< 3.25E-05	< 4.59E-03	< 2.40E-03
<i>1,1-Dichloroethane</i>	< 7.22E-04	< 3.84E-04	< 3.31E-05	< 4.68E-03	< 2.45E-03
Ethyl acetate	< 1.29E-03	< 6.85E-04	< 5.90E-05	< 8.34E-03	< 4.35E-03
<b>Hexane</b>	2.00E-03	1.64E-02	7.89E-04	6.25E-01	4.86E-02
<b>Chloroform</b>	< 8.71E-04	< 4.64E-04	< 4.00E-05	< 5.65E-03	< 2.95E-03
Tetrahydrofuran	< 5.26E-04	< 2.80E-04	< 2.41E-05	< 3.41E-03	< 1.78E-03
1,2-Dichloroethane	< 7.22E-04	< 3.84E-04	< 3.31E-05	< 4.68E-03	< 2.45E-03
<b>1,1,1-Trichloroethane</b>	< 9.73E-04	< 5.18E-04	< 4.47E-05	< 6.31E-03	< 3.30E-03
<i>Carbon tetrachloride</i>	< 1.12E-03	< 5.98E-04	< 5.15E-05	< 7.28E-03	< 3.80E-03
<b>Benzene</b>	1.10E-03	4.24E-03	1.31E-03	1.08E-01	9.88E-03
<b>Cyclohexane</b>	< 6.14E-04	< 3.27E-04	< 2.82E-05	< 6.65E-03	< 2.08E-03
<i>Trichloroethene</i>	< 9.59E-04	< 5.10E-04	< 4.40E-05	< 6.22E-03	< 3.25E-03
<b>1,2-Dichloropropane</b>	< 8.24E-04	< 4.39E-04	< 3.78E-05	< 5.35E-03	< 2.79E-03
<b>Bromodichloromethane</b>	< 1.20E-03	< 6.36E-04	< 5.49E-05	< 7.75E-03	< 4.05E-03
Heptane	< 7.31E-04	1.59E-03	< 5.53E-05	4.16E-02	7.84E-03
<b>cis-1,3-Dichloropropene</b>	< 8.10E-04	< 4.31E-04	< 3.72E-05	< 5.25E-03	< 2.74E-03
4-Methyl-2-pentanone	< 7.31E-04	< 3.89E-04	< 3.35E-05	< 4.99E-03	< 2.47E-03
<b>trans-1,3-Dichloropropene</b>	< 8.10E-04	< 4.31E-04	< 3.72E-05	< 5.25E-03	< 2.74E-03
1,1,2-Trichloroethane	< 9.73E-04	< 5.18E-04	< 4.47E-05	< 6.31E-03	< 3.30E-03
<i>Toluene</i>	5.14E-03	1.26E-02	3.28E-04	1.09E-01	2.34E-02
2-Hexanone	< 1.46E-03	< 7.78E-04	< 6.71E-05	< 9.48E-03	< 4.95E-03
<b>Tetrachloroethene</b>	< 1.21E-03	< 6.44E-04	< 5.55E-05	< 7.85E-03	< 4.10E-03
<b>Dibromochloromethane</b>	< 1.52E-03	< 8.09E-04	< 6.97E-05	< 9.86E-03	< 5.15E-03
<i>1,2-Dibromoethane</i>	< 1.37E-03	< 7.30E-04	< 6.29E-05	< 8.89E-03	< 4.64E-03
<b>Chlorobenzene</b>	< 8.21E-04	< 4.37E-04	< 3.77E-05	< 5.33E-03	< 2.78E-03
<i>Ethyl benzene</i>	< 8.85E-04	< 4.62E-04	< 3.56E-05	< 5.66E-03	< 2.62E-03

## **APPENDIX F: M204 TEST DATA**

---



<b>COMPANY</b>	Hollingsworth & Vose
<b>FACILITY</b>	Glass Plant 1
<b>LOCATION</b>	Corvallis, Oregon
<b>SOURCE</b>	Raw Materials Handling
<b>DATE</b>	12/14/22
<b>METHOD</b>	204
<b>POLLUTANT</b>	PTE Verification

**Bison Engineering, Inc.**  
**Method 204 Field Data Summary**

**Client:** Hollingsworth & Vose  
**Source:** Glass Plant 1 - Raw Materials Handling  
**Location:** Corvallis, Oregon  
**Date:** 12/14/2022

Area Description	Pressure Differential	Pass/Fail
	inH <sub>2</sub> O	Press. Diff. ≤ -0.007 inH <sub>2</sub> O
North Man Door	-0.0275	Pass
NE Load In/Out Door	-0.0189	Pass
SE Load In/Out Door	-0.0164	Pass
Second Floor Load In/Out Door	-0.0271	Pass
Second Floor Man Door	-0.3319	Pass
<b>Average of all NDOs</b>	<b>-0.0843</b>	Pass

**Acceptance criteria per EPA Method 204, Section 8.3:**

The facial velocity (FV) shall be at least 3,600 m/hr (200 fpm).

Alternatively, pressure differential across the opening may be measured.

A pressure drop of 0.013 mmHg (0.007 inH<sub>2</sub>O) corresponds to a FV of 3,600 m/hr.

The average FV of air through all natural draft openings (NDOs) shall be at least 3,600 m/hr (200 fpm).

The direction of airflow through all NDOs shall be into the enclosure.

**Bison Engineering, Inc.**  
**Method 204 Field Data**

**Client:** Hollingsworth & Vose  
**Source:** Glass Plant 1 - Raw Materials Handling  
**Location:** Corvallis, Oregon  
**Date:** 12/14/2022

Area Description		North Man Door			NE Load In/Out Door			SE Load In/Out Door		
Time (mm:ss)		13:00	13:25	13:45	13:05	13:28	13:48	13:09	13:33	13:50
Units		Inches of H <sub>2</sub> O			Inches of H <sub>2</sub> O			Inches of H <sub>2</sub> O		
Readings	#1	-0.0429	-0.0221	-0.0187	-0.0128	-0.0270	-0.0175	-0.0258	-0.0241	-0.0095
	#2	-0.0546	-0.0131	-0.0196	-0.0092	-0.0208	-0.0199	-0.0110	-0.0212	-0.0117
	#3	-0.0321	-0.0182	-0.0517	-0.0136	-0.0256	-0.0188	-0.0162	-0.0180	-0.0157
	#4	-0.0319	-0.0194	-0.0136	-0.0156	-0.0230	-0.0158	-0.0129	-0.0203	-0.0119
	#5	-0.0325	-0.0179	-0.0247	-0.0161	-0.0225	-0.0247	-0.0195	-0.0164	-0.0119
<b>Average</b>		<b>-0.0388</b>	<b>-0.0181</b>	<b>-0.0257</b>	<b>-0.0135</b>	<b>-0.0238</b>	<b>-0.0193</b>	<b>-0.0171</b>	<b>-0.0200</b>	<b>-0.0121</b>
<b>Overall</b>			<b>-0.0275</b>			<b>-0.0189</b>			<b>-0.0164</b>	

Area Description		Second Floor Man Door			Second Floor Load In/Out Door		
Time (mm:ss)		13:19	13:40	13:59	13:14	13:37	13:54
Units		Inches of H <sub>2</sub> O			Inches of H <sub>2</sub> O		
Readings	#1	-0.1159	-0.1105	-0.3637	-0.0303	-0.0304	-0.0115
	#2	-0.2738	-0.1574	-0.5723	-0.0379	-0.0321	-0.0111
	#3	-0.3279	-0.0940	-0.6484	-0.0255	-0.0222	-0.0101
	#4	-0.3686	-0.0338	-0.7000	-0.0585	-0.0356	-0.0114
	#5	-0.4390	-0.0296	-0.7430	-0.0287	-0.0359	-0.0249
<b>Average</b>		<b>-0.3050</b>	<b>-0.0851</b>	<b>-0.6055</b>	<b>-0.0362</b>	<b>-0.0312</b>	<b>-0.0138</b>
<b>Overall</b>			<b>-0.3319</b>			<b>-0.0271</b>	


Average of all NDOs: -0.0843 Inches of H <sub>2</sub> O
--

Bison Engineering, Inc.


Method 204 Verification of Permanent Total Enclosure

Client: H&V Glass plant 1  
 Location: Cavalis OR  
 Enclosure: Raw materials handling  
 Date: 12-14-22

	Area	1- North Main Door			2- NE Load In/out Door			3- SE Load In/out Door			4- Second Floor Load In/out Door			
		Time	13:00	13:25	13:45	13:05	13:28	13:48	13:09	13:33	13:50	13:14	13:37	13:54
		Units	Inches of H <sub>2</sub> O			Inches of H <sub>2</sub> O			Inches of H <sub>2</sub> O			Inches of H <sub>2</sub> O		
Readings	#1	-0.0429	-0.0224	-0.0187	-0.0128	-0.0270	-0.0175	-0.0258	-0.0241	-0.0095	-0.0303	-0.0304	-0.0115	
	#2	-0.0546	-0.0131	-0.0196	-0.0092	-0.0208	-0.0199	-0.0110	-0.0212	-0.017	-0.0379	-0.0301	-0.0111	
	#3	-0.0321	-0.0182	-0.0517	-0.0136	-0.0256	-0.0198	-0.0162	-0.0180	-0.0157	-0.0255	-0.0222	-0.0101	
	#4	-0.0319	-0.0194	-0.036	-0.0156	-0.0230	-0.0158	-0.0129	-0.0203	-0.0119	-0.0385	-0.0352	-0.0114	
	#5	-0.0225	-0.0179	-0.0247	-0.0161	-0.0223	-0.0247	-0.0195	-0.0169	-0.0119	-0.0287	-0.0359	-0.0249	
	Area	5- Second Floor MCA Door			6-			7-			8-			
		Time	13:19	13:40	13:59									
		Units	Inches of H <sub>2</sub> O			Inches of H <sub>2</sub> O			Inches of H <sub>2</sub> O			Inches of H <sub>2</sub> O		
Readings	#1	-0.1159	-0.1105	-0.3137										
	#2	-0.2738	-0.1574	-0.5723										
	#3	-0.3229	-0.0940	-0.6484										
	#4	-0.3686	-0.0328	-0.9000										
	#5	-0.4590	-0.0596	-0.7430										



# Second Floor





## **APPENDIX G: LABORATORY REPORTS**

---

**Client:**

EPA Method TO-15  
Speciated Organics

Source: CFV109

Process Description:

---

Run 1

Date: 12/13/22  
Cannister ID: 0475 (1460) / 000896  
Start: 14:30  
Stop: 15:30

Time	Pressure (Inches HG)
14:30	30
14:40	29
14:50	27
15:00	20
15:10	15
15:20	10
15:30	5

Notes:

Run 2

Date: 12/13/22  
Cannister ID: 0443 (14752) / 1185  
Start: 15:40  
Stop: 16:40

Time	Pressure (Inches HG)
15:40	30
15:50	27
16:00	24
16:10	17
16:20	12
16:30	8
16:40	4

Notes:

Run 3

Date: 12/13/22  
Cannister ID: 0302 (14572) / 0256  
Start: 16:50  
Stop: 17:50

Time	Pressure (Inches HG)
16:50	26
17:00	23
17:10	15
17:20	9
17:30	4
17:40	3
17:50	2

Notes:

**Client:**

EPA Method TO-15  
Speciated Organics

Source: LF0112  
Process Description:

---

Run 1

Date: 12/13/22  
Cannister ID: 1213(35611)/0427  
Start: 1035  
Stop: 11:35

Time	Pressure (Inches HG)
1035	30
1045	29
1055	27
1105	21
1110	16
1115	12
1125	7

Notes:

Run 2

Date: 12/13/22  
Cannister ID: 8001677(35624)/1162  
Start: 11:45-12:45  
Stop: 12:45

Time	Pressure (Inches HG)
11:45	29
11:55	25
12:05	21
12:15	17
12:25	13
12:35	8
12:45	4

Notes:

Run 3

Date: 12/13/22  
Cannister ID: 0334(4763)/1044  
Start: 1300  
Stop: 1400

Time	Pressure (Inches HG)
1300	29
1310	26
1320	17
1330	13
1340	11
1350	8
1400	3

Notes:

**Client:**

EPA Method TO-15  
Speciated Organics

Source: CFU113

Process Description:

Run 1

Date: 12/13/22 (0257)  
Cannister ID: 54: 3755/06388  
Start: 06:55  
Stop: 07:55

Time	Pressure (Inches Hg)
06:55	30.0
07:05	27
07:15	22
07:15	17
07:35	12
07:45	8
07:55	2

Notes:

Run 2

Date: 12/13/22  
Cannister ID: 0448/0090 (0048)/0090  
Start: 08:05  
Stop: 09:05

Time	Pressure (Inches Hg)
08:05	30
08:15	29
08:25	25
08:35	20
08:45	16
08:55	13
09:05	9

Notes:

Run 3

Date: 12/13/22  
Cannister ID: 1459 (44002)/0393  
Start: 09:20  
Stop: 10:20

12/13

Time	Pressure (Inches Hg)
09:20	29
09:30	27
09:40	23
09:50	18
10:00	11
10:10	10
10:20	6

Notes:

**Client:**

EPA Method TO-15  
Speciated Organics

Source: CFV115

Process Description:

---

Run 1

Date: 12/14/22  
Cannister ID: 0377(4762) / 001148  
Start: 0900  
Stop: 0900

Time	Pressure (Inches Hg)
0900	30
0910	28
0920	19
0930	15
0940	10
0950	7
0900	5

Notes:

Run 2

Date: 12/14/22  
Cannister ID: 1222(35519) / 001149  
Start: 0910  
Stop: 1010

Time	Pressure (Inches Hg)
0910	29
0920	26
0930	22
0940	17
0950	14
1000	9
1010	5

Notes:

Run 3

Date: 12/14/22  
Cannister ID: 0294(4770) / 0886  
Start: 10:20  
Stop: 11:20

Time	Pressure (Inches Hg)
10:20	30
10:30	27
10:40	24
10:50	19
11:00	15
11:10	10
11:20	5

Notes:

**Client:**

EPA Method TO-15  
Speciated Organics

Source: CFU115 - ROAD 2

Process Description:

Run 4

Date: 12/14/22  
Cannister ID: 0298 (4801) / 0464  
Start: 1305  
Stop: 1405

Time	Pressure (Inches HG)
1305	24
1315	21
1325	19
1335	17 @ 15
1345	11
1355	8
1405	6

Notes:

▶ MTR 12/14

Run 5

Date: 12/14/22  
Cannister ID: 0806 (21261) / 1011  
Start: 1415  
Stop: 1515

Time	Pressure (Inches HG)
1415	30
1425	27
1435	24
1445	18
1455	15
1505	11
1515	7

Notes:

Run 6

Date: 12/14/22  
Cannister ID: 0856 (21128) / 1063  
Start: 1525  
Stop: 1625

Time	Pressure (Inches HG)
1525	20
1535	27
1545	25
1555	20
1605	15
1615	11
1625	6

Notes:

**Client:**

EPA Method TO-15  
Speciated Organics

Source: CFU119

Process Description:

---

Run 1

Date: 12/15/22  
Cannister ID: 1263 (36674) / 0717  
Start: 0820  
Stop: 0920

Time	Pressure (Inches Hg)
0820	14
0830	14
0840	14
0850	14
0900	13
0910	9
0920	3

Notes:

Run 2

Date: 12/16/22  
Cannister ID: 0537 (4612) / 1182  
Start: 0930  
Stop: 1030

Time	Pressure (Inches Hg)
0930	30
0940	27
0950	23
1000	19
1010	15
1020	10
1030	5

Notes:

Run 3

Date: 12/15/22  
Cannister ID: 0662 (20848) / 1034  
Start: 1040  
Stop: 1140

Time	Pressure (Inches Hg)
1040	27
1050	25
1100	21
1110	17
1120	13
1130	7
1140	7

Notes:



# ANALYTICAL REPORT

Report Date: January 05, 2023

Conor Fox  
Bison Engineering  
3143 E Lyndale Ave.  
Helena, MT 59601

Phone: 406-442-5768

E-mail: cfox@bison-eng.com

Workorder: **34-2236123**

Project ID: HAV222965

Purchase Order: HAV216269/HAV222965

Project Manager Jessica Cofrancesco

Client Sample ID	Lab ID	Collect Date	Receive Date	Sampling Site
CFU113 Run 2	2236123001	NA	12/27/22	HAV222965
CFU113 Run 1	2236123002	NA	12/27/22	HAV222965
CFU112 Run 1	2236123003	NA	12/27/22	HAV222965
CFU113 Run 3	2236123004	NA	12/27/22	HAV222965
CFU112 Run 3	2236123005	NA	12/27/22	HAV222965
CFU108 Run 2	2236123006	NA	12/27/22	HAV222965
CFU112 Run 2	2236123007	NA	12/27/22	HAV222965
CFU108 Run 1	2236123008	NA	12/27/22	HAV222965
CFU118 Run 3	2236123009	NA	12/27/22	HAV222965
CFU118 Run 1	2236123010	NA	12/27/22	HAV222965
CFU115 Run 6	2236123011	NA	12/27/22	HAV222965
CFU118 Run 2	2236123012	NA	12/27/22	HAV222965
CFU115 Run 2	2236123013	NA	12/27/22	HAV222965
CFU115 Run 5	2236123014	NA	12/27/22	HAV222965
CFU115 Run 4	2236123015	NA	12/27/22	HAV222965
CFU115 Run 3	2236123016	NA	12/27/22	HAV222965
CFU108 Run 3	2236123017	NA	12/27/22	HAV222965
CFU115 Run 1	2236123018	NA	12/27/22	HAV222965





# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU113 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123001	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/04/2023 18:36	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<0.50	<1.0	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<b>17</b>	<b>37</b>	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>94</b>	<b>220</b>	1.0	1	E
Carbon disulfide	<b>0.80</b>	<b>2.5</b>	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>1.7</b>	<b>5.0</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>12</b>	<b>44</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>28</b>	<b>89</b>	0.50	1	E
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>0.70</b>	<b>2.9</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU113 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123001	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 18:36	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>4.4</b>	<b>17</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 18:36	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propene	88	4.70	1	J
Acetaldehyde	34	5.06	1	J
2-Butene	41	5.28	1	J
Butane	12	5.36	1	J
1-Propene, 2-methyl-	5.8	5.47	1	J
Cyclopropane, ethyl-	13	6.63	1	J
Pentane	8.1	6.86	1	J
1,2-Pentadiene	7.1	6.96	1	J



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU113 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022		
Lab ID: 2236123001	Media: Summa 6 Liter Canister			
Matrix: Air	Sampling Parameter: NA			
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>				
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 18:36	Instrument ID: 5975-J		
<b>Tentatively Identified Compound</b>	<b>Result (ppb)</b>	<b>Retention Time</b>	<b>Dilution</b>	<b>Qual</b>
3-Penten-1-yne	14	7.62	1	J
1-Propene, 2-methyl-	24	9.00	1	J

Sample ID: <b>CFU113 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022			
Lab ID: 2236123002	Media: Summa 6 Liter Canister				
Matrix: Air	Sampling Parameter: NA				
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>					
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 19:16	Instrument ID: 5975-J			
<b>Analyte</b>	<b>Result (ppb)</b>	<b>Result (ug/m<sup>3</sup>)</b>	<b>RL (ppb)</b>	<b>Dilution</b>	<b>Qual</b>
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<0.50	<1.0	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<b>16</b>	<b>36</b>	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>250</b>	<b>590</b>	1.0	1	E
Carbon disulfide	<b>0.77</b>	<b>2.4</b>	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>0.87</b>	<b>2.6</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>20</b>	<b>70</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU113 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123002	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/04/2023 19:16	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>18</b>	<b>57</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<0.50	<2.0	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>0.96</b>	<b>3.6</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU113 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123002	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/04/2023 19:16	

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propene	81	4.70	1	J
Acetaldehyde	31	5.06	1	J
2-Butene	40	5.28	1	J
Butane	10	5.38	1	J
Cyclopropane, ethyl-	12	6.63	1	J
Pentane	8.4	6.86	1	J
3-Penten-1-yne, (E)-	12	7.62	1	J
1-Hexene	19	9.00	1	J
Pentane, 2,4-dimethyl-	8.4	10.17	1	J
Butane, 2,2,3,3-tetramethyl-	19	11.86	1	J

Sample ID: <b>CFU112 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123003	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/04/2023 19:55	

Analyte	Result (ppb)	Result (ug/m³)	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<0.50	<1.0	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<b>0.58</b>	<b>1.3</b>	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>67</b>	<b>160</b>	1.0	1	E
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU112 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123003	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/04/2023 19:55	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>2.3</b>	<b>6.9</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>47</b>	<b>160</b>	0.50	1	E
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>12</b>	<b>38</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>3.8</b>	<b>16</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>31</b>	<b>120</b>	0.50	1	E
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<b>0.68</b>	<b>3.0</b>	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	



# ANALYTICAL REPORT

**Workorder:** 34-2236123

**Client:** Bison Engineering

**Project Manager:** Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU112 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123003	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 19:55	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 19:55	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	15	4.72	1	J
Isobutane	11	5.07	1	J
Butane	9.0	5.38	1	J
Pentane	20	6.86	1	J
2-Pentene, (E)-	4.2	7.00	1	J
Pentane, 2-methyl-	7.9	8.48	1	J
1-Pentene, 4-methyl-	7.8	10.17	1	J
Pentane, 2,3-dimethyl-	5.6	11.29	1	J
1-Heptene	3.9	11.78	1	J
Pentane, 2,2,4-trimethyl-	7.2	11.86	1	J

Sample ID: <b>CFU113 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123004	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 20:34	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<0.50	<1.0	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU113 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123004	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 20:34	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<b>15</b>	<b>33</b>	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>66</b>	<b>160</b>	1.0	1	E
Carbon disulfide	<b>0.68</b>	<b>2.1</b>	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>2.0</b>	<b>6.0</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>8.3</b>	<b>29</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>30</b>	<b>97</b>	0.50	1	E
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>1.3</b>	<b>5.5</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>11</b>	<b>43</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	





# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU113 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123004	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 20:34	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,1,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 20:34	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propene	83	4.70	1	J
Acetaldehyde	36	5.06	1	J
1-Propene, 2-methyl-	35	5.28	1	J
Butane	10	5.38	1	J
1-Butene	5.8	5.47	1	J
1-Propene, 2-methyl-	5.2	5.64	1	J
Cyclopropane, ethyl-	11	6.63	1	J
Pentane	5.2	6.86	1	J
1-Hexene	22	9.00	1	J
1-Heptene	7.0	11.78	1	J



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU112 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123005	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/04/2023 21:14	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<0.50	<1.0	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>15</b>	<b>35</b>	1.0	1	
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<0.50	<1.5	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>4.8</b>	<b>17</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>1.7</b>	<b>5.4</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>0.55</b>	<b>2.3</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU112 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123005	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 21:14	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>5.9</b>	<b>22</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 21:14	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	7.5	4.72	1	J
Isobutane	4.2	5.07	1	J
Butane	3.5	5.38	1	J
Pentane	3.6	6.86	1	J



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU108 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123006	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/04/2023 21:53	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<0.50	<1.0	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>11</b>	<b>26</b>	1.0	1	
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<0.50	<1.5	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>1.3</b>	<b>4.5</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>0.65</b>	<b>2.1</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<0.50	<2.0	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU108 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123006	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 21:53	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>2.3</b>	<b>8.8</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 21:53	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	7.6	4.72	1	J
Isobutane	4.0	5.07	1	J
Butane	2.4	5.38	1	J
Pentane	2.0	6.86	1	J
Cyclohexanone	2.0	16.33	1	J



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU112 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123007	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/04/2023 22:32	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<0.50	<1.0	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>46</b>	<b>110</b>	1.0	1	E
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>1.4</b>	<b>4.1</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>22</b>	<b>76</b>	0.50	1	E
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>7.3</b>	<b>23</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>1.8</b>	<b>7.4</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU112 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123007	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 22:32	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>16</b>	<b>59</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 22:32	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	11	4.72	1	J
Isobutane	6.6	5.07	1	J
Butane	6.5	5.38	1	J
Pentane	13	6.86	1	J
Cyclopropane, 1,2-dimethyl-, trans-	2.9	7.00	1	J
1-Butene, 3-methyl-	2.2	7.27	1	J
Pentane, 2-methyl-	4.6	8.48	1	J
1-Pentene, 4-methyl-	4.2	10.17	1	J



# ANALYTICAL REPORT

**Workorder:** 34-2236123

**Client:** Bison Engineering

**Project Manager:** Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU112 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022		
Lab ID: 2236123007	Media: Summa 6 Liter Canister			
Matrix: Air	Sampling Parameter: NA			
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>				
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 22:32	Instrument ID: 5975-J		
Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Pentane, 2,3-dimethyl-	3.6	11.29	1	J
Butane, 2,2,3,3-tetramethyl-	4.2	11.86	1	J

Sample ID: <b>CFU108 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022			
Lab ID: 2236123008	Media: Summa 6 Liter Canister				
Matrix: Air	Sampling Parameter: NA				
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>					
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 23:12	Instrument ID: 5975-J			
Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<0.50	<1.0	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>24</b>	<b>57</b>	1.0	1	E
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>0.63</b>	<b>1.8</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>2.8</b>	<b>9.7</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	





# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU108 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123008	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/04/2023 23:12	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>1.7</b>	<b>5.6</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<0.50	<2.0	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>7.5</b>	<b>28</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<b>0.72</b>	<b>3.1</b>	0.50	1	
m,p-Xylene	<b>2.1</b>	<b>9.1</b>	1.0	1	
o-Xylene	<b>0.94</b>	<b>4.1</b>	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU108 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022		
Lab ID: 2236123008	Media: Summa 6 Liter Canister			
Matrix: Air	Sampling Parameter: NA			
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>				
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 23:12	Instrument ID: 5975-J		
Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	9.1	4.72	1	J
Unknown Compound	2.5	4.84	1	J
Isobutane	5.5	5.07	1	J
Butane	2.7	5.38	1	J
Pentane	3.2	6.86	1	J
Hexane, 2,2-dimethyl-	2.9	11.86	1	J

Sample ID: <b>CFU118 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022			
Lab ID: 2236123009	Media: Summa 6 Liter Canister				
Matrix: Air	Sampling Parameter: NA				
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>					
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 23:50	Instrument ID: 5975-J			
Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<b>1.3</b>	<b>2.8</b>	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>16</b>	<b>39</b>	1.0	1	
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<0.50	<1.5	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU118 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123009	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/04/2023 23:50	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>10</b>	<b>36</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>2.2</b>	<b>6.9</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>2.2</b>	<b>9.2</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>5.9</b>	<b>22</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU118 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123009	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 23:50	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/04/2023 23:50	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	23	4.72	1	J
Isobutane	9.1	5.07	1	J
Butane	6.2	5.38	1	J
Pentane	6.7	6.86	1	J
Pentane, 2-methyl-	3.2	8.48	1	J
1-Pentene, 4-methyl-	5.2	10.17	1	J
Pentane, 2,3-dimethyl-	6.1	11.29	1	J
Butane, 2,2,3,3-tetramethyl-	14	11.86	1	J
Pentane, 2,3,4-trimethyl-	2.8	13.51	1	J
Heptane, 2,4-dimethyl-	2.6	15.22	1	J

Sample ID: <b>CFU118 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123010	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 00:30	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<b>1.3</b>	<b>2.7</b>	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU118 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123010	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 00:30	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>23</b>	<b>55</b>	1.0	1	E
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>0.58</b>	<b>1.7</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>17</b>	<b>60</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>3.8</b>	<b>12</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>1.8</b>	<b>7.3</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>6.4</b>	<b>24</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU118 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123010	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 00:30	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 00:30	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	32	4.72	1	J
Isobutane	12	5.07	1	J
Butane	10	5.38	1	J
Butane, 2-methyl-	8.9	6.38	1	J
Pentane	15	6.86	1	J
Butane, 2,3-dimethyl-	3.2	8.40	1	J
Pentane, 2-methyl-	6.1	8.48	1	J
Pentane, 2,4-dimethyl-	8.2	10.17	1	J
Pentane, 2,3-dimethyl-	7.2	11.29	1	J
Butane, 2,2,3,3-tetramethyl-	8.9	11.86	1	J



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 6</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123011	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/05/2023 01:09	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<b>5.4</b>	<b>11</b>	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>51</b>	<b>120</b>	1.0	1	E
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>1.4</b>	<b>4.3</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>79</b>	<b>280</b>	0.50	1	E
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>13</b>	<b>41</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>8.3</b>	<b>34</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 6</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123011	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 01:09	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>21</b>	<b>78</b>	0.50	1	E
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<b>0.69</b>	<b>3.0</b>	0.50	1	
m,p-Xylene	<b>1.5</b>	<b>6.3</b>	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 01:09	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	30	4.72	1	J
Isobutane	29	5.07	1	J
Butane	22	5.38	1	J
Butane, 2-methyl-	23	6.38	1	J
Pentane	45	6.86	1	J
Butane, 2,3-dimethyl-	12	8.40	1	J
Pentane, 2-methyl-	25	8.48	1	J
Pentane, 2,4-dimethyl-	40	10.17	1	J





# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 6</b>	Sampling Site: HAV222965	Received: 12/27/2022		
Lab ID: 2236123011	Media: Summa 6 Liter Canister			
Matrix: Air	Sampling Parameter: NA			
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>				
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 01:09	Instrument ID: 5975-J		
<b>Tentatively Identified Compound</b>	<b>Result (ppb)</b>	<b>Retention Time</b>	<b>Dilution</b>	<b>Qual</b>
Pentane, 2,3-dimethyl-	32	11.29	1	J
Butane, 2,2,3,3-tetramethyl-	53	11.86	1	J

Sample ID: <b>CFU118 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022			
Lab ID: 2236123012	Media: Summa 6 Liter Canister				
Matrix: Air	Sampling Parameter: NA				
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>					
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 01:48	Instrument ID: 5975-J			
<b>Analyte</b>	<b>Result (ppb)</b>	<b>Result (ug/m<sup>3</sup>)</b>	<b>RL (ppb)</b>	<b>Dilution</b>	<b>Qual</b>
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<b>2.0</b>	<b>4.1</b>	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>13</b>	<b>30</b>	1.0	1	
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<0.50	<1.5	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>7.3</b>	<b>26</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU118 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123012	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/05/2023 01:48	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>1.7</b>	<b>5.4</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>0.78</b>	<b>3.2</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>3.2</b>	<b>12</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU118 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123012	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 01:48	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	19	4.72	1	J
Isobutane	10	5.07	1	J
Butane	7.0	5.38	1	J
Pentane	6.9	6.86	1	J
Pentane, 2-methyl-	2.6	8.48	1	J
Pentane, 2,4-dimethyl-	3.2	10.17	1	J
Pentane, 2,3-dimethyl-	3.3	11.29	1	J
Butane, 2,2,3,3-tetramethyl-	4.0	11.86	1	J

Sample ID: <b>CFU115 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123013	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 02:28	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<b>0.51</b>	<b>1.0</b>	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>25</b>	<b>58</b>	1.0	1	E
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>0.69</b>	<b>2.0</b>	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123013	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/05/2023 02:28	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>13</b>	<b>45</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>4.8</b>	<b>15</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>2.3</b>	<b>9.4</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>18</b>	<b>68</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<b>0.97</b>	<b>4.2</b>	0.50	1	
m,p-Xylene	<b>2.7</b>	<b>12</b>	1.0	1	
o-Xylene	<b>0.94</b>	<b>4.1</b>	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 2</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123013	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 02:28	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 02:28	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	20	4.72	1	J
Isobutane	12	5.07	1	J
Butane	10	5.38	1	J
Pentane	15	6.86	1	J
Pentane, 2-methyl-	7.7	8.48	1	J
C6 Hydrocarbon	2.9	8.87	1	J
Pentane, 2,4-dimethyl-	6.6	10.17	1	J
Hexane, 2-methyl-	2.7	11.21	1	J
Pentane, 2,3-dimethyl-	6.5	11.29	1	J
Butane, 2,2,3,3-tetramethyl-	6.8	11.86	1	J

Sample ID: <b>CFU115 Run 5</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123014	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 10:05	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<b>3.2</b>	<b>6.6</b>	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 5</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123014	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/05/2023 10:05	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>44</b>	<b>100</b>	1.0	1	E
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>1.5</b>	<b>4.4</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>79</b>	<b>280</b>	0.50	1	E
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>15</b>	<b>47</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>2.9</b>	<b>12</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>9.7</b>	<b>36</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 5</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123014	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 10:05	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 10:05	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	34	4.72	1	J
Isobutane	28	5.07	1	J
Butane	26	5.36	1	J
Butane, 2-methyl-	37	6.37	1	J
Pentane	73	6.86	1	J
Butane, 2,3-dimethyl-	19	8.40	1	J
Pentane, 2-methyl-	42	8.48	1	J
Pentane, 2,4-dimethyl-	44	10.17	1	J
Pentane, 2,3-dimethyl-	31	11.29	1	J
Hexane, 2,2-dimethyl-	39	11.86	1	J



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 4</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123015	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/05/2023 10:43	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<b>17</b>	<b>35</b>	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<b>0.50</b>	<b>1.3</b>	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>140</b>	<b>320</b>	1.0	1	E
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>3.1</b>	<b>9.1</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>72</b>	<b>250</b>	0.50	1	E
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>16</b>	<b>51</b>	0.50	1	
Cyclohexane	<b>1.5</b>	<b>5.2</b>	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>2.0</b>	<b>8.2</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<b>0.58</b>	<b>2.4</b>	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	





# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 4</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123015	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 10:43	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>7.0</b>	<b>26</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 10:43	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Butane, 2-methyl-	11	6.37	1	J
Pentane	19	6.86	1	J
Pentane, 2-methyl-	8.8	8.48	1	J
Pentane, 2,4-dimethyl-	6.4	10.17	1	J
Pentane, 2,3-dimethyl-	31	11.29	1	J
Butane, 2,2,3,3-tetramethyl-	40	11.86	1	J
Disulfide, dimethyl	19	12.93	1	J
o-Cymene	41	19.30	1	J



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123016	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/05/2023 11:22	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<b>0.56</b>	<b>1.2</b>	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>22</b>	<b>52</b>	1.0	1	E
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>0.87</b>	<b>2.6</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>8.3</b>	<b>29</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>3.8</b>	<b>12</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>1.5</b>	<b>6.2</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123016	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 11:22	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>15</b>	<b>55</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<b>0.91</b>	<b>4.0</b>	0.50	1	
m,p-Xylene	<b>2.9</b>	<b>12</b>	1.0	1	
o-Xylene	<b>1.0</b>	<b>4.5</b>	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 11:22	Instrument ID: 5975-J
-----------------------------	--	-----------------------

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	25	4.72	1	J
Unknown Compound	2.0	4.84	1	J
Isobutane	12	5.07	1	J
Butane	8.6	5.38	1	J
Pentane	11	6.86	1	J
Pentane, 2-methyl-	5.5	8.48	1	J
C6 Hydrocarbon	2.1	8.87	1	J
Pentane, 2,4-dimethyl-	4.8	10.17	1	J



# ANALYTICAL REPORT

**Workorder:** 34-2236123

**Client:** Bison Engineering

**Project Manager:** Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022		
Lab ID: 2236123016	Media: Summa 6 Liter Canister			
Matrix: Air	Sampling Parameter: NA			
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>				
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 11:22	Instrument ID: 5975-J		
Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Pentane, 2,3-dimethyl-	4.5	11.29	1	J
Butane, 2,2,3,3-tetramethyl-	4.9	11.86	1	J

Sample ID: <b>CFU108 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022			
Lab ID: 2236123017	Media: Summa 6 Liter Canister				
Matrix: Air	Sampling Parameter: NA				
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>					
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 12:01	Instrument ID: 5975-J			
Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<0.50	<1.0	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>9.3</b>	<b>22</b>	1.0	1	
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<0.50	<1.5	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>0.71</b>	<b>2.5</b>	0.50	1	
Chloroform	<0.50	<2.4	0.50	1	
Tetrahydrofuran	<0.50	<1.5	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU108 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123017	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/05/2023 12:01	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>0.56</b>	<b>1.8</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<0.50	<2.0	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>1.8</b>	<b>7.0</b>	0.50	1	
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<0.50	<2.2	0.50	1	
m,p-Xylene	<1.0	<4.3	1.0	1	
o-Xylene	<0.50	<2.2	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU108 Run 3</b>	Sampling Site: HAV222965	Received: 12/27/2022		
Lab ID: 2236123017	Media: Summa 6 Liter Canister			
Matrix: Air	Sampling Parameter: NA			
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>				
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 12:01	Instrument ID: 5975-J		
Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	7.7	4.72	1	J
Isobutane	4.1	5.07	1	J
Butane	2.2	5.36	1	J

Sample ID: <b>CFU115 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022			
Lab ID: 2236123018	Media: Summa 6 Liter Canister				
Matrix: Air	Sampling Parameter: NA				
<b>Analysis Method - EPA TO-15 by IH-AN-014</b>					
Preparation: Not Applicable	Analysis: EPA TO-15, Air Batch: IVOA/6039 (HBN: 302293) Analyzed: 01/05/2023 12:41	Instrument ID: 5975-J			
Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Dichlorodifluoromethane	<0.50	<2.5	0.50	1	
Chloromethane	<b>0.67</b>	<b>1.4</b>	0.50	1	
Freon 114	<0.50	<3.5	0.50	1	
Vinyl chloride	<0.50	<1.3	0.50	1	
1,3-Butadiene	<0.50	<1.1	0.50	1	
Bromomethane	<0.50	<1.9	0.50	1	
Chloroethane	<0.50	<1.3	0.50	1	
Freon 11	<0.50	<2.8	0.50	1	
Freon 113	<0.50	<3.8	0.50	1	
1,1-Dichloroethene	<0.50	<2.0	0.50	1	
Acetone	<b>54</b>	<b>130</b>	1.0	1	E
Carbon disulfide	<0.50	<1.6	0.50	1	
Methylene chloride	<0.50	<1.7	0.50	1	
trans-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
Methyl t-butyl ether	<0.50	<1.8	0.50	1	
Vinyl acetate	<0.50	<1.8	0.50	1	
2-Butanone	<b>1.1</b>	<b>3.2</b>	0.50	1	
cis-1,2-Dichloroethene	<0.50	<2.0	0.50	1	
1,1-Dichloroethane	<0.50	<2.0	0.50	1	
Ethyl acetate	<1.0	<3.6	1.0	1	
Hexane	<b>32</b>	<b>110</b>	0.50	1	E
Chloroform	<0.50	<2.4	0.50	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123018	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/05/2023 12:41	

Analyte	Result (ppb)	Result (ug/m <sup>3</sup> )	RL (ppb)	Dilution	Qual
Tetrahydrofuran	<0.50	<1.5	0.50	1	
1,2-Dichloroethane	<0.50	<2.0	0.50	1	
1,1,1-Trichloroethane	<0.50	<2.7	0.50	1	
Carbon tetrachloride	<0.50	<3.1	0.50	1	
Benzene	<b>9.5</b>	<b>30</b>	0.50	1	
Cyclohexane	<0.50	<1.7	0.50	1	
Trichloroethene	<0.50	<2.7	0.50	1	
1,2-Dichloropropane	<0.50	<2.4	0.50	1	
Bromodichloromethane	<0.50	<3.4	0.50	1	
Heptane	<b>3.6</b>	<b>15</b>	0.50	1	
cis-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
4-Methyl-2-pentanone	<0.50	<2.0	0.50	1	
trans-1,3-Dichloropropene	<0.50	<2.3	0.50	1	
1,1,2-Trichloroethane	<0.50	<2.7	0.50	1	
Toluene	<b>23</b>	<b>87</b>	0.50	1	E
2-Hexanone	<1.0	<4.1	1.0	1	
Tetrachloroethene	<0.50	<3.4	0.50	1	
Dibromochloromethane	<0.50	<4.3	0.50	1	
1,2-Dibromoethane	<0.50	<3.8	0.50	1	
Chlorobenzene	<0.50	<2.3	0.50	1	
Ethyl benzene	<b>1.0</b>	<b>4.4</b>	0.50	1	
m,p-Xylene	<b>3.2</b>	<b>14</b>	1.0	1	
o-Xylene	<b>1.1</b>	<b>5.0</b>	0.50	1	
Styrene	<1.0	<4.3	1.0	1	
Bromoform	<1.0	<10	1.0	1	
1,1,2,2-Tetrachloroethane	<0.50	<3.4	0.50	1	
4-Ethyl toluene	<1.0	<4.9	1.0	1	
1,3,5-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,2,4-Trimethylbenzene	<1.0	<4.9	1.0	1	
1,3-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,4-Dichlorobenzene	<1.0	<6.0	1.0	1	
Benzyl chloride	<1.0	<5.2	1.0	1	
1,2-Dichlorobenzene	<1.0	<6.0	1.0	1	
1,2,4-Trichlorobenzene	<1.0	<7.4	1.0	1	
Hexachlorobutadiene	<1.0	<11	1.0	1	



# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## Analytical Results

Sample ID: <b>CFU115 Run 1</b>	Sampling Site: HAV222965	Received: 12/27/2022
Lab ID: 2236123018	Media: Summa 6 Liter Canister	
Matrix: Air	Sampling Parameter: NA	

### Analysis Method - EPA TO-15 by IH-AN-014

Preparation: Not Applicable	Analysis: EPA TO-15, Air	Instrument ID: 5975-J
	Batch: IVOA/6039 (HBN: 302293)	
	Analyzed: 01/05/2023 12:41	

Tentatively Identified Compound	Result (ppb)	Retention Time	Dilution	Qual
Propane	24	4.72	1	J
Isobutane	18	5.07	1	J
Butane	18	5.38	1	J
Pentane	34	6.86	1	J
Pentane, 2-methyl-	18	8.48	1	J
Pentane, 3-methyl-	6.5	8.87	1	J
Pentane, 2,4-dimethyl-	16	10.17	1	J
Hexane, 2-methyl-	5.4	11.20	1	J
Pentane, 2,3-dimethyl-	14	11.29	1	J
Butane, 2,2,3,3-tetramethyl-	14	11.86	1	J

## Comments

### Quality Control: EPA TO-15 by IH-AN-014 - (Batch: 302293)

The percent difference for target compounds in the CCV standard must be less than 30% relative to the target. The following compounds did not meet this criteria: 2-Butanone, Ethyl Acetate, 4-methyl-2-Pentanone, 2-Hexanone, 4-ethyl Toluene, 1,2,4-Trimethylbenzene, Benzyl Chloride, 1,2-Dichlorobenzene, 1,2,4-Trichlorobenzene and Hexachloro-1,3-butadiene.

Not all compounds in the LCS/LCSD were within performance limits. This is not a method requirement.

## Report Authorization (/S/ is an electronic signature that complies with 21 CFR Part 11)

Method	Analyst	Peer Review
EPA TO-15 by IH-AN-014 (302293)	/S/ Paul Kelly 01/05/2023 13:14	/S/ Thomas J. Masoian 01/05/2023 14:44

## Laboratory Contact Information

ALS Environmental  
960 W Levoy Drive  
Salt Lake City, Utah 84123

Phone: (801) 266-7700  
Email: alsit.lab@ALSGlobal.com  
Web: www.alsglobal.com/slt





# ANALYTICAL REPORT

Workorder: **34-2236123**

Client: Bison Engineering

Project Manager: Jessica Cofrancesco

## General Lab Comments

The results provided in this report relate only to the items tested.  
 Samples were received in acceptable condition unless otherwise noted.  
 The following was provided by the client: Sample ID, Collection Date, Sampling Location, Media Type, Sampling Parameter.  
 Collection Date, Media Type, and Sampling Parameter can potentially affect the validity of the results.  
 Samples have not been blank corrected unless otherwise noted.  
 This test report shall not be reproduced, except in full, without written approval of ALS.

ALS provides professional analytical services for all samples submitted. ALS is not in a position to interpret the data and assumes no responsibility for the quality of the samples submitted.

All quality control samples processed with the samples in this report yielded acceptable results unless otherwise noted.

ALS is accredited for specific fields of testing (scopes) in the following testing sectors. The quality system implemented at ALS conforms to accreditation requirements and is applied to all analytical testing performed by ALS. The following table lists testing sector, accreditation body, accreditation number and website. Please contact these accrediting bodies or your ALS project manager for the current scope of accreditation that applies to your analytical testing.

Testing Sector	Accreditation Body (Standard)	Certificate Number	Website
Industrial Hygiene	AIHA (ISO 17025 & AIHA IHLAP)	101574	<a href="http://www.aihaaccreditedlabs.org">http://www.aihaaccreditedlabs.org</a>
	DOECAP-AP Washington	L22-62 C596	<a href="http://www.pjlabs.com">http://www.pjlabs.com</a> <a href="https://ecology.wa.gov/Regulations-Permits/Permits-certifications/Laboratory-Accreditation">https://ecology.wa.gov/Regulations-Permits/Permits-certifications/Laboratory-Accreditation</a>
Dietary Supplements	PJLA (ISO 17025)	L22-61	<a href="http://www.pjlabs.com">http://www.pjlabs.com</a>

## Result Symbol Definitions

MDL = Method Detection Limit, a statistical estimate of method/media/instrument sensitivity.  
 RL = Reporting Limit, a verified value of method/media/instrument sensitivity.  
 CRDL = Contract Required Detection Limit  
 Reg. Limit = Regulatory Limit.  
 ND = Not Detected, testing result not detected above the MDL or RL.  
 < Means this testing result is less than the numerical value.  
 \*\* No result could be reported, see sample comments for details.

## Qualifier Symbol Definitions

U = Qualifier indicates that the analyte was not detected above the MDL.  
 J = Qualifier Indicates that the analyte value is between the MDL and the RL. It is also used to indicate an estimated value for tentatively identified compounds in mass spectrometry where a 1:1 response is assumed.  
 B = Qualifier indicates that the analyte was detected in the blank.  
 E = Qualifier indicates that the analyte result exceeds calibration range.  
 P = Qualifier indicates that the RPD between the two columns is greater than 40%.  
 Q = Qualifier indicates that the analyte was outside the limits in a lab QC sample.

## **APPENDIX H: PLANT OPERATING RECORDS**

---

Table 1  
**December 2022 Source Test—Production Data**  
**Hollingsworth & Vose Fiber Company—Corvallis, OR**

Source Test	Product Type	Test ID	Test Time <sup>(1)</sup>	Production Rates (lb/hr)														
				CFU-113 <sup>(2)</sup>			CFU-112 <sup>(3)</sup>			CFU-108 <sup>(3)</sup>			CFU-115 <sup>(4)</sup>			CFU-118 <sup>(5)</sup>		
				L1	L2	Total	L2R4	L2R9	Total	L1R5	L1R6	Total	L4R3	L4R4	Total	L4R8	L4R9	Total
12/13/2022 CFU-113 Outlet	Glass Melt (GM)	Run 1	06:55 - 07:55	2,095.9	1,863.4	3,959.3	--	--	--	--	--	--	--	--	--	--	--	
		Run 2	08:05 - 09:05	2,107.0	2,036.4	4,143.4	--	--	--	--	--	--	--	--	--	--	--	
		Run 3	09:20 - 10:20	2,057.0	2,020.5	4,077.5	--	--	--	--	--	--	--	--	--	--	--	
		Average		2,086.6	1,973.4	4,060.0	--	--	--	--	--	--	--	--	--	--	--	
12/13/2022 CFU-112 Outlet	Ultra-Rotary Coarse (URC)	Run 1	10:35 - 11:35	--	--	--	354.0	346.8	700.8	--	--	--	--	--	--	--	--	
		Run 2	11:45 - 12:45	--	--	--	341.3	351.6	692.8	--	--	--	--	--	--	--	--	
		Run 3	13:00 - 14:00	--	--	--	354.7	345.2	700.0	--	--	--	--	--	--	--	--	
		Average		--	--	--	350.0	347.9	697.8	--	--	--	--	--	--	--	--	
12/13/2022 CFU-108 Outlet	Rotary Coarse (RC)	Run 1	14:30 - 15:30	--	--	--	--	--	--	189.7	196.0	385.7	--	--	--	--	--	
		Run 2	15:40 - 16:40	--	--	--	--	--	--	196.0	194.4	390.4	--	--	--	--	--	
		Run 3	16:50 - 17:50	--	--	--	--	--	--	192.1	188.1	380.1	--	--	--	--	--	
		Average		--	--	--	--	--	--	192.6	192.8	385.4	--	--	--	--	--	
12/14/2022 CFU-115 Outlet <sup>(6)</sup>	Flameblown (FB)	Run 4	13:05 - 14:05	--	--	--	--	--	--	--	--	--	31.5	31.5	63.0	--	--	
		Run 5	14:15 - 15:15	--	--	--	--	--	--	--	--	--	31.5	31.5	63.0	--	--	
		Run 6	15:25 - 16:25	--	--	--	--	--	--	--	--	--	31.5	31.5	63.0	--	--	
		Average		--	--	--	--	--	--	--	--	--	31.5	31.5	63.0	--	--	
12/15/2022 CFU-118 Outlet	Rotary Fine (RF)	Run 1	08:20 - 09:20	--	--	--	--	--	--	--	--	--	--	--	--	55.5	53.2	108.7
		Run 2	09:30 - 10:30	--	--	--	--	--	--	--	--	--	--	--	--	56.3	54.0	110.3
		Run 3	10:40 - 11:40	--	--	--	--	--	--	--	--	--	--	--	--	56.3	54.0	110.3
		Average		--	--	--	--	--	--	--	--	--	--	--	--	56.1	53.7	109.8

Notes

CFU = ceramic filtration unit.

hr = hour.

lb = pound.

References

<sup>(1)</sup> Information provided by Bison Engineering.

<sup>(2)</sup> Information provided by Hollingsworth & Vose Fiber Company. The hourly production rate represents the total of the average production rate at each position measured during the test run.

<sup>(3)</sup> Information provided by Hollingsworth & Vose Fiber Company. The hourly fiber pull rate represents the average pull rate measured during the test run.

<sup>(4)</sup> Information provided by Hollingsworth & Vose Fiber Company. Average pull rates from 12/14/2022.

<sup>(5)</sup> Information provided by Hollingsworth & Vose Fiber Company. Value represents the average pull rate measured before and after the test run.

<sup>(6)</sup> Only results from Runs 4 through 6 were used.

Table 2  
**December 2022 Source Test—Natural Gas Usage**  
**Hollingsworth & Vose Fiber Company—Corvallis, OR**

Source Test	Product Type	Test ID	Test Time <sup>(1)</sup>	Natural Gas Usage (cf/hr)														
				CFU-113 <sup>(2)</sup>			CFU-112 <sup>(3)</sup>			CFU-108 <sup>(3)</sup>			CFU-115 <sup>(3)</sup>			CFU-118 <sup>(3)</sup>		
				L1	L2	Total	L2R4	L2R9	Total	L1R5	L1R6	Total	L4R3	L4R4	Total	L4R8	L4R9	Total
12/13/2022 CFU-113 Outlet	Glass Melt (GM)	Run 1	06:55 - 07:55	--	--	--	--	--	--	--	--	--	--	--	--	--	--	
		Run 2	08:05 - 09:05	--	--	--	--	--	--	--	--	--	--	--	--	--	--	
		Run 3	09:20 - 10:20	--	--	--	--	--	--	--	--	--	--	--	--	--	--	
		Average		--	--	--	--	--	--	--	--	--	--	--	--	--	--	
12/13/2022 CFU-112 Outlet	Ultra-Rotary Coarse (URC)	Run 1	10:35 - 11:35	--	--	--	2,127.8	2,220.1	4,347.9	--	--	--	--	--	--	--	--	
		Run 2	11:45 - 12:45	--	--	--	2,125.7	2,216.9	4,342.6	--	--	--	--	--	--	--	--	
		Run 3	13:00 - 14:00	--	--	--	2,124.3	2,215.7	4,339.9	--	--	--	--	--	--	--	--	
		Average		--	--	--	2,125.9	2,217.6	4,343.5	--	--	--	--	--	--	--	--	
12/13/2022 CFU-108 Outlet	Rotary Coarse (RC)	Run 1	14:30 - 15:30	--	--	--	--	--	--	2,842.8	2,780.7	5,623.6	--	--	--	--	--	
		Run 2	15:40 - 16:40	--	--	--	--	--	--	2,827.2	2,795.4	5,622.6	--	--	--	--	--	
		Run 3	16:50 - 17:50	--	--	--	--	--	--	2,822.0	2,781.7	5,603.7	--	--	--	--	--	
		Average		--	--	--	--	--	--	2,830.7	2,785.9	5,616.6	--	--	--	--	--	
12/14/2022 CFU-115 Outlet <sup>(4)</sup>	Flameblown (FB)	Run 4	13:05 - 14:05	--	--	--	--	--	--	--	--	--	3,210.2	3,248.9	6,459.0	--	--	
		Run 5	14:15 - 15:15	--	--	--	--	--	--	--	--	--	3,202.6	3,245.9	6,448.5	--	--	
		Run 6	15:25 - 16:25	--	--	--	--	--	--	--	--	--	3,164.7	3,230.1	6,394.7	--	--	
		Average		--	--	--	--	--	--	--	--	--	3,192.5	3,241.6	6,434.1	--	--	
12/15/2022 CFU-118 Outlet	Rotary Fine (RF)	Run 1	08:20 - 09:20	--	--	--	--	--	--	--	--	--	--	--	--	2,594.7	2,557.4	5,152.1
		Run 2	09:30 - 10:30	--	--	--	--	--	--	--	--	--	--	--	--	2,574.0	2,549.3	5,123.4
		Run 3	10:40 - 11:40	--	--	--	--	--	--	--	--	--	--	--	--	2,577.7	2,557.6	5,135.3
		Average		--	--	--	--	--	--	--	--	--	--	--	--	2,582.1	2,554.8	5,136.9

Notes

cf = cubic feet.  
 CFU = ceramic filtration unit.  
 hr = hour.

References

- <sup>(1)</sup> Information provided by Bison Engineering.
- <sup>(2)</sup> Information provided by Hollingsworth & Vose Fiber Company. Hourly natural gas consumption rates for glass melt are not available.
- <sup>(3)</sup> Information provided by Hollingsworth & Vose Fiber Company. The hourly natural gas usage rate represents the average usage rate measured during the test run.
- <sup>(4)</sup> Only results from Runs 4 through 6 were used.

Table 3  
**December 2022 Source Test—Differential Pressure  
 Hollingsworth & Vose Fiber Company—Corvallis, OR**

Source Test	Product Type	Test ID	Test Time <sup>(1)</sup>	Differential Pressure <sup>(2)</sup> ("w.c.)
12/13/2022 CFU-113 Outlet	Glass Melt (GM)	Run 1	06:55 - 07:55	3.85
		Run 2	08:05 - 09:05	3.87
		Run 3	09:20 - 10:20	3.85
		Average		3.86
12/13/2022 CFU-112 Outlet	Ultra-Rotary Coarse (URC)	Run 1	10:35 - 11:35	4.39
		Run 2	11:45 - 12:45	4.39
		Run 3	13:00 - 14:00	4.39
		Average		4.39
12/13/2022 CFU-108 Outlet	Rotary Coarse (RC)	Run 1	14:30 - 15:30	6.70
		Run 2	15:40 - 16:40	7.52
		Run 3	16:50 - 17:50	7.81
		Average		7.35
12/14/2022 CFU-115 Outlet <sup>(3)</sup>	Flameblown (FB)	Run 4	13:05 - 14:05	4.10
		Run 5	14:15 - 15:15	4.08
		Run 6	15:25 - 16:25	4.08
		Average		4.09
12/15/2022 CFU-118 Outlet	Rotary Fine (RF)	Run 1	08:20 - 09:20	5.02
		Run 2	09:30 - 10:30	5.24
		Run 3	10:40 - 11:40	5.32
		Average		5.19

Notes

" w.c. = inches water column.

CFU = ceramic filtration unit.

References

<sup>(1)</sup> Information provided by Hollingsworth & Vose Fiber Company.

<sup>(2)</sup> Information provided by Hollingsworth & Vose Fiber Company. The hourly natural gas usage rate represents the average usage rate measured during the test run.

<sup>(3)</sup> Only results from Runs 4 through 6 were used.

## **APPENDIX I: CALIBRATIONS AND CERTIFICATIONS**

---

# *Accredited Air Emission Testing Body*

A2LA has accredited

## **BISON ENGINEERING, INC.**

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 27<sup>th</sup> day of January 2022 .



Vice President, Accreditation Services  
For the Accreditation Council  
Certificate Number 4675.01  
Valid to November 30, 2023

*This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.*

## APEX INSTRUMENTS METERBOX CALIBRATION USING REFERENCE DGM

Meter Console Information	
Console Model Number	C-5000
Console Serial Number	2029
DGM Model Number	SK25EX
DGM Serial Number	13966757

Calibration Conditions			
Date	Time	30-Oct-22	10:07
Barometric Pressure		26.15	in Hg
Calibration Technician		JCR	
Calibration Meter Gamma		1.0000	

Standardized Factors/Conversions		
Temperature	528	R
Pressure	29.92	in Hg
K <sub>1</sub>	17.647	R/in Hg

<<<<<<<Your reference meter here

Calibration Data											
Run Time	Metering Console						Reference Meter				
Elapsed	Manometer ΔH	Volume Initial	Volume Final	Sample Volume	Outlet Temp Initial	Outlet Temp Final	Volume Initial	Volume Final	Sample Volume	Outlet Temp Initial	Outlet Temp Final
Θ minutes	P <sub>m</sub> in H <sub>2</sub> O	V <sub>mi</sub> cubic feet	V <sub>mf</sub> cubic feet	V <sub>m</sub> cubic feet	t <sub>oi</sub> °F	t <sub>of</sub> °F	V <sub>wi</sub> cubic feet	V <sub>wf</sub> cubic feet	V <sub>w</sub> cubic feet	t <sub>wi</sub> °F	t <sub>wf</sub> °F
10.00	6.00	105.857	120.570	14.713	57	60	0.000	14.711	14.711	66	67
10.00	3.00	120.839	131.248	10.409	60	64	0.000	10.272	10.272	67	68
10.00	2.00	131.500	140.046	8.546	64	67	0.000	8.369	8.369	68	69
10.00	1.00	140.265	146.436	6.171	67	69	0.000	6.011	6.011	69	70
10.00	0.50	146.624	151.016	4.392	69	71	0.000	4.272	4.272	70	70

Results								
Standardized Data				Dry Gas Meter				
Dry Gas Meter		Calibration Meter		Calibration Factor		Flowrate	ΔH <sub>@</sub>	
V <sub>m(std)</sub> cubic feet	Q <sub>m(std)</sub> ft <sup>3</sup> /min	V <sub>w(std)</sub> cubic feet	Q <sub>w(std)</sub> ft <sup>3</sup> /min	Value	Variation	Std & Corr	0.75 SCFM	Variation
				Y	ΔY	Q <sub>m(std)(corr)</sub> ft <sup>3</sup> /min	ΔH <sub>@</sub> in H <sub>2</sub> O	ΔΔH <sub>@</sub>
13.316	1.332	12.894	1.289	0.9683	-0.001	1.289	1.808	-0.006
9.280	0.928	8.986	0.899	0.9683	-0.001	0.899	1.849	0.034
7.547	0.755	7.308	0.731	0.9683	-0.001	0.731	1.851	0.037
5.409	0.541	5.239	0.524	0.9686	0.000	0.524	1.793	-0.022
3.829	0.383	3.720	0.372	0.9713	0.002	0.372	1.771	-0.043
Pre-test Y	0.968	% Deviation	PASS	0.9690	Y Average		1.815	ΔH <sub>@</sub> Average

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

Note: For ΔH<sub>@</sub>, orifice pressure differential that equates to 0.75cfm (0.0212m<sup>3</sup>/min) at standard temperature and pressure, acceptable tolerance of individual values from the average is +/-0.2inches (5.1mm) H<sub>2</sub>O.

Initials JCR _____ JCR	Date 10/30/2022 _____ 30-Oct-22
---------------------------	------------------------------------



## APEX INSTRUMENTS METERBOX CALIBRATION USING REFERENCE DGM

Meter Console Information	
Console Model Number	C-5000
Console Serial Number	2029
DGM Model Number	SK25EX
DGM Serial Number	13966757

Calibration Conditions			
Date	Time	17-Dec-22	12:51
Barometric Pressure		25.92	in Hg
Calibration Technician		MTK	
Calibration Meter Gamma		1.0000	

Standardized Factors/Conversions		
Temperature	528	R
Pressure	29.92	in Hg
K <sub>1</sub>	17.647	R/in Hg

<<<<<<<Your reference meter here

Calibration Data											
Run Time	Metering Console						Reference Meter				
	Manometer	Volume	Volume	Sample	Outlet Temp	Outlet Temp	Volume	Volume	Sample	Outlet Temp	Outlet Temp
Elapsed	ΔH	Initial	Final	Volume	Initial	Final	Initial	Final	Volume	Initial	Final
Θ minutes	P <sub>m</sub> in H <sub>2</sub> O	V <sub>mi</sub> cubic feet	V <sub>mf</sub> cubic feet	V <sub>m</sub> cubic feet	t <sub>oi</sub> °F	t <sub>of</sub> °F	V <sub>wi</sub> cubic feet	V <sub>wf</sub> cubic feet	V <sub>w</sub> cubic feet	t <sub>wi</sub> °F	t <sub>wf</sub> °F
10.00	6.00	83.005	97.750	14.745	62	65	0.000	14.602	14.602	65	65
14.00	3.00	97.940	112.630	14.690	65	68	0.000	14.335	14.335	65	67
15.00	2.00	113.100	125.770	12.670	68	70	0.000	12.289	12.289	67	67
10.00	1.00	126.100	132.190	6.090	70	71	0.000	5.880	5.880	67	68
10.00	0.50	132.500	136.830	4.330	71	72	0.000	4.163	4.163	68	67

Results								
Standardized Data				Dry Gas Meter				
Dry Gas Meter		Calibration Meter		Calibration Factor		Flowrate	ΔH <sub>0</sub>	
				Value	Variation	Std & Corr	0.75 SCFM	Variation
V <sub>m(std)</sub> cubic feet	Q <sub>m(std)</sub> ft <sup>3</sup> /min	V <sub>w(std)</sub> cubic feet	Q <sub>w(std)</sub> ft <sup>3</sup> /min	Y	ΔY	Q <sub>m(std)(corr)</sub> ft <sup>3</sup> /min	ΔH <sub>0</sub> in H <sub>2</sub> O	ΔΔH <sub>0</sub>
13.103	1.310	12.722	1.272	0.9710	0.002	1.272	1.823	-0.042
12.871	0.919	12.465	0.890	0.9685	0.000	0.890	1.851	-0.014
11.018	0.735	10.666	0.711	0.9681	-0.001	0.711	1.925	0.060
5.266	0.527	5.099	0.510	0.9682	0.000	0.510	1.867	0.002
3.732	0.373	3.610	0.361	0.9674	-0.001	0.361	1.859	-0.006
Pre-test Y	0.9690	% Deviation	PASS	0.9686	Y Average		1.865	ΔH <sub>0</sub> Average

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.  
 Note: For ΔH<sub>0</sub>, orifice pressure differential that equates to 0.75cfm (0.0212m<sup>3</sup>/min) at standard temperature and pressure, acceptable tolerance of individual values from the average is +/-0.2inches (5.1mm) H<sub>2</sub>O.

Initials \_\_\_\_\_ MTK  
 MTK  
 Date \_\_\_\_\_ 17-Dec-22

# AIRDATA MULTIMETER CERTIFICATE OF RECALIBRATION

Customer ID: 022037 S/N: M16654  
 Customer: BISON ENGINEERING, INC. City: HELENA State: MT  
 As-Received Model #: ADM-850L Converted to Model #: \_\_\_\_\_ Order #: R213346  
 PO #: \_\_\_\_\_ Customer Eqpt ID#: \_\_\_\_\_ Calibration Due Date: 01/2024

This instrument has been calibrated using Calibration Standards which are traceable to NIST (National Institute of Standards and Technology). Test accuracy ratio is 4:1 for pressures and temperature. Quality Assurance Program and calibration procedures meet the requirements for ANSI/NCSS Z540-1, ISO 17025, MIL-STD 45662A and manufacturer's specifications. Calibration accuracy is certified when meters are used with properly functioning accessories only. All Uncertainties are expressed in expanded terms (twice the calculated uncertainty). This report shall not be reproduced, except in full, without the written approval of Shortridge Instruments, Inc. Results relate only to the item calibrated. For limitations on use, see Shortridge Instruments, Inc. Instruction Manual for the use of AirData Multimeters. Procedure used: Procedure for Differential Pressure, Absolute Pressure and Temperature Recalibration of AirData Multimeters SIP-CP02 Revision: 30 Dated: 04/04/16

Calibration Technician(s): D. Babb Calibration Date: 01/14/2022  
 Calibration Approved by: m. Romo Title: Cal Supv Date: 01/17/2022

AS-Received By <u>D. Babb</u> Date <u>12/28/2021</u> Rh <u>37</u> % Ambient Temperature <u>72</u> °F Barometric Pressure <u>28.19</u> in Hg All within spec <u>YES</u> NO NA	FINAL Test By <u>D. Babb</u> Date <u>01/14/2022</u> Rh <u>33</u> % Ambient Temperature <u>71</u> °F Barometric Pressure <u>28.46</u> in Hg All within spec <u>YES</u> NO	Test By _____ Date _____ Rh _____ % Ambient Temperature _____ °F Barometric Pressure <u>NA</u> in Hg All within spec YES NO
--	--	---

### ABSOLUTE PRESSURE TEST (in Hg)

TEST METER TOLERANCE = ± 2.0 % ± 1 in Hg Pressure Standard: Heise #02-R S/N: 41741/42451 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #04-R S/N: 41743/42453 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #06-R S/N: 41742/42452-1 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #08-R S/N: 42186/43328 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #10-R S/N: 42203/43352 As-Rcvd Test 2 Test 3	AS-RECEIVED TEST WITHIN SPEC <u>YES</u> NO N/A See Notes Pressure Standard: Heise #12-A-R S/N: 45605/48491 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #14-R S/N: 43412/45043-2 <u>As-Rcvd Test 2</u> Test 3 Pressure Standard: Heise #16-R S/N: 43413/45044 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #18-R S/N: 44581/46845 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #20-R S/N: 44582/46847 As-Rcvd Test 2 Test 3
---	--

Approx Set Pt	Standard	Test Meter	% Diff	Standard	Test Meter	% Diff	Standard	Test Meter	% Diff
14.0	14.09	14.1	.07	14.19	14.2	.07			
28.4	28.19	28.3	.39	28.46	28.5	.14			
40.0	40.12	40.2	.20	40.57	40.6	.07			

### DIFFERENTIAL PRESSURE TEST (in wc)

TEST METER TOLERANCE = ± 2.0 % ± 0.001 in wc Pressure Standard: Heise #01-L S/N: 41739/42449 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #01-R S/N: 41739/42446 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #02-L S/N: 41741/42454 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #03A-L S/N: 45570/48461 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #03A-R S/N: 45570/48460 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #04-L S/N: 41743/42456 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #05-L S/N: 41740/42450 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #05-R S/N: 41740/42447 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #06-L S/N: 41742/42455 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #07-L S/N: 42185/42186 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #07-R S/N: 42185/43326 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #08-L S/N: 42186/43329 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #09-L S/N: 42202/43351 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #09-R S/N: 42202/43350 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #10-L S/N: 42203/43353 As-Rcvd Test 2 Test 3	AS-RECEIVED TEST WITHIN SPEC <u>YES</u> NO N/A See Notes Pressure Standard: Heise #11-L S/N: 43165/44551-1 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #11-R S/N: 43165/44730 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #12A-L S/N: 45605/48490-1 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #13-L S/N: 43415/45041 <u>As-Rcvd Test 2</u> Test 3 Pressure Standard: Heise #13-R S/N: 43415/45039 <u>As-Rcvd Test 2</u> Test 3 Pressure Standard: Heise #14-L S/N: 43412/45045 <u>As-Rcvd Test 2</u> Test 3 Pressure Standard: Heise #15-L S/N: 43416/45042 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #15-R S/N: 43416/45040 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #16-L S/N: 43413/45046 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #17-L S/N: 44579/46842 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #17-R S/N: 44579/46841 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #18-L S/N: 44581/46846 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #19-L S/N: 44580/46844 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #19-R S/N: 44580/46843 As-Rcvd Test 2 Test 3 Pressure Standard: Heise #20-L S/N: 44582/46848 As-Rcvd Test 2 Test 3
---	---

Approx Set Pt	Standard	Test Meter	% Diff	Standard	Test Meter	% Diff	Standard	Test Meter	% Diff
0.0100	.0105	.0104	-.95	.0106	.0106	.00			
0.0200	.0207	.0206	-.48	.0205	.0205	.00			
0.0300	.0302	.0302	.00	.0301	.0301	.00			
0.0400	.0402	.0401	-.25	.0404	.0405	.25			
0.0500	.0501	.0501	.00	.0502	.0502	.00			
0.1250	.1258	.1255	-.24	.1252	.1249	-.24			
0.2250	.2256	.2252	-.18	.2258	.2256	-.09			
1.000	1.015	1.012	-.30	1.014	1.011	-.30			
2.000	2.006	2.000	-.30	2.019	2.015	-.20			
3.600	3.611	3.597	-.39	3.617	3.604	-.36			
4.400	4.403	4.406	.07	4.410	4.413	.07			
27.00	27.11	27.11	.00	27.08	27.07	-.04			
50.00	50.16	50.02	-.28	50.14	50.02	-.24			
Overrange	NA	✓	NA	NA	✓	NA	NA	NA	NA

# AIRDATA MULTIMETER CERTIFICATE OF RECALIBRATION

S/N: M16654

Order #: R213346

## LOW VELOCITY CONFIRMATION (FPM)

TEST METER TOLERANCE =  $\pm 3.0\% \pm 7$  FPM      AS-RECEIVED TEST WITHIN SPEC **YES**    NO    N/A    See Notes

Vel Eqv Trans Std: S/N: M02009	As-Rcvd	Test 2	Test 3	Vel Eqv Trans Std: S/N: M10897	As-Rcvd	Test 2	Test 3
Vel Eqv Trans Std: S/N: M02903	As-Rcvd	Test 2	Test 3	Vel Eqv Trans Std: S/N: M10901	As-Rcvd	Test 2	Test 3
Vel Eqv Trans Std: S/N: M10839	As-Rcvd	Test 2	Test 3	Vel Eqv Trans Std: S/N: M13492	As-Rcvd	Test 2	Test 3
Vel Eqv Trans Std: S/N: M10840	As-Rcvd	Test 2	Test 3	Vel Eqv Trans Std: S/N: M19325	As-Rcvd	Test 2	Test 3

Approx Set Point	Standard	Test Meter	Diff	Standard	Test Meter	Diff	Standard	Test Meter	Diff
100	106	104	-2	105	106	1	NA		
500	511	511	0	510	509	-1			

ADM-880C, ADM-870/870C and ADM-860/860C models are read in AirFoil Mode. ADM-850/850L models are read in Pitot Tube Mode.

## TEMPERATURE TEST - AIRDATA MULTIMETER (° F)

TEST METER TOLERANCE =  $\pm 0.2^\circ$  F      AS-RECEIVED TEST WITHIN SPEC **YES**    NO    N/A    See Notes

RTD Simulator: S/N 249	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 250	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 253	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 254	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 256	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 257	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 292	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 293	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 294	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 313	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 314	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 315	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 316	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 317	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F
RTD Simulator: S/N 318	As-Rcvd	Test 2	Test 3	Set Point: 35.6° F	95° F	154.4° F

RTD Simulator Temperature Equivalent Set Point	Test Meter	Difference	Test Meter	Difference	Test Meter	Difference
35.60	35.7	.1	35.7	.1	NA	
95.00	94.9	-.1	95.0	0		
154.40	154.3	-.1	154.3	-.1		

There were no additions to or deviations from the specified calibration procedure during the calibration process.

Any calibration due date shown is specified by the customer.

The enclosed ADM Calibration Standards for Pressure and Temperature form(s) is/are an integral part of this calibration and must remain with this Certificate of Calibration. There may be more than one such form included that pertains to this calibration.

Any additional information required pertaining to this calibration or to any repairs performed may be included in other documentation. If applicable, these documents may include, but not be limited to an AirData Multimeter Recalibration Notes form, and/or a Repair Record Notes form.

NOTES: \_\_\_\_\_

## Shortridge Instruments, Inc.

7855 East Redfield Road Scottsdale, Arizona 85260  
(480) 991-6744 • Fax (480) 443-1267 • www.shortridge.com

HAV222965

194

Procedure used: Procedure for Calibration/Recalibration of MultiTemps and/or TemProbes SIP-CP14 Rev: 03 Dated: 07/31/14. There were no additions to or deviations from the calibration procedure during this calibration process.

Equipment Being Tested: MultiTemp and TemProbes \_\_\_\_\_ TemProbe(s)

AS-RECEIVED TEMPERATURE TEST (° F)  
 MULTITEMP TOLERANCE (MULTITEMP AND TEMPROBES TESTED AS A UNIT) = ± 0.5° F  
 TEMPROBE TOLERANCE = ± 0.3° F

Thermometer #1 S/N 8A089 / Thermistor S/N A410660	Set Point: 35° F 95° F 155° F
Thermometer #2 S/N 8B104 / Thermistor S/N 871507	Set Point: 35° F 95° F <u>155° F</u>
Thermometer #5 S/N B11780 / Thermistor S/N B10505	Set Point: <u>35° F</u> 95° F 155° F
Thermometer #6 S/N B11782 / Thermistor S/N B10509	Set Point: 35° F <u>95° F</u> 155° F
Thermometer #7 S/N B49938 / Thermistor S/N B482202	Set Point: 35° F 95° F 155° F
Temperature Standard AirData Multimeter S/N M00136	Set Point: 35° F 95° F 155° F
Temperature Standard AirData Multimeter S/N M96100	Set Point: <u>35° F</u> <u>95° F</u> <u>155° F</u>

Test By: D. Babb Date: 12/28/2021 Rh: 37 % Ambient Temperature: 72 °F Barometric Pressure: 28.21 in Hg

Approx Set Point	Temp Standard	Test Probe #1 ADT- <u>442</u>	Test Probe #2 ADT- <u>446</u>	Test Probe #3 ADT- _____	Test Probe #4 ADT- _____	Test Probe #5 ADT- _____	Test Probe #6 ADT- _____	Test Probe #7 ADT- _____	Test Probe #8 ADT- _____
35°	<u>35.0</u>	<u>35.0</u>	<u>35.1</u>						
95°	<u>95.0</u>	<u>95.0</u>	<u>95.0</u>		<u>NA</u>				
155°	<u>155.0</u>	<u>155.1</u>	<u>155.0</u>						

A check in the box to the right of a TemProbe reading indicates that the reading is Out Of Specification.

If all As-Received readings were within specification, and no repairs were performed, no Final test is required.

NOTES: \_\_\_\_\_

FINAL TEMPERATURE TEST (° F)  
 MULTITEMP TOLERANCE (MULTITEMP AND TEMPROBES TESTED AS A UNIT) = ± 0.5° F  
 TEMPROBE TOLERANCE = ± 0.3° F

Thermometer #1 S/N 8A089 / Thermistor S/N A410660	Set Point: 35° F 95° F 155° F
Thermometer #2 S/N 8B104 / Thermistor S/N 871507	Set Point: 35° F 95° F 155° F
Thermometer #5 S/N B11780 / Thermistor S/N B10505	Set Point: 35° F 95° F 155° F
Thermometer #6 S/N B11782 / Thermistor S/N B10509	Set Point: 35° F 95° F 155° F
Thermometer #7 S/N B49938 / Thermistor S/N B482202	Set Point: 35° F 95° F 155° F
Temperature Standard AirData Multimeter S/N M00136	Set Point: 35° F 95° F 155° F
Temperature Standard AirData Multimeter S/N M96100	Set Point: 35° F 95° F 155° F

Test By: \_\_\_\_\_ Date: \_\_\_\_\_ Rh: \_\_\_\_\_ % Ambient Temperature: \_\_\_\_\_ °F Barometric Pressure: \_\_\_\_\_ in Hg

Approx Set Point	Temp Standard	Test Probe #1 ADT- _____	Test Probe #2 ADT- _____	Test Probe #3 ADT- _____	Test Probe #4 ADT- _____	Test Probe #5 ADT- _____	Test Probe #6 ADT- _____	Test Probe #7 ADT- _____	Test Probe #8 ADT- _____
35°									
95°					<u>NA</u>				
155°									

NOTES: \_\_\_\_\_

Calibration standards used by Shortridge Instruments, Inc. are traceable to NIST (National Institute of Standards and Technology). Calibration is performed in accordance with ANSI/NCSL Z540-1, ISO 17025, MIL-STD 45662A and manufacturer's specifications. Calibration accuracy is certified when meters are used with properly functioning accessories only. This report shall not be reproduced, except in full, without the written approval of Shortridge Instruments, Inc. Results relate only to the item calibrated. Limitations on use: See Shortridge Instruments, Inc. Instruction Manual for the use of AirData Multimeters.

The enclosed ADM or HDM Calibration Standards form(s) is/are an integral part of this calibration and must remain with this Certificate of Calibration. Note: There may be more than one such form included that pertains to this calibration. Any calibration due date shown is specified by the customer.

Calibration Approved by: m. Ramirez Title: Cal Super Date: 01/17/2022

Shortridge Instruments, Inc. • 7855 E Redfield Road, Scottsdale, AZ 85260 • (480) 991-6744 • Fax (480) 443-1267 • www.shortridge.com



# Shortridge Instruments, Inc. AirData Multimeter Calibration Equipment

Order Number: R213346 Serial Number: m16654 Test Type: Initial As-Received Final

### ABSOLUTE PRESSURE STANDARDS

ADM #02-R	S/N: 41741/42451	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 04/30/21	Due Date: 04/2022
ADM #04-R	S/N: 41743/42453	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 11/19/21	Due Date: 11/2022
ADM #06-R	S/N: 41742/42452-1	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 08/17/21	Due Date: 08/2022
ADM #08-R	S/N: 42186/43328	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 04/10/21	Due Date: 03/2022
ADM #10-R	S/N: 42203/43352	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 01/27/21	Due Date: 02/2022
ADM #12A-R	S/N: 45605/48491	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 07/27/21	Due Date: 07/2022
ADM #14-R	S/N: 43412/45043-2	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/24/21	Due Date: 09/2022
ADM #16-R	S/N: 43413/45044	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 08/17/21	Due Date: 08/2022
ADM #18-R	S/N: 44581/46845	Heise Model: PPM-2	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 10/26/21	Due Date: 10/2022
ADM #20-R	S/N: 44582/46847	Heise Model: PPM-2	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 06/16/21	Due Date: 06/2022
#02-R, 04-R, 06-R, 08-R, 10-R, 12A-R, 14-R, 16-R	Rated Accuracy: 0.05% fs (0.0305 in Hg)		Range: 0-30 psia		Resolution: 0.01	Uncertainty: < 0.0358
#18-R, 20-R	Rated Accuracy: 0.05% fs (0.0305 in Hg)		Range: 0-60 in Hg		Resolution: 0.001	Uncertainty: < 0.0358

### DIFFERENTIAL PRESSURE STANDARDS

ADM #01-L	S/N: 41739/42449	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 05/06/21	Due Date: 04/2022
ADM #01-R	S/N: 41739/42446	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 05/07/21	Due Date: 04/2022
ADM #02-L	S/N: 41741/42454	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 05/05/21	Due Date: 04/2022
ADM #03A-L	S/N: 45570/48461	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 11/24/21	Due Date: 11/2022
ADM #03A-R	S/N: 45570/48460	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 11/24/21	Due Date: 11/2022
ADM #04-L	S/N: 41743/42456	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 11/23/21	Due Date: 11/2022
ADM #05-L	S/N: 41740/42450	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/08/21	Due Date: 08/2022
ADM #05-R	S/N: 41740/42447	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/07/21	Due Date: 08/2022
ADM #06-L	S/N: 41742/42455	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/07/21	Due Date: 08/2022
ADM #07-L	S/N: 42185/42186	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 04/08/21	Due Date: 03/2022
ADM #07-R	S/N: 42185/43326	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 04/08/21	Due Date: 03/2022
ADM #08-L	S/N: 42186/43329	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 04/08/21	Due Date: 03/2022
ADM #09-L	S/N: 42202/43351	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 01/26/21	Due Date: 02/2022
ADM #09-R	S/N: 42202/43350	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 01/26/21	Due Date: 02/2022
ADM #10-L	S/N: 42203/43353	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 01/26/21	Due Date: 02/2022
ADM #11-L	S/N: 43165/44551-1	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 07/30/21	Due Date: 07/2022
ADM #11-R	S/N: 43165/44730	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 07/30/21	Due Date: 07/2022
ADM #12A-L	S/N: 45605/48490-1	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 08/09/21	Due Date: 07/2022
ADM #13-L	S/N: 43415/45041	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/24/21	Due Date: 09/2022
ADM #13-R	S/N: 43415/45039	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/24/21	Due Date: 09/2022
ADM #14-L	S/N: 43412/45045	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/24/21	Due Date: 09/2022
ADM #15-L	S/N: 43416/45042	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/08/21	Due Date: 08/2022
ADM #15-R	S/N: 43416/45040	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/07/21	Due Date: 08/2022
ADM #16-L	S/N: 43413/45046	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/07/21	Due Date: 08/2022
ADM #17-L	S/N: 44579/46842	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 10/29/21	Due Date: 10/2022
ADM #17-R	S/N: 44579/46841	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 10/29/21	Due Date: 10/2022
ADM #18-L	S/N: 44581/46846	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 10/29/21	Due Date: 10/2022
ADM #19-L	S/N: 44580/46844	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 06/23/21	Due Date: 06/2022
ADM #19-R	S/N: 44580/46843	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 06/24/21	Due Date: 06/2022
ADM #20-L	S/N: 44582/46848	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 06/23/21	Due Date: 06/2022
#01-L, 03A-L, 05-L, 07-L, 09-L, 11-L, 13-L, 15-L, 17-L, 19-L	Rated Accuracy: > 0.07% fs (0.000175 in wc)		Range: 0.0-0.25 in wc		Res.: 0.00001	Uncertainty: < 0.00035
#01-R, 03A-R, 05-R, 07-R, 09-R, 11-R, 13-R, 15-R, 17-R, 19-R	Rated Accuracy: > 0.06% fs ( 0.003 in wc)		Range: 0.0-5.0 in wc		Res.: 0.0001	Uncertainty: < 0.00348
#02-L, 04-L, 06-L, 08-L, 10-L, 12A-L, 14-L, 16-L, 18-L, 20-L	Rated Accuracy: > 0.06% fs (0.03 in wc)		Range: 0.0-50.0 in wc		Res.: 0.001	Uncertainty: < 0.0346

## Shortridge Instruments, Inc.

7855 East Redfield Road Scottsdale, Arizona 85260  
(480) 991-6744 • Fax (480) 443-1267 • www.shortridge.com

HAV222965

197

# Shortridge Instruments, Inc. AirData Multimeter Calibration Equipment

Customer Order Number, Meter Serial Number, and Test Type are referenced on page 1

## LOW VELOCITY EQUIVALENT CONFIRMATION STANDARDS

Vel Eqv Transfer Standard S/N: M02009	Model ADM-870C	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 08/20/21	Due Date: 08/2022
Vel Eqv Transfer Standard S/N: M02903	Model ADM-870C	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 12/16/21	Due Date: 12/2022
Vel Eqv Transfer Standard S/N: M10839	Model ADM-870C	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 10/26/21	Due Date: 10/2022
Vel Eqv Transfer Standard S/N: M10840	Model ADM-870C	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 10/26/21	Due Date: 10/2022
Vel Eqv Transfer Standard S/N: M10897	Model ADM-870C	Mfg'd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 01/26/21	Due Date: 01/2022
Vel Eqv Transfer Standard S/N: M10901	Model ADM-870C	Mfg'd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 12/16/21	Due Date: 12/2022
Vel Eqv Transfer Standard S/N: M13492	Model ADM-870C	Mfg'd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 08/20/21	Due Date: 08/2022
Vel Eqv Transfer Standard S/N: M19325	Model ADM-870C	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 06/29/21	Due Date: 06/2022
Rated Accuracy: Velocity $\pm 1.5\%$ $\pm 3.5$ fpm		Range: 100-5000 fpm    Resolution: 0.1	Uncertainty: <5.00 fpm at 100 fpm; <7.50 fpm at 500 fpm	

## TEMPERATURE STANDARDS

RTD Simulator S/N: 249	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/02/20	Due Date: 03/2024
RTD Simulator S/N: 250	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/02/20	Due Date: 03/2024
RTD Simulator S/N: 253	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/02/20	Due Date: 03/2024
RTD Simulator S/N: 254	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 05/04/20	Due Date: 04/2024
RTD Simulator S/N: 256	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 05/04/20	Due Date: 04/2024
RTD Simulator S/N: 257	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 05/04/20	Due Date: 04/2024
RTD Simulator S/N: 292	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 01/03/20	Due Date: 01/2024
RTD Simulator S/N: 293	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 01/03/20	Due Date: 01/2024
RTD Simulator S/N: 294	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 01/03/20	Due Date: 01/2024
RTD Simulator S/N: 313	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 03/16/18	Due Date: 03/2022
RTD Simulator S/N: 314	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 03/16/18	Due Date: 03/2022
RTD Simulator S/N: 315	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 03/16/18	Due Date: 03/2022
RTD Simulator S/N: 316	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/16/18	Due Date: 04/2022
RTD Simulator S/N: 317	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/16/18	Due Date: 04/2022
RTD Simulator S/N: 318	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/16/18	Due Date: 04/2022
Rated Accuracy: 0.025% of setting		Range: 100.00 $\Omega$ to 11111.10 $\Omega$	Resolution: 0.01 $\Omega$	Uncertainty: $\leq 32$ ppm	

Thermometer #1 S/N 8A089/Thermistor S/N A410660	Model 1504/5610	Mfgd by Hart Scientific	Calibrated by Fluke	Calibration Date: 08/26/21	Due Date: 08/2023
Thermometer #2 S/N 8B104/Thermistor S/N 871507	Model 1504/5610	Mfgd by Hart Scientific	Calibrated by Fluke	Calibration Date: 11/04/20	Due Date: 11/2022
Thermometer #5 S/N B11780/Thermistor S/N B10505	Model 1504/5610	Mfgd by Hart Scientific	Calibrated by Fluke	Calibration Date: 11/04/20	Due Date: 11/2022
Thermometer #6 S/N B11782/Thermistor S/N B10509	Model 1504/5610	Mfgd by Hart Scientific	Calibrated by Fluke	Calibration Date: 02/24/20	Due Date: 02/2022
Thermometer #7 S/N B49938/Thermistor S/N B482202	Model 1504/5610	Mfgd and Calibrated by Fluke		Calibration Date: 10/13/21	Due Date: 10/2023
Rated Accuracy(combined): 0.0324° F		Range: 32° F to 176° F	Resolution: 0.001° F	Combined Uncertainty with Baths: $\leq 0.040$ ° F	

Temp Transfer Standard S/N M00136	Model ADM-870	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 10/26/21	Due Date: 10/2022
Temp Transfer Standard S/N M96100	Model ADM-870	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 03/17/21	Due Date: 03/2022
Rated Accuracy: 0.03° F		Range: 33° F to 158° F	Resolution: 0.01° F	Uncertainty: < 0.023° F
Total combined Uncertainty for MultiTemp and TemProbe testing : $\leq 0.046$ ° F				

This form must remain with the Certificate of Calibration corresponding to the Customer Order Number and Meter Serial Number referenced on page 1.

**Shortridge Instruments, Inc.**  
 7855 East Redfield Road Scottsdale, Arizona 85260  
 (480) 991-6744 • Fax (480) 443-1267 • www.shortridge.com

# Shortridge Instruments, Inc. AirData Multimeter Calibration Equipment

Order Number: R213346    Serial Number: m16654    Test Type:    Initial As-Received    Final

## ABSOLUTE PRESSURE STANDARDS

ADM #02-R	S/N: 41741/42451	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 04/30/21	Due Date: 04/2022
ADM #04-R	S/N: 41743/42453	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 11/19/21	Due Date: 11/2022
ADM #06-R	S/N: 41742/42452-1	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 08/17/21	Due Date: 08/2022
ADM #08-R	S/N: 42186/43328	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 04/10/21	Due Date: 03/2022
ADM #10-R	S/N: 42203/43352	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 01/27/21	Due Date: 01/2022
ADM #12A-R	S/N: 45605/48491	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 07/27/21	Due Date: 07/2022
ADM #14-R	S/N: 43412/45043-2	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/24/21	Due Date: 09/2022
ADM #16-R	S/N: 43413/45044	Heise Model: PPM-2	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 08/17/21	Due Date: 08/2022
ADM #18-R	S/N: 44581/46845	Heise Model: PPM-2	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 10/26/21	Due Date: 10/2022
ADM #20-R	S/N: 44582/46847	Heise Model: PPM-2	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 06/16/21	Due Date: 06/2022
#02-R, 04-R, 06-R, 08-R, 10-R, 12A-R, 14-R, 16-R			Rated Accuracy: 0.05% fs (0.0305 in Hg)	Range: 0-30 psia	Resolution: 0.01	Uncertainty: < 0.0358
#18-R, 20-R			Rated Accuracy: 0.05% fs (0.0305 in Hg)	Range: 0-60 in Hg	Resolution: 0.001	Uncertainty: < 0.0358

## DIFFERENTIAL PRESSURE STANDARDS

ADM #01-L	S/N: 41739/42449	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 05/06/21	Due Date: 04/2022
ADM #01-R	S/N: 41739/42446	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 05/07/21	Due Date: 04/2022
ADM #02-L	S/N: 41741/42454	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 05/05/21	Due Date: 04/2022
ADM #03A-L	S/N: 45570/48461	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 11/24/21	Due Date: 11/2022
ADM #03A-R	S/N: 45570/48460	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 11/24/21	Due Date: 11/2022
ADM #04-L	S/N: 41743/42456	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 11/23/21	Due Date: 11/2022
ADM #05-L	S/N: 41740/42450	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/08/21	Due Date: 08/2022
ADM #05-R	S/N: 41740/42447	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/07/21	Due Date: 08/2022
ADM #06-L	S/N: 41742/42455	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/07/21	Due Date: 08/2022
ADM #07-L	S/N: 42185/42186	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 04/08/21	Due Date: 03/2022
ADM #07-R	S/N: 42185/43326	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 04/08/21	Due Date: 03/2022
ADM #08-L	S/N: 42186/43329	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 04/08/21	Due Date: 03/2022
ADM #09-L	S/N: 42202/43351	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 01/26/21	Due Date: 01/2022
ADM #09-R	S/N: 42202/43350	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 01/26/21	Due Date: 01/2022
ADM #10-L	S/N: 42203/43353	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 01/26/21	Due Date: 01/2022
ADM #11-L	S/N: 43165/44551-1	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 07/30/21	Due Date: 07/2022
ADM #11-R	S/N: 43165/44730	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 07/30/21	Due Date: 07/2022
ADM #12A-L	S/N: 45605/48490-1	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 08/09/21	Due Date: 07/2022
ADM #13-L	S/N: 43415/45041	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/24/21	Due Date: 09/2022
ADM #13-R	S/N: 43415/45039	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/24/21	Due Date: 09/2022
ADM #14-L	S/N: 43412/45045	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/24/21	Due Date: 09/2022
ADM #15-L	S/N: 43416/45042	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/08/21	Due Date: 08/2022
ADM #15-R	S/N: 43416/45040	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/07/21	Due Date: 08/2022
ADM #16-L	S/N: 43413/45046	Heise Model: PPM-1	Mfgd by Dresser Industries	Calibrated by Ashcroft	Calibration Date: 09/07/21	Due Date: 08/2022
ADM #17-L	S/N: 44579/46842	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 10/29/21	Due Date: 10/2022
ADM #17-R	S/N: 44579/46841	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 10/29/21	Due Date: 10/2022
ADM #18-L	S/N: 44581/46846	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 10/29/21	Due Date: 10/2022
ADM #19-L	S/N: 44580/46844	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 06/23/21	Due Date: 06/2022
ADM #19-R	S/N: 44580/46843	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 06/24/21	Due Date: 06/2022
ADM #20-L	S/N: 44582/46848	Heise Model: PPM-1	Mfgd & Calibrated by Ashcroft, Inc.		Calibration Date: 06/23/21	Due Date: 06/2022
#01-L, 03A-L, 05-L, 07-L, 09-L, 11-L, 13-L, 15-L, 17-L, 19-L			Rated Accuracy: > 0.07% fs (0.000175 in wc)	Range: 0.0-0.25 in wc	Res.: 0.00001	Uncertainty: < 0.00035
#01-R, 03A-R, 05-R, 07-R, 09-R, 11-R, 13-R, 15-R, 17-R, 19-R			Rated Accuracy: > 0.06% fs ( 0.003 in wc)	Range: 0.0-5.0 in wc	Res.: 0.0001	Uncertainty: < 0.00348
#02-L, 04-L, 06-L, 08-L, 10-L, 12A-L, 14-L, 16-L, 18-L, 20-L			Rated Accuracy: > 0.06% fs (0.03 in wc)	Range: 0.0-50.0 in wc	Res.: 0.001	Uncertainty: < 0.0346

## Shortridge Instruments, Inc.

7855 East Redfield Road    Scottsdale, Arizona 85260  
 (480) 991-6744 • Fax (480) 443-1267 • www.shortridge.com

HAV222965



# Shortridge Instruments, Inc. AirData Multimeter Calibration Equipment

Customer Order Number, Meter Serial Number, and Test Type are referenced on page 1

## LOW VELOCITY EQUIVALENT CONFIRMATION STANDARDS

Vel Eqv Transfer Standard S/N: M02009	Model ADM-870C	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 08/20/21	Due Date: 08/2022
Vel Eqv Transfer Standard S/N: M02903	Model ADM-870C	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 12/16/20	Due Date: 12/2021
Vel Eqv Transfer Standard S/N: M10839	Model ADM-870C	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 10/26/21	Due Date: 10/2022
Vel Eqv Transfer Standard S/N: M10840	Model ADM-870C	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 10/26/21	Due Date: 10/2022
Vel Eqv Transfer Standard S/N: M10897	Model ADM-870C	Mfg'd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 01/26/21	Due Date: 01/2022
Vel Eqv Transfer Standard S/N: M10901	Model ADM-870C	Mfg'd & Calibrated by Shortridge Instruments, inc.	Calibration Date: 12/16/20	Due Date: 12/2021
Vel Eqv Transfer Standard S/N: M13492	Model ADM-870C	Mfg'd & Calibrated by Shortridge Instruments, inc.	Calibration Date: 08/20/21	Due Date: 08/2022
Vel Eqv Transfer Standard S/N: M19325	Model ADM-870C	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 06/29/21	Due Date: 06/2022
Rated Accuracy: Velocity ± 1.5 % ± 3.5 fpm		Range: 100-5000 fpm    Resolution: 0.1	Uncertainty: <5.00 fpm at 100 fpm; <7.50 fpm at 500 fpm	

## TEMPERATURE STANDARDS

RTD Simulator S/N: 249	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/02/20	Due Date: 03/2024
RTD Simulator S/N: 250	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/02/20	Due Date: 03/2024
RTD Simulator S/N: 253	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/02/20	Due Date: 03/2024
RTD Simulator S/N: 254	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 05/04/20	Due Date: 04/2024
RTD Simulator S/N: 256	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 05/04/20	Due Date: 04/2024
RTD Simulator S/N: 257	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 05/04/20	Due Date: 04/2024
RTD Simulator S/N: 292	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 01/03/20	Due Date: 01/2024
RTD Simulator S/N: 293	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 01/03/20	Due Date: 01/2024
RTD Simulator S/N: 294	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 01/03/20	Due Date: 01/2024
RTD Simulator S/N: 313	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 03/16/18	Due Date: 03/2022
RTD Simulator S/N: 314	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 03/16/18	Due Date: 03/2022
RTD Simulator S/N: 315	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 03/16/18	Due Date: 03/2022
RTD Simulator S/N: 316	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/16/18	Due Date: 04/2022
RTD Simulator S/N: 317	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/16/18	Due Date: 04/2022
RTD Simulator S/N: 318	Model RTD-1000/500	Mfgd by General Resistance	Calibrated by IET Labs	Calibration Date: 04/16/18	Due Date: 04/2022
Rated Accuracy: 0.025% of setting		Range: 100.00 Ω to 11111.10 Ω	Resolution: 0.01 Ω	Uncertainty: ≤ 32 ppm	

Thermometer #1 S/N 8A089/Thermistor S/N A410660	Model 1504/5610	Mfgd by Hart Scientific	Calibrated by Fluke	Calibration Date: 08/26/21	Due Date: 08/2023
Thermometer #2 S/N 8B104/Thermistor S/N 871507	Model 1504/5610	Mfgd by Hart Scientific	Calibrated by Fluke	Calibration Date: 11/04/20	Due Date: 11/2022
Thermometer #5 S/N B11780/Thermistor S/N B10505	Model 1504/5610	Mfgd by Hart Scientific	Calibrated by Fluke	Calibration Date: 11/04/20	Due Date: 11/2022
Thermometer #6 S/N B11782/Thermistor S/N B10509	Model 1504/5610	Mfgd by Hart Scientific	Calibrated by Fluke	Calibration Date: 02/24/20	Due Date: 02/2022
Thermometer #7 S/N B49938/Thermistor S/N B482202	Model 1504/5610	Mfgd and Calibrated by Fluke		Calibration Date: 10/13/21	Due Date: 10/2023
Rated Accuracy(combined): 0.0324° F		Range: 32° F to 176° F	Resolution: 0.001° F	Combined Uncertainty with Baths: ≤ 0.040° F	

Temp Transfer Standard S/N M00136	Model ADM-870	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 10/26/21	Due Date: 10/2022
Temp Transfer Standard S/N M96100	Model ADM-870	Mfgd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 03/17/21	Due Date: 03/2022
Rated Accuracy: 0.03° F		Range: 33° F to 158° F	Resolution: 0.01° F	Uncertainty: < 0.023° F
Total combined Uncertainty for MultiTemp and TemProbe testing : ≤ 0.046° F				

This form must remain with the Certificate of Calibration corresponding to the Customer Order Number and Meter Serial Number referenced on page 1.

**Shortridge Instruments, Inc.**

7855 East Redfield Road Scottsdale, Arizona 85260  
(480) 991-6744 • Fax (480) 443-1267 • www.shortridge.com



## Field Barometer Calibration Form

Project #:           HAV222965          

**IN OFFICE PRE-TEST CALIBRATION**

---

**Reference Standard Used:**

Standard ID	Serial number	Adjusted on:	Calibration due:
Helena mercury barometer	BIS01	12/9/2022	Must be properly adjusted prior to every use

**Field Barometer Verification:**

**Barometer ID:**                    TS4

Reference Value (in Hg)	Observed (in Hg)	Correction*	Tolerance (+/- 0.1 in Hg)**
25.90	25.90	0.00	PASS

\*Correction is the difference between the observed and reference values

\*\*EPA Method 5, Section 6.1.2 and EPA Method 2, Section 6.5.

Technician:           ARB          

Date:           12/9/2022



## Field Balance and Weights Calibration Form

Project #:           HAV222965          

### IN OFFICE PRE-TEST CHECKS

Date: 12/9/2022

Performed by: ARB

#### Environmental conditions in the lab:

Temperature °F	Pressure "Hg
69	25.90

#### Reference Standard(s) Used:

Standard ID	Serial number(s)	Calibrated on:	Calibration due:
500g and 200g weight set	10696	2/12/2022	2/12/2023

#### Verification of Field Balance Against Reference Standard Weights:

Balance ID: HLNFB1

Nominal Value (g)	Observed (g)	Correction*	Tolerance (+/- 0.5g)**
500	500.0	0.0	PASS
1000	1000.0	0.0	PASS
2000	2000.0	0.0	PASS

#### Verification of Field Standard Weights :

Weights ID: HLNFW1

Nominal Value (g)	Observed (g)	Correction*	Tolerance (+/- 0.5g)**
500	500.0	0.0	PASS
1000	1000.0	0.0	PASS
2000	2000.0	0.0	PASS

\*Correction is the difference between the observed and nominal mass values

\*\*EPA Method 5, Section 6.3.4

**ONSITE BALANCE VERIFICATION**

---

**Date:** 12/13/2022**Performed by:** MTK**Environmental conditions onsite:**

Temperature °F	Pressure "Hg
39	30.00

**Field Balance Verification:****Balance ID:** HLNFB1**Weights ID:** HLN FW1

Nominal Value (g)	Observed (g)	Correction*	PASS/FAIL Tolerance (+/- 0.5g)
500	500.1	0.1	PASS
1000	1000.0	0.0	PASS
2000	2000.0	0.0	PASS

\*Correction is the difference between the observed and nominal mass values

**ONSITE BALANCE VERIFICATION**

Date: 12/14/2022  
Performed by: MTK

**Environmental conditions onsite:**

Temperature °F	Pressure "Hg
34	30.15

**Field Balance Verification:**

Balance ID: HLNFB1  
Weights ID: HLN FW1

Nominal Value (g)	Observed (g)	Correction*	PASS/FAIL Tolerance (+/- 0.5g)
500	500.0	0.0	PASS
1000	1000.0	0.0	PASS
2000	2000.0	0.0	PASS

\*Correction is the difference between the observed and nominal mass values

**ONSITE BALANCE VERIFICATION**

Date: 12/15/2022  
Performed by: MTK

**Environmental conditions onsite:**

Temperature °F	Pressure "Hg
25	30.21

**Field Balance Verification:**

Balance ID: HLNFB1  
Weights ID: HLN FW1

Nominal Value (g)	Observed (g)	Correction*	PASS/FAIL Tolerance (+/- 0.5g)
500	500.1	0.1	PASS
1000	1000.1	0.1	PASS
2000	2000.0	0.0	PASS

\*Correction is the difference between the observed and nominal mass values



## Field Caliper Calibration Form

Project #:           HAV222965          

### IN OFFICE PRE-TEST CHECKS

**Date:** 12/9/2022  
**Performed by:** ARB

#### Reference Standard Used:

Standard ID	Serial number	Calibrated on:	Calibration due:
HLN1 Aurora	77160806226	3/21/2022	3/21/2023

#### Caliper Verification:

**Field Caliper ID:** WS1

##### Inside Diameter

Reference Value (inches)	Observed (inches)	Correction*	Tolerance (+/- 0.0050 inch)
0.273	0.273	0.000	PASS

\*Correction is the difference between the observed and reference values

##### Outside Diameter

Reference Value (inches)	Observed (inches)	Correction*	Tolerance (+/- 0.0050 inch)
0.375	0.375	0.000	PASS

\*Correction is the difference between the observed and reference values



## Digital Manometer Calibration Form

Project #: HAV222965

### IN OFFICE POST-TEST CHECKS

Date: 12/17/2022

Performed by: MTK

Reference Standard Used: Fluid manometer

Digital Manometer Serial No.: HLN DM1

Reference Value of H <sub>2</sub> O)	Digital readout (" of H <sub>2</sub> O)	Correction*	Tolerance (+/- 5%)	Digital readout (" of H <sub>2</sub> O)	Correction*	Tolerance (+/- 5%)
4.00	3.990	-0.25%	PASS	4.000	0.00%	PASS
3.00	2.990	-0.33%	PASS	3.030	0.99%	PASS
2.00	1.990	-0.50%	PASS	1.980	-1.01%	PASS
1.00	0.980	-2.00%	PASS	1.010	0.99%	PASS
0.50	0.500	0.00%	PASS	0.490	-2.04%	PASS
0.30	0.290	-3.33%	PASS	0.300	0.00%	PASS
0.20	0.200	0.00%	PASS	0.200	0.00%	PASS
0.10	0.100	0.00%	PASS	0.100	0.00%	PASS

\*Correction is the difference between the observed and reference values



## Thermocouple Calibration Form

Project #:   HAV222965  

### POST-TEST CHECKS

---

#### Reference Standard Used:

Standard ID	Serial number(s)	Calibrated on:	Calibration due:
Omega	T-318009	10/13/2022	10/13/2023

#### Temperature Meter Mode:

Thermocouple ID	Continuity (x = pass)	Observed Temp (°F)	Reference Temp (°F)	Correction*	Tolerance (+/- 2°F)**
Stack Temp - 4E	x	68.6	69.2	0.6	PASS
Condenser - GN3	x	67.8		1.4	PASS
DGM Outlet	x	68.5		0.7	PASS
DGM Inlet (If applicable)	x	68.6		0.6	PASS

#### Calibration Output Mode:

Switch the Omega from 'Meter Input' to 'Calibration Output' mode. Test the meter box temperature readout by sending a voltage output equivalent to a temperature similar to stack temperature.

Meter Box ID	Reference Temp Output (°F)	Meter Box Readout (°F)	Correction*	Tolerance (+/- 2°F)**
Box 11	300.0	301	1.0	PASS

\*Correction is the difference between the observed and reference values

\*\*Alt-011 6/21/94 Alternative Method 2 Thermocouple Calibration Procedure:

Continuity Check - confirm the thermocouple is reading at the tip by subjecting it to a change in temperature (e.g. removing it from the stack, or touching it with your hand).

Single-point temperature check at ambient temperature, or any temperature, within the range specified by the manufacturer.


Technician:           MTK          

Date:           12/17/2022



## S-Type Pitot Tube Geometric Calibration

 Pitot ID: 4E

 Date of Geometric Calibration (< 6 months): 7/7/2022


A	0.88
B	0.40
C	0.95
D	0.39
E	0.95


$$\frac{a^2 + b^2 - c^2}{2ab} = \cos \phi$$

$$\frac{a^2 + d^2 - e^2}{2ad} = \cos \phi$$

$\phi$	87.17
--------	-------

 (80° <  $\phi$  < 100°)

$\phi$	88.13
--------	-------

 (80° <  $\phi$  < 100°)


A	0.88
B	0.63
C	1.09
D	0.63
E	1.09


$$\frac{a^2 + b^2 - c^2}{2ab} = \cos \phi$$

$$\frac{a^2 + d^2 - e^2}{2ad} = \cos \phi$$

$\phi$	90.49
--------	-------


 (85° <  $\phi$  < 95°)

$\phi$	90.49
--------	-------

 (85° <  $\phi$  < 95°)


F=	0.070
----	-------

( F &lt; 0.125 )



G=	0.000
----	-------

( G &lt; 0.032 )

**Results of the Post-Test Pitot Inspection (mark with x below):**

 No change   X  

 Damaged           

 New Calibration           
**Technician:**   MTK  
**Date:**   12/17/2022

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA PROTOCOL STANDARD

Part Number: E03NI80E15A0138	Reference Number: 153-402491513-1
Cylinder Number: CC503830	Cylinder Volume: 141.0 CF
Laboratory: 124 - Tooele (SAP) - UT	Cylinder Pressure: 2015 PSIG
PGVP Number: B72022	Valve Outlet: 590
Gas Code: CO2,O2,BALN	Certification Date: Jul 18, 2022

**Expiration Date: Jul 18, 2030**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

### ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	10.00 %	9.951 %	G1	+/- 0.8% NIST Traceable	07/18/2022
OXYGEN	10.00 %	10.05 %	G1	+/- 0.8% NIST Traceable	07/18/2022
NITROGEN	Balance				

### CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13060405	CC411744	7.489 % CARBON DIOXIDE/NITROGEN	0.6%	May 14, 2025
NTRM	98051010	SG9161286BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 14, 2023

### ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA-510 SV4MEUTJ CO2	CO2 NDIR (Dixon)	Jun 23, 2022
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Jun 23, 2022

Triad Data Available Upon Request



\_\_\_\_\_  
Signature on file

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number:	E03NI56E15A1055	Reference Number:	153-402284491-1
Cylinder Number:	SA20406	Cylinder Volume:	161.7 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	590
Gas Code:	CO2,O2,BALN	Certification Date:	Nov 16, 2021

**Expiration Date: Nov 16, 2029**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	22.00 %	21.70 %	G1	+/- 0.7% NIST Traceable	11/16/2021
OXYGEN	22.00 %	21.94 %	G1	+/- 0.5% NIST Traceable	11/16/2021
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13060802	CC415397	24.04 % CARBON DIOXIDE/NITROGEN	0.6%	Dec 11, 2025
NTRM	12062008	CC367433	22.883 % OXYGEN/NITROGEN	0.2%	May 14, 2024

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA-510 SV4MEUTJ CO2	CO2 NDIR (Dixon)	Oct 28, 2021
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Nov 03, 2021

Triad Data Available Upon Request



*[Signature]*  
HAV222965 **Approved for Release**  
2022 H&V Emission Factor and PTE Verification Test Report

This is the last page of the report.