



**OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY  
Underground Storage Tank Program**

**UST Public Record – General Program Information for FFY 2014**

**General Information**

Public record posted date: Oct. 20, 2014

Total number of UST facilities: 1888  
Total number of USTs: 5596

**Summary Information for Inspections on Site**

Number of UST facilities inspected: 569  
Inspection period dates: 10/1/13 to 9/30/14  
Percent compliance (combined measure): 86.3

NOTE: Tank, facility and on-site inspection information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in Title 40 of the Code of Federal Regulations 280.12, except for those identified in 40 CFR 280.10(b) and 280.10(c) as excluded or deferred USTs. Inspection information provided above includes emergency generator USTs. On-site inspections are comprehensive compliance inspections that include measuring significant operational compliance as defined by the U.S. Environmental Protection Agency.

**Summary Information for Releases**

Number of confirmed UST releases: 46  
Release reporting period dates: 10/1/13 to 9/30/14

**Summary Information for Release Sources and Causes**

Source			Causes													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%	
Tank	16	38.0	0	0	0	0	1	2.4	4	9.4	0	0	1	2.4	10	23.8
Piping	7	16.7	0	0	0	0	1	2.4	1	2.4	2	4.8	1	2.4	2	4.7
Dispenser	7	16.7	1	2.4	0	0	1	2.4	0	0	0	0	1	2.4	4	9.5
STP	1	2.4	0	0	0	0	0	0	0	0	1	2.4	0	0	0	0
Delivery Problem	3	7.2	1	2.4	2	4.8	0	0	0	0	0	0	0	0	0	0
Other	8	19.0	0	0	0	0	0	0	0	0	0	0	1	2.4	7	16.6
<b>Totals</b>	<b>42</b>	<b>100</b>	<b>2</b>	<b>4.8</b>	<b>2</b>	<b>4.8</b>	<b>3</b>	<b>7.2</b>	<b>5</b>	<b>11.8</b>	<b>3</b>	<b>7.2</b>	<b>4</b>	<b>9.6</b>	<b>23</b>	<b>54.6</b>

# = number, % = percent of total number

**NOTES:**

- Sources of the releases at four of the 46 confirmed release sites are unknown.
- Release, source and cause information is based on USTs regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those USTs identified in 40 CFR 280.10(b) as excluded USTs. USTs deferred in 40 CFR 280.10(c) and those used for emergency power generation (deferred from release detection by 40 CFR 280.10(d)) are included as part of the public record.
- Staff collected source and cause data at the time of reported release either by phone or on-line and verified by phone and entered it into the Leaking Underground Storage Tank Database. Project managers may update the data as additional information on the source and cause of the release becomes available.
- Site-specific information on releases is on DEQ's Leaking Underground Storage Tank Cleanup Site Database on the Web at <http://www.deq.state.or.us/lq/tanks/lust/LustPublicLookup.asp> DEQ regional tank staff can provide additional site-specific compliance and release information.

## **Contacting DEQ Regional Tank Staff**

DEQ tanks specialists are available in the following offices:

### **In Northwest Oregon**

(Clatsop, Clackamas, Columbia, Multnomah, Tillamook and Washington counties)

- Portland, 2020 SW Fourth Ave., Suite 400  
503-229-5263

### **In Western Oregon**

(Benton, Coos, Curry, Douglas, Jackson, Josephine, Lane, Lincoln, Linn, Marion, Polk and Yamhill counties)

- Salem office: 750 Front St. NE, Suite 120  
503-378-8240
- Eugene office: 165 E. Seventh Ave., Suite 100  
541-686-7838
- Coos Bay office: 381 N. Second St.  
541-269-2721
- Medford office: 221 Stewart Ave., Suite 201  
541-776-6003

### **In Eastern Oregon**

(Baker, Crook, Deschutes, Gilliam, Grant, Harney, Hood River, Jefferson, Klamath, Lake, Malheur, Morrow, Sherman, Umatilla, Union, Wallowa, Wasco and Wheeler counties)

- Bend office: 475 NE Bellevue Drive, Suite 110  
541-388-6146