

1 AMENDMENT NUMBER TWO  
2 TO THE  
3 THERMAL POWER PLANT SITE CERTIFICATE  
4 FOR THE  
5 COYOTE SPRINGS COGENERATION PROJECT  
6  
7

8 This amendment number two to the thermal power plant site certificate for the Coyote  
9 Springs Cogeneration Project (CSCP) is issued and executed pursuant to the Order in the  
10 Matter of the Thermal Power Plant Site Certificate for the Coyote Springs Cogeneration  
11 Project Request for Amendment No. 2 between the State of Oregon (State) acting by and  
12 through the Energy Facility Siting Council (EFSC) and Portland General Electric  
13 Company (PGE), an Oregon corporation.  
14

15 The amendment authorizes PGE to use #2 low-sulfur distillate oil for back-up fuel for the  
16 natural gas-fired combustion turbines at the Coyote Springs Cogeneration Project. It  
17 revises one site certificate condition, as noted below, and adds new site certificate  
18 conditions relating to the use of alternative fuel in a natural gas-fired facility.  
19

20 I. SITE CERTIFICATION  
21

22 Site Certification A is replaced with the following condition:  
23

- 24 A. To the extent authorized by State law and subject to those warranties and  
25 conditions set forth herein, the State approves and authorizes for  
26 construction, operation and retirement by PGE of a natural gas-fired  
27 combustion turbine energy facility with oil firing back-up (as defined in  
28 OAR 345-01-010(33)), together with related or supporting facilities in  
29 Boardman, Oregon, in the manner described in PGE's application for site  
30 certificate. "Facility", as used in this site certificate, consists of the energy  
31 facility and the related or supporting facilities described in PGE's application  
32 for site certificate, except where otherwise stated or where the context  
33 clearly indicates otherwise. The findings of facts, reasoning and conclusions  
34 of law underlying the terms and conditions of this site certificate are set forth  
35 in EFSC's final order and subsequent orders approving amendments number  
36 one and two, which by this reference are incorporated herein. Subject to the  
37 conditions herein, this certificate binds the State and all counties, cities and  
38 political subdivisions in this State as to the approval of the site and the  
39 construction, operation and retirement of the facility, as to matters that are  
40 included in and governed by this site certificate.  
41


42 XII. CONDITIONS ISSUED PURSUANT TO USING ALTERNATE FUEL IN A  
43 NATURAL GAS-FIRED FACILITY  
44


45 The site certificate is amended to add the conditions stated below.

- 1 1. The CSCP shall not exceed permitted emission levels, total emissions or the  
2 allowable amount of distillate fuel use stated in its Air Contaminant Discharge  
3 Permit (amended for distillate fuel burning). The CSCP's use of distillate fuel in  
4 its combustion turbines in any year shall not exceed an amount of 10 percent of  
5 the expected total fuel use, on a Btu higher heating value basis.  
6
- 7 2. PGE shall not use #2 low sulfur distillate fuel oil in its turbines at CSCP prior to  
8 receiving an amended Air Contaminant Discharge Permit from the Department of  
9 Environmental Quality authorizing it to burn distillate fuel.  
10
- 11 3. PGE shall prepare a Spill Prevention Control and Countermeasures Plan meeting  
12 federal standards and fully implement it within one year of storing distillate fuel at  
13 CSCP.  
14
- 15 4. PGE shall prepare a response plan meeting the requirements of a Federal  
16 Response Plan for CSCP suitable for submission to the U.S. Environmental  
17 Protection Agency Regional Administrator prior to beginning filling the second  
18 distillate oil storage tank.  
19  
20  
21  
22

23  
24 Portland General Electric Company

State of Oregon  
Energy Facility Siting Council

25  
26  
27  
28  
29  
30  
31  
32  


  
Terry Edvalson, Chair

33 March 11, 1997

March 7, 1997

34  
35  
36  
37  
38  
39 \council\coyote\amend2.doc