

800 NE Oregon Street, Suite 465, Portland OR 97232

Voice: (971) 673-0540

Fax: (971) 673-0556

TTY: (971) 673-0372

http://www.healthoregon.org/fps

mailbox.fps@state.or.us

Site Inspection Check List for:

## Central Services - OAR 333-535-0205

PR#	!		Date: In	spector:					
Pro۱	/ider:								
Proj	ect:								
Add	ress:								
			e Inspection:						
Inte	nded	Occ	upancy Date:						
Req	Required <b>PRIOR</b> to Approved Inspection:  RECEIVED?  YES NO NA								
Cert	ificate	e of	Occupancy (CO) from governir	ng jurisdiction					
MEF	Clos	se-O	ut verification (if required)						
SIT	E IN	SPE	ECTION:						
INT	ERIC	OR:	= Verify that the facility has i	nstalled:					
			TLITY ROOM:						
YES	NO	NA	<del>-</del>	222 525 225	244				
			The following shall be provided: Utility room physically separated		• •				
			Work space to handle the clean medical/surgical instruments and	•	erilization/disinfection of all				
			Work tables, sinks, flush-type de	evices, and wash	ner/sterilizer decontaminators				

			Lockers, showers, and toilets for staff employed in this area if these facilities are not available in adjacent employee facilities servicing other soiled areas.
CLE	EAN	AS	SEMBLY/UTILITY ROOM:
YES	NO	NA	Doors Shall Contain: 222 F2F 020F (2)
			Room Shall Contain: 333-535-0205 (2)  Work space and equipment for terminal sterilizing medical and surgical equipment and supplies and hand-washing stations
			Hand-washing stations
			A sterilization room shall be provided that is used exclusively for the inspection, assembly, and packaging of medical/surgical supplies and equipment for sterilization. 333-535-0205 (2)(a)
			Access to the sterilization room shall be restricted. 333-535-0205 (2)(a)(A)
			This room shall contain Hi-Vacuum or gravity steam sterilizers and sterilization equipment to accommodate heat-sensitive equipment (ETO sterilizers) and ETO aerators. 333-535-0205 (2)(a)(B)
			Sterilization room shall contain: 333-535-0205 (2)(a)(C) Work tables & Counters Hand-washing station Ultrasonic storage facilities for back up supplies & instruments Drying cabinet or equipment
			The area shall be designed to accommodate sterilizer carts for loading of prepared supplies for sterilization. 333-535-0205 (2)(a)(D)
STO	DRA	GE .	AREA:
YES	NO	NA	A room for breakdown shall be provided for manufacturers' clean/sterile supplies. The clean processing area shall not be in this area but in an adjacent space. 333-535-0205 (3)
EQ	UIPN	ΛΕΝ	T STORAGE ROOM:
YES	NO	NA	Storage for packs, etc. shall include provisions for ventilation, humidity, and temperature control. 333-535-0205 (4)
CAI	RT S	TO	RAGE:
YES	NO	NA	

	□ This area shall be adjacent and easily available to clean and sterile storage and close to the main distribution point to keep traffic to a minimum and ease workflow. 333-535-0205 (5)	