FACILITY	PR#:
PROJECT	
ADDRESS	

## PHARMACY SUITE OAR 333-535-0170 Effective October 1, 2009

Schematic Design (SD) Review	Construction Document (CD) Review
------------------------------	-----------------------------------

OAR RULE SECTION		LIED?	Colombia
		No	COMMENT
(1) The size and type of services to be provided in the pharmacy will depend upon the type of drug distribution system to be used in the hospital and whether the hospital proposes to provide, purchase, or share pharmacy services with other hospitals or other medical facilities.			
(2) Provisions shall be made for the following functional areas:			
(a) Hand-washing stations shall be provided within each separate room where open medication is prepared for administration; (b) Dispensing area;			
(c) Editing or order review area;			
(d) Sterile products area. (For the compounding of IV admixtures and other sterile products. May also be used for extemporaneous compounding.) If intravenous (IV) solutions are prepared in the pharmacy, a sterile work area with a laminar-flow workstation designed for product protection shall be provided. See OAR 333-535-0300; (e) Administrative areas. (Office area for the chief			
pharmacist and any other offices required for the proper maintenance of records and reports and also for purchasing, accounting, and personnel activities.);  (f) Storage areas (bulk, active, refrigeration, vault,			
volatile liquids);			
<ul><li>(g) Drug information area;</li><li>(h) Packaging area. (Provide only if required by the program.);</li><li>(i) Bulk compounding area. (Provide only if</li></ul>			
required by program.); and (j) Quality control area. (Required only if either packaging or bulk compounding areas are			
provided.)  (3) The pharmacy suite shall be in conformance with statutes and administrative rules pertaining to the State Board of Pharmacy.			