

CHAPTER 31
TENTS AND OTHER MEMBRANE STRUCTURES
Double strike through denotes model language deleted by Oregon
Blue text denotes Oregon Amendments

3104.19 Separation of generators. Generators and other internal combustion power sources shall be separated from tents or membrane structures by a minimum of 20 feet (6096 mm) and shall be **placed on an approved surface.** **Such equipment shall be** isolated from contact with the public by fencing, enclosure or other *approved* means.