

605.9.1 Attachment to structures. Temporary wiring attached to a structure shall be attached in an *approved* manner.

605.10 Portable, electric space heaters. Where not prohibited by other sections of this code, portable, electric space heaters shall be permitted to be used in all occupancies other than Group I-2 and SR-R-4 and in accordance with Sections 605.10.1 through 605.10.4.

Exception: The use of portable, electric space heaters in which the heating element cannot exceed a temperature of 212°F (100°C) shall be permitted in nonsleeping staff and employee areas in Group I-2 and SR-R-4 occupancies.

605.10.1 Listed and labeled. Only *listed* and *labeled* portable, electric space heaters shall be used.

605.10.2 Power supply. Portable, electric space heaters shall be plugged directly into an *approved* receptacle.

605.10.3 Extension cords. Portable, electric space heaters shall not be plugged into extension cords.

605.10.4 Prohibited areas. Portable, electric space heaters shall not be operated within 3 feet (914 mm) of any combustible materials. Portable, electric space heaters shall be operated only in locations for which they are *listed*.

605.11 Building-mounted solar photovoltaic power systems. See Oregon Solar Installation Specialty Code (OSISC) as adopted by OAR 918-800-0020. ~~Solar photovoltaic power systems shall be installed in accordance with Sections 605.11.1 through 605.11.4, the International Building Code and NFPA 70.~~

~~**Exception:** Detached, nonhabitable Group U structures including, but not limited to, parking shade structures, carports, solar trellises and similar structures shall not be subject to the requirements of this section.~~

605.11.1 Marking and Labeling. Marking and labeling as is required ~~on interior and exterior direct current (DC) conduit, enclosures, raceways, cable assemblies, junction boxes, combiner boxes and disconnects~~ by the Oregon Electrical Specialty Code, Section 690.31 shall be maintained.

~~**605.11.1.1 Materials.** The materials used for marking shall be reflective, weather resistant and suitable for the environment. Marking as required in Sections 605.11.1.2 through 605.11.1.4 shall have all letters capitalized with a minimum height of 3/8 inch (9.5 mm) white on red background.~~

~~**605.11.1.2 Marking content.** The marking shall contain the words "WARNING: PHOTOVOLTAIC POWER SOURCE."~~

~~**605.11.1.3 Main service disconnect.** The marking shall be placed adjacent to the main service disconnect in a location clearly visible from the location where the disconnect is operated.~~

~~**605.11.1.4 Location of marking.** Marking shall be placed on interior and exterior DC conduit, raceways, enclosures and cable assemblies every 10 feet (3048 mm), within 1 foot (305 mm) of turns or bends and within 1 foot (305 mm) above and below penetrations of roof/ceiling assemblies, walls or barriers.~~

~~**605.11.2 Locations of DC conductors.** Conduit, wiring systems, and raceways for photovoltaic circuits shall be located as close as possible to the ridge or hip or valley and from the hip or valley as directly as possible to an outside wall to reduce trip hazards and maximize ventilation opportunities. Conduit runs between sub arrays and to DC combiner boxes shall be installed in a manner that minimizes the total amount of conduit on the roof by taking the shortest path from the array to the DC combiner box. The DC combiner boxes shall be located such that conduit runs are minimized in the pathways between arrays. DC wiring shall be installed in metallic conduit or raceways, when located within enclosed spaces in a building. Conduit shall run along the bottom of load bearing members.~~

~~**605.11.3 Access and pathways.** Roof access, pathways, and spacing requirements shall be provided in accordance with Sections 605.11.3.1 through 605.11.3.3.~~

~~**Exceptions:**~~

~~Residential structures shall be designed so that each photovoltaic array is no greater than 150 feet (45~~