

SECTION 608
STATIONARY STORAGE BATTERY SYSTEMS

608.1 Scope. Flooded lead-acid, nickel cadmium and VRLA stationary storage battery systems ~~having an electrolyte capacity of more than 50 gallons (189 L) for flooded lead-acid, nickel cadmium and VRLA,~~ **of greater than 7 batteries or over 600 amp-hour total capacity,** or **more** than 1,000 pounds (454 kg) for lithium-ion and lithium metal polymer, used for facility standby power, emergency power or uninterrupted power supplies shall comply with this section and Table 608.1. **Stationary storage battery systems shall not be located in a space with an open combustion source.**