

RED Underlined = Existing Oregon Amendment brought forward from the 2007 OFC
BLUE or BLUE Strikethrough = Oregon Deletion or NOT ADOPTED
TEAL Underlined = New Oregon Amendment in the 2010 OFC

CHAPTER 45 MARINAS

4502.1 Definitions. The following words and terms shall, for the purpose of this chapter and as used elsewhere in this code, have the meanings shown herein.

PIER. A structure ~~built over the water, supported by pillars or piles, and used as a landing place, pleasure pavilion or similar purpose~~ **usually of greater length than width and projecting from the shore into a body of water with direct access from land that can be either open deck or provided with a superstructure.** (Was 902.1)

WHARF. A structure ~~or bulkhead constructed of wood, stone, concrete or similar material built at the shore~~ **line, of a harbor, lake or river for vessels to lie alongside of, and to anchor piers or floats, having a platform built along side and parallel to a body of water that may have an open deck or provided with a superstructure.** (Was 902.1)

4504.2 Piers or wharves. An automatic sprinkler system shall be installed under piers or wharves regulated by Section 424 of the Oregon Structural Specialty Code, which exceed 200 feet (60 960 mm) in length or exceed 5,000 square feet (465 m²) in area. Such systems shall comply with NFPA 307, Standard for the Construction and Fire Protection of Marine Terminals, Piers and Wharves. (Was 903.2.10.4)

(Renumber remaining sections)