

OYA OFFENDER JOB TRAINING MODULES

PROFICIENCY TEST

MODULE 1-04 FIRE EXTINGUISHERS

Multiple Choice:

1. Extinguishers must be inspected annually. Which of the following is not required in the annual inspection?
 - a) Checking pin and hose.
 - b) Turn upside down and shaking.
 - c) Setting off the extinguisher.
 - d) Initialing the tag when done.
2. Extinguisher should be located in which locations?
 - a) Located in exit path from buildings.
 - b) Located near dangerous area where flammable liquid or gases are located.
 - c) On large riding equipment (mowers, backhoes, tractors.)
 - d) In each individual campsite.
 - e) a, b and c.
 - f) None of the above
3. Which of the following is not a recommended operation procedure?
 - a) Staying back 15 feet from fire.
 - b) Breaking plastic tag before using.
 - c) Swing the nozzle from top of the flame to bottom.
 - d) Pulling pin.
 - e) Aim the nozzle at base of fire and squeeze the handle.

True/False:

4. _____ CO2 Extinguisher should be recharged every 5 years.
5. _____ Extinguishers should be used on all large fires.
6. _____ No PPE is required, but ABC extinguisher chemicals may be an inhalation irritant.
7. _____ Monthly inspection is recommended.
8. _____ After each use, the extinguisher should be removed and recharged or replaced.
9. _____ An extinguisher can be used on large fires that are out of control.

Discussion Questions:

1. What type of fires should you not use a fire extinguisher on?
2. How should you approach a fire and use an extinguisher?

Employee Name: _____ Pass _____ No Pass _____ Date _____