



GENERAL NOTES FOR ALL DETAILS ON THIS SHEET:



NOTE: ("TYPE B" MODIFIED INLET)
Dimensions shown in parenthesis are for Type B Modified inlet.
All cover bars for "Type B" Modified inlet are to be placed 1" min.
clear of bottom face of concrete and 2½" min. clear of top face of
concrete. "Type B" modified inlet to be used if B inlet is under traffic.



The selection and use of this Standard Drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user and should not be used without first consulting a Registered Professional Engineer.

OREGON STANDARD DRAWINGS

CONCRETE INLETS TYPE M-E, M-O, B AND B-SL

2024

DATE	REVISION DESCRIPTION		
CALC. BOOK NO.	- - - N/A - - -	SDR DATE	22-JUL-2016
			RD368