



Oregon

Kate Brown, Governor

Department of Consumer and Business Services
Building Codes Division

1535 Edgewater Street NW

P.O. Box 14470

Salem, OR 97309-0404

503-378-4133

Fax: 503-378-2322

bcd.oregon.gov

September 30, 2016

VIA ELECTRONIC MAIL (broast@beavertonoregon.gov)

Mr. Brad Roast

City of Beaverton Building Division

12725 SW Millikan Way

Beaverton, OR 97005

2016-04 EL Product Listing Exemption

RE: Final decision on appeal

Dear Mr. Roast:

The Building Codes Division recently issued a final decision on appeal concerning the application of the certification exemption of OAR 918-261-0039 to audio equipment in a school building located at 650 NW 118th Ave, Beaverton, OR 97229. The final decision was as follows:

OAR 918-261-0039 exempts all electrical products installed on the load side of a class 2 transformer from the general certification requirement of ORS 479.610 and any subsequent listing or marking requirements adopted under the OESC.

Any power source which meets the standards for an inherently limited, class 2 power source under OESC tables 11(A) and 11(B) is a class 2 transformer for the purposes of OAR 918-261-0039.

The certification question from the appeal is now resolved and the division expects the City to apply the clarified standard to the above address.

DIRECTIVE: Based upon the final decision of the appeal filed under ORS 455.475, the Building Codes Division now directs you, as building official, to enforce OAR 918-261-0039 as contained in the appeal decision. This directive is provided under ORS chapter 455 and OAR chapter 918 division 098. Per OAR 918-271-0020(1), the division expects this directive completed within 48 hours of receipt of this letter.

Please call me if you have any questions.

Sincerely,

Richard Rogers

Chief Building Official

richard.rogers@oregon.gov

503-378-4472

cc: Anita Paso, GB Manchester, Inc.
Greg Evers, Inspector, City of Beaverton Building Division