

Electrical Contractor (C)

OAR 918-282-0010

The scope of work allowed with a Minor Label is regulated by license type. This does **not** allow any business/person to make an installation or perform any work that is not authorized by the scope of the contractor's and individual's license.

Scope of work allowed under a Minor Label	Individual installer license requirement
<p>Repair and replacement of up to 50 devices in existing construction, or installation of up to 10 new devices (including new construction), for Class 2 or 3 installations not exceeding 100 volt-amperes, provided the system does not penetrate any fire-rated assembly.</p> <ul style="list-style-type: none"> • Audio and stereo systems • Central vacuum systems • Doorbells • Garage door openers • HVAC • Telephone wiring <p><i>OAR 918-309-0220(6)(a)</i></p>	<p>Limited Energy Technician, Class B (LEB)</p> <p style="text-align: center;">- or -</p> <p>Limited Energy Technician, Class A (LEA)</p> <p style="text-align: center;">- or -</p> <p>General Journeyman Electrician (J)</p> <p style="text-align: center;">- or -</p> <p>General Supervising Electrician (S)</p> <p style="text-align: center;">- or -</p> <p>Limited Residential (LR) 1- and 2-family dwellings ONLY</p>
<p>Repair and replacement of up to 50 devices in existing construction, or installation of up to 10 new devices (including new construction), for Class 2 or 3 installations not exceeding 100 volt-amperes, provided the system does not penetrate any fire-rated assembly.</p> <ul style="list-style-type: none"> • Burglar alarms • Fire alarms • Security systems <p><i>OAR 918-309-0220(6)(a)</i></p>	<p>Limited Energy Technician, Class A (LEA)</p> <p style="text-align: center;">- or -</p> <p>General Journeyman Electrician (J)</p> <p style="text-align: center;">- or -</p> <p>General Supervising Electrician (S)</p> <p style="text-align: center;">- or -</p> <p>Limited Residential (LR) 1- and 2-family dwellings ONLY</p>
<p>Alteration, repair, and replacement of up to 50 devices in existing construction, for Class 2 or 3 installations not exceeding 100 volt-amperes, provided the system does not penetrate any fire-rated assembly.</p> <ul style="list-style-type: none"> • Cable television • Closed circuit television systems (CCTV)(not part of a protective signaling system) • Central vacuum systems • Data communication devices • Door or gate control, monitor, or access devices • Intercom, music, and paging devices • Thermostats <p><i>OAR 918-309-0220(6)(b)</i></p>	<p>Limited Energy Technician, Class B (LEB)</p> <p style="text-align: center;">- or -</p> <p>Limited Energy Technician, Class A (LEA)</p> <p style="text-align: center;">- or -</p> <p>General Journeyman Electrician (J)</p> <p style="text-align: center;">- or -</p> <p>General Supervising Electrician (S)</p> <p style="text-align: center;">- or -</p> <p>Limited Residential (LR) 1- and 2-family dwellings ONLY</p>
<p>Alteration, repair, and replacement of up to 50 devices in existing construction, for Class 2 or 3 installations not exceeding 100 volt-amperes, provided the system does not penetrate any fire-rated assembly.</p> <ul style="list-style-type: none"> • Burglar alarms • Closed circuit television systems (CCTV) Security • Security systems • Fire alarm devices <p><i>OAR 918-309-0220(6)(b)</i></p>	<p>Limited Energy Technician, Class A (LEA)</p> <p style="text-align: center;">- or -</p> <p>General Journeyman Electrician (J)</p> <p style="text-align: center;">- or -</p> <p>General Supervising Electrician (S)</p> <p style="text-align: center;">- or -</p> <p>Limited Residential (LR) 1- and 2-family dwellings ONLY</p>

...continued next page

Scope of work allowed under a Minor Label	Individual installer license requirement
<p>Installation or extension of up to three (3) new electrical circuits limited to 60 amps and not more than 150 volts to ground (single-phase or three-phase electrical installations).</p> <p><i>OAR 918-309-0220(7)(a)</i></p>	<p>General Journeyman Electrician (J) - or - General Supervising Electrician (S) - or - Limited Residential (LR) 1- and 2-family dwellings ONLY</p>
<p>Installation or extension of one (1) new electrical circuit limited to 30 amps and not more than 300 volts to ground (single-phase or three-phase electrical installations).</p> <p><i>OAR 918-309-0220(7)(b)</i></p>	<p>General Journeyman Electrician (J) - or - General Supervising Electrician (S) - or - Limited Residential (LR) 1- and 2-family dwellings ONLY</p>
<p>Repair, replacement, or installation of components within existing electrical equipment or services, not to exceed 200 amps and 150 volts to ground, provided a reconnect is not required by the serving utility (single-phase or three-phase electrical installations).</p> <p><i>OAR 918-309-0220(7)(c)</i></p>	<p>General Journeyman Electrician (J) - or - General Supervising Electrician (S) - or - Limited Residential (LR) 1- and 2-family dwellings ONLY</p>
<p>Replacement of multiple switches, circuit breakers, receptacles, light fixtures and light fixture components, and smoke detectors (single-phase or three-phase electrical installations).</p> <p><i>OAR 918-309-0220(7)(d)</i></p>	<p>General Journeyman Electrician (J) - or - General Supervising Electrician (S) - or - Limited Residential (LR) 1- and 2-family dwellings ONLY</p>
<p>In dwelling units, replacement of multiple 15 and 20 amp, 125-volt, GFCI or AFCI circuit breakers and receptacles (single-phase or three-phase electrical installations).</p> <p><i>OAR 918-309-0220(7)(e)</i></p>	<p>General Journeyman Electrician (J) - or - General Supervising Electrician (S) - or - Limited Residential (LR) 1- and 2-family dwellings ONLY</p>
<p>Installation of a grounding electrode <u>only</u> when a metal water service is replaced with a non-metallic pipe (single-phase or three-phase electrical installations).</p> <p><i>OAR 918-309-0220(7)(f)</i></p>	<p>General Journeyman Electrician (J) - or - General Supervising Electrician (S) - or - Limited Residential (LR) 1- and 2-family dwellings ONLY</p>
<p>Installation of a fan connected to existing duct work (single-phase or three-phase electrical installations), without an additional mechanical permit when:</p> <p>(A) The fan is replacing an existing fan; (B) The replacement fan is 200 cfm or less; (C) The person performing the replacement connects the new fan to the existing duct work; and (D) No changes are made to the existing duct system.</p> <p><i>OAR 918-309-0220(7)(g)</i></p>	<p>General Journeyman Electrician (J) - or - General Supervising Electrician (S) - or - Limited Residential (LR) 1- and 2-family dwellings ONLY</p>
<p>Repair and maintenance of renewable electrical energy systems as set forth in ORS 479.630(16)(a).</p> <p><i>OAR 918-309-0220(8)</i></p>	<p>Limited Renewable Energy Tech (LRT) - or - General Journeyman Electrician (J) - or - General Supervising Electrician (S)</p>