

Limited Energy Contractor (CLE)

OAR 918-282-0030

The scope of work allowed with a Minor Label is regulated by license type. This does not allow any business/person to make an installation or perform any work that is not authorized by the scope of the contractor's and individual's license.

Scope of work allowed under a Minor Label	Individual installer license requirement
<p>Repair and replacement of up to 50 devices in existing construction, or installation of up to 10 new devices (including new construction), for Class 2 or 3 installations not exceeding 100 volt-amperes, provided the system does not penetrate any fire-rated assembly.</p> <ul style="list-style-type: none"> • Audio and stereo systems • Central vacuum systems • Doorbells • Garage door openers • HVAC • Telephone wiring <p><i>OAR 918-309-0220(6)(a)</i></p>	<p>Limited Energy Technician, Class B (LEB)</p> <p style="text-align: center;">- or -</p> <p>Limited Energy Technician, Class A (LEA)</p> <p style="text-align: center;">- or -</p> <p>General Journeyman Electrician (J)</p> <p style="text-align: center;">- or -</p> <p>General Supervising Electrician (S)</p> <p style="text-align: center;">- or -</p> <p>Installer license is not required for one- and two-family dwellings. See ORS 479.940</p>
<p>Repair and replacement of up to 50 devices in existing construction, or installation of up to 10 new devices (including new construction), for Class 2 or 3 installations not exceeding 100 volt-amperes, provided the system does not penetrate any fire-rated assembly.</p> <ul style="list-style-type: none"> • Burglar alarm • Fire alarms • Security systems <p><i>OAR 918-309-0220(6)(a)</i></p>	<p>Limited Energy Technician, Class A (LEA)</p> <p style="text-align: center;">- or -</p> <p>General Journeyman Electrician (J)</p> <p style="text-align: center;">- or -</p> <p>General Supervising Electrician (S)</p>
<p>Alteration, repair, and replacement of up to 50 devices in existing construction, for Class 2 or 3 installations not exceeding 100 volt-amperes, provided the system does not penetrate any fire-rated assembly.</p> <ul style="list-style-type: none"> • Cable television • Closed circuit television systems (CCTV)(not part of a protective signaling system) • Central vacuum systems • Data communication devices • Door or gate control, monitor, or access devices • Intercom, music, and paging devices • Thermostats <p><i>OAR 918-309-0220(6)(b)</i></p>	<p>Limited Energy Technician, Class B (LEB)</p> <p style="text-align: center;">- or -</p> <p>Limited Energy Technician, Class A (LEA)</p> <p style="text-align: center;">- or -</p> <p>General Journeyman Electrician (J)</p> <p style="text-align: center;">- or -</p> <p>General Supervising Electrician (S)</p>
<p>Alteration, repair, and replacement of up to 50 devices in existing construction, for Class 2 or 3 installations not exceeding 100 volt-amperes, provided the system does not penetrate any fire-rated assembly.</p> <ul style="list-style-type: none"> • Burglar alarms • Closed circuit television systems (CCTV) Security • Security systems • Fire alarm devices <p><i>OAR 918-309-0220(6)(b)</i></p>	<p>Limited Energy Technician, Class A (LEA)</p> <p style="text-align: center;">- or -</p> <p>General Journeyman Electrician (J)</p> <p style="text-align: center;">- or -</p> <p>General Supervising Electrician (S)</p>