

Limited Maintenance Specialty Contractor HVAC/R (LHR)

OAR 918-282-0040

The scope of work allowed with a Minor Label is regulated by license type. This does not allow any business/person to make an installation or perform any work that is not authorized by the scope of the contractor's and individual's license.

Scope of work allowed under a Minor Label	Individual installer license requirement
Repair or replacement of a furnace, oil or gas , not to exceed 20 amps, where the installation does not exceed 150 volts to ground, single-phase. <i>OAR 918-309-0220(5)(a)(A)</i>	Installer license is not required <i>*Must have list of employees on record with BCD</i>
Repair or replacement of a fan , not to exceed 20 amps, where the installation does not exceed 150 volts to ground, single-phase. <i>OAR 918-309-0220(5)(a)(B)</i>	Installer license is not required <i>*Must have list of employees on record with BCD</i>
Repair or replacement of an electrical furnace, air conditioning unit, or refrigeration unit , where the installation does not exceed 150 volts to ground, single-phase. <i>OAR 918-309-0220(5)(a)(E)</i>	Installer license is not required <i>*Must have list of employees on record with BCD</i>

* Limited maintenance specialty contractor HVAC/R is required to create and maintain an electrical training record within 60 days of hiring for each employee who will do the electrical work.