



State of Oregon
Department of
Environmental
Quality

Underground Storage Tank Public Record General Program Information for FFY 2018

Public record posted date: Oct. 15, 2018

Oregon Department of Environmental Quality
Underground Storage Tank Program
700 NE Multnomah St., Suite #600
Portland OR 97232

Contact: Stephanie A. Holmes

Holmes.Stephanie.A@deq.state.or.us

503-229-6085

General Information

Total number of UST facilities: 1,845

Total number of USTs: 5,494

Summary Information for Inspections on Site

Number of UST facilities inspected: 409

Inspection period dates: 10/1/17 to 9/30/18

Percent compliance (combined measure): 84.6

Note: Tank, facility, and on-site inspection information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in Title 40 of the Code of Federal Regulations 280.12, except for those identified in 40 CFR 280.10(b) and 280.10(c) as excluded or deferred USTs. Inspection information provided above includes emergency generator USTs. On-site inspections are comprehensive compliance inspections measuring significant operational compliance as defined by the U.S. Environmental Protection Agency.

Summary Information for Releases

Number of confirmed UST releases: 51

Release reporting period dates: 10/1/17 to 9/30/18

Summary Information for Release Sources and Causes

Source			Causes													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	20	44.5	0	0	0	0	1	2.2	8	17.8	0	0	1	2.2	10	22.3
Piping	3	6.7	0	0	0	0	1	2.2	0	0	0	0	0	0	2	4.5
Dispenser	5	11.1	2	4.4	0	0	0	0	0	0	0	0	2	4.4	1	2.3
STP	1	2.2	0	0	0	0	1	2.2	0	0	0	0	0	0	0	0
Delivery Problem	2	4.4	1	2.2	1	2.2	0	0	0	0	0	0	0	0	0	0
Other	14	31.1	0	0	0	0	0	0	0	0	1	2.2	2	4.5	11	24.4
Totals	45	100	3	6.6	1	2.2	3	6.6	8	17.8	1	2.2	5	11.1	24	53.5

= number, % = percent of total number

Notes:

- (1) Sources of releases at 6 of the 51 confirmed release sites are unknown.
- (2) Release, source and cause information is based on USTs regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those USTs identified in 40 CFR 280.10(b) as excluded USTs. USTs deferred in 40 CFR 280.10(c) and those used for emergency power generation are included as part of the public record.
- (3) Staff collected source and cause data at the time of reported release either by phone or on-line and verified by phone and entered it into the Leaking Underground Storage Tank Database. Project managers may update the data as additional information is available on the source and cause of the release.
- (4) Site-specific information on releases is on [DEQ's Leaking Underground Storage Tank Cleanup Site Database](#). DEQ regional tank staff can provide additional site-specific compliance and release information.
- (5) For more details or to obtain a paper or electronic copy of this report, contact Stephanie A. Holmes.

Contacting DEQ Regional Tank Staff

DEQ tanks specialists are available in the following offices:

In Northwest Oregon

(Clatsop, Clackamas, Columbia, Multnomah, Tillamook and Washington counties)

- Portland, 700 NE Multnomah St., Suite 600
503-229-5263

In Western Oregon

(Benton, Coos, Curry, Douglas, Jackson, Josephine, Lane, Lincoln, Linn, Marion, Polk and Yamhill counties)

- Salem office: 4026 Fairview Industrial Dr.
503-378-8240
- Eugene office: 165 E. Seventh Ave., Suite 100
541-686-7838
- Coos Bay office: 381 N. Second St.
541-269-2721
- Medford office: 221 Stewart Ave., Suite 201
541-776-6010

In Eastern Oregon

(Baker, Crook, Deschutes, Gilliam, Grant, Harney, Hood River, Jefferson, Klamath, Lake, Malheur, Morrow, Sherman, Umatilla, Union, Wallowa, Wasco and Wheeler counties)

- The Dalles office: 400 E. Scenic Drive, Suite 700
541-298-7255
- Bend office: 475 NE Bellevue Drive, Suite 110
541-388-6146

