



State of Oregon Department of Environmental Quality

2018 Oregon UST Requirements: New Implementation Time Frames

2018 DEQ Requirement	Implementation Time Frame
To change tank owner, permittee or property owner information <ul style="list-style-type: none"> • Notification required within 30 days 	Owners and operators must begin meeting this requirement as of June 1, 2018
Changing tank contents to an alternative fuel greater than 10% ethanol or 20% biodiesel	Owners and operators must begin meeting this requirement as of June 1, 2018
Flow restrictors in vent lines may no longer be used to meet the overfill prevention requirement at new installations and when an existing flow restrictor is replaced	Owners and operators must begin meeting this requirement as of June 1, 2018
Testing following a repair	Owners and operators must begin meeting these requirements by Oct. 1, 2020
For previously deferred UST systems: <ul style="list-style-type: none"> • Release detection for UST systems that store fuel solely for use by emergency power generators or for both emergency power generators and heating 	
Spill prevention equipment testing	Owners and operators must conduct the first test or inspection by Oct. 1, 2020
Overfill prevention equipment inspections	
Containment sump testing for sumps used for piping interstitial monitoring	
Release detection equipment testing	
Walkthrough inspections	

Questions? Please contact Mitch Scheel at 503-229-6704 or scheel.mitch@deq.state.or.us