

Date: 8/18/2022

To: File/Julia DeGagné**From:** Thomas Rhodes**Subject:** Source Test Review Report
Covanta Marion, Inc.
Permit No. 24-5398-TV-01Test Date: March 8, 2022
Report Received: May 9, 2022
Revised Report Received: July 5, 2022
Source Tester: Montrose Air Quality
DEQ Observed: Yes

D) Source Description: Covanta Marion, Inc. (CMI) owns and operates a Solid Waste-to-Energy Facility (Facility) in Brooks, Oregon. The primary objective of the CMI Facility is to provide for the disposal of solid waste. In order to achieve this primary objective the Facility receives, stores, and combusts solid waste as defined in Oregon Revised Statutes (ORS) 459.005 and the Facility's Solid Waste Permit. The combustible fraction of the solid waste is utilized to produce steam, which is in turn utilized in a turbine generator to produce electricity which is sold to the local utility. The Facility operates 24 hours per day, 365 days per year, except for periods of scheduled and unscheduled maintenance.

Additionally, CMI is authorized under the Solid Waste Permit to accept for disposal the following: a) cannery wastes; b) conditionally exempt small quantity generator hazardous wastes; c) narcotics, illicit drugs, and equipment and other materials used in the production of illicit drugs; d) pharmaceutical wastes such as prescription and over-the-counter drugs, and DEA-controlled substances; and e) infectious wastes.

II) Process (es)/Emissions Unit(s) Tested: Testing was conducted on the Unit 2 combustor. Target operating parameters for the test were:

Maximum steam load	≤ 90% of design or 60 klbs/hr
Minimum rate of Regulated Medical Waste (RMW)	1.5 tons/hour
Minimum rate of Liquid Direct Injection (LDI)	225 gallons/hour

III) Test Purpose: To evaluate emissions of Toxic Air Contaminants with acute health effects at a low steam production rate.

IV) Testing Location:

Unit 2 Stack:

Diameter:	48"
Distance A (Method 1):	1440" (30 Diameters)
Distance B (Method 1):	1200" (25 Diameters)
Number traverse points utilized:	12

V) Testing Methodology: The following testing methods were utilized during the testing program:

Exhaust Gas Flow Rate: EPA Methods 1-4
Hydrogen Chloride and Hydrogen Fluoride: EPA Method 26A
Multi Metals: EPA Method 29

VI) Summary of Results: The test results and operating parameters are summarized in the Tables below:

Table 1: Hydrogen Chloride and Hydrogen Fluoride Emissions

Table 2: Multi Metal Emissions

TABLE 1: Hydrogen Chloride and Hydrogen Fluoride Emissions

Parameter	Run 1	Run 2	Run 3	Average
Date	3/8/2022	3/8/2022	3/8/2022	--
Test Times	10:20-12:26	13:57-16:05	17:00-19:07	--
Steam Load (klbs/hr)	58.6	58.9	58.7	58.7
Natural Gas (kscf/hr)	0.0	0.0	0.0	0.0
Lime flow (lbs/hr)	249	250	249	249
RMW (tons/hr)	0.7	1.4	1.8	1.3
RMW (% of total fuel)	8	17	23	16
LDI Rate (gals/hr)	210	210	210	210
Exhaust Gas Temperature (°F)	271	272	273	272
Exhaust Gas Moisture (%)	14.0	14.2	13.7	14.0
Exhaust O ₂ (% dry vol)	13.1	13.0	13.0	13.1
Exhaust CO ₂ (% dry vol)	6.7	6.6	6.5	6.6
Exhaust Gas Velocity (ft/m)	5,558	5,530	5,400	5,496
Exhaust Gas Flow Rate (dscf/m)	43,449	43,065	42,246	42,920
Sample Volume (dscf)	80.786	82.490	80.514	81.263
HCl Emissions:	--	--	--	--
· ug/dscm	2,846	2,747	2,988	2,860
· ppmv	1.9	1.8	2.0	1.9
· lb/hr	0.46	0.44	0.47	0.46
· lb/1000 lb steam	7.89E-03	7.51E-03	8.04E-03	7.81E-03
HF Emissions:	--	--	--	--
· ug/dscm	< 9.9	< 10.2	< 11.3	< 10.5
· ppmv	< 0.01	< 0.01	< 0.01	< 0.01
· lb/hr	< 1.60E-03	< 1.65E-03	< 1.78E-03	< 1.68E-03
· lb/1000 lb steam	< 2.74E-05	< 2.80E-05	< 3.03E-05	< 2.86E-05

'<' denotes results calculated using the MDL for results that were non-detect

TABLE 2: Multi Metal Emissions

Parameter	Run 1	Run 2	Run 3	Average
Date	3/8/2022	3/8/2022	3/8/2022	--
Test Times	10:20-12:26	13:57-16:05	17:00-19:07	--
Steam Load (klbs/hr)	58.6	58.9	58.7	58.7
Natural Gas (kscf/hr)	0.0	0.0	0.0	0.0
Carbon Feed (lbs/hr)	10.1	9.8	9.8	9.9
RMW (tons/hr)	0.7	1.4	1.8	1.3
RMW (% of total fuel)	8	17	23	16
LDI Rate (gals/hr)	210	210	210	210
Exhaust Gas Flow Rate (dscf/m)	43,373	43,838	42,453	43,221
Sample Volume (dscf)	79.618	79.095	77.864	78.859
Aluminum Emissions:	--	--	--	--
· ug/dscm	6.34E+01	6.09E+01	<5.57E+01	<6.00E+01
· lb/hr	1.03E-02	9.99E-03	<8.85E-03	<9.71E-03
· lb/1000 lb steam	1.76E-04	1.70E-04	<1.51E-04	<1.65E-04
Antimony Emissions:	--	--	--	--
· ug/dscm	<4.43E+00	<3.31E+00	<4.38E+00	<4.04E+00
· lb/hr	<7.20E-04	<5.43E-04	<6.96E-04	<6.53E-04
· lb/1000 lb steam	<1.23E-05	<9.22E-06	<1.19E-05	<1.11E-05
Arsenic Emissions:	--	--	--	--
· ug/dscm	<2.07E-01	<2.21E-01	<1.94E-01	<2.07E-01
· lb/hr	<3.36E-05	<3.62E-05	<3.08E-05	<3.35E-05
· lb/1000 lb steam	<5.73E-07	<6.15E-07	<5.25E-07	<5.71E-07
Barium Emissions:	--	--	--	--
· ug/dscm	9.45E-01	1.12E+00	9.08E-01	9.90E-01
· lb/hr	1.53E-04	1.83E-04	1.44E-04	1.60E-04
· lb/1000 lb steam	2.62E-06	3.11E-06	2.46E-06	2.73E-06
Beryllium Emissions:	--	--	--	--
· ug/dscm	<2.71E-02	<2.73E-02	<2.77E-02	<2.73E-02
· lb/hr	<4.40E-06	<4.48E-06	<4.40E-06	<4.43E-06
· lb/1000 lb steam	<7.51E-08	<7.61E-08	<7.49E-08	<7.54E-08
Cadmium Emissions:	--	--	--	--
· ug/dscm	<6.33E-01	<9.66E-01	<6.56E-01	<7.52E-01
· lb/hr	<1.03E-04	<1.59E-04	<1.04E-04	<1.22E-04
· lb/1000 lb steam	<1.76E-06	<2.69E-06	<1.78E-06	<2.08E-06
Chromium Emissions:	--	--	--	--
· ug/dscm	1.63E+00	1.52E+00	1.10E+00	1.42E+00
· lb/hr	2.65E-04	2.49E-04	1.75E-04	2.30E-04
· lb/1000 lb steam	4.52E-06	4.23E-06	2.99E-06	3.91E-06

'<' denotes results calculated using the MDL for front half and/or back half results that were non-detect.

TABLE 2: Multi Metal Emissions continued

Parameter	Run 1	Run 2	Run 3	Average
Cobalt Emissions:	--	--		--
· ug/dscm	9.40E-02	1.43E-01	<8.70E-02	<1.08E-01
· lb/hr	1.53E-05	2.35E-05	<1.38E-05	<1.75E-05
· lb/1000 lb steam	2.61E-07	4.00E-07	<2.36E-07	<2.99E-07
Copper Emissions:	--	--		--
· ug/dscm	1.67E+00	1.47E+00	1.36E+00	1.50E+00
· lb/hr	2.71E-04	2.42E-04	2.16E-04	2.43E-04
· lb/1000 lb steam	4.63E-06	4.11E-06	3.67E-06	4.13E-06
Iron Emissions:	--	--		--
· ug/dscm	1.05E+02	1.41E+02	1.05E+02	1.17E+02
· lb/hr	1.71E-02	2.32E-02	1.67E-02	1.90E-02
· lb/1000 lb steam	2.92E-04	3.93E-04	2.85E-04	3.23E-04
Lead Emissions:	--	--		--
· ug/dscm	2.95E+00	2.98E+00	3.02E+00	2.98E+00
· lb/hr	4.79E-04	4.89E-04	4.81E-04	4.83E-04
· lb/1000 lb steam	8.18E-06	8.31E-06	8.19E-06	8.22E-06
Manganese Emissions:	--	--		--
· ug/dscm	1.55E+00	2.02E+00	1.37E+00	1.65E+00
· lb/hr	2.52E-04	3.31E-04	2.18E-04	2.67E-04
· lb/1000 lb steam	4.31E-06	5.62E-06	3.72E-06	4.55E-06
Mercury Emissions:	--	--		--
· ug/dscm	<5.03E-01	<5.50E-01	<5.77E-01	<5.43E-01
· lb/hr	<8.16E-05	<9.03E-05	<9.17E-05	<8.79E-05
· lb/1000 lb steam	<1.39E-06	<1.53E-06	<1.56E-06	<1.50E-06
Molybdenum Emissions:	--	--		--
· ug/dscm	< 1.35E+00	< 1.36E+00	<1.38E+00	<1.37E+00
· lb/hr	< 2.20E-04	< 2.24E-04	<2.20E-04	<2.21E-04
· lb/1000 lb steam	< 3.75E-06	< 3.80E-06	<3.75E-06	<3.77E-06
Nickel Emissions:	--	--		--
· ug/dscm	1.20E+00	7.46E-01	5.30E-01	8.26E-01
· lb/hr	1.95E-04	1.23E-04	8.42E-05	1.34E-04
· lb/1000 lb steam	3.33E-06	2.08E-06	1.43E-06	2.28E-06
Phosphorus Emissions:	--	--		--
· ug/dscm	9.08E+00	9.09E+00	1.05E+01	9.57E+00
· lb/hr	1.48E-03	1.49E-03	1.67E-03	1.55E-03
· lb/1000 lb steam	2.52E-05	2.53E-05	2.85E-05	2.63E-05
Potassium Emissions:	--	--		--
· ug/dscm	1.28E+02	1.37E+02	1.37E+02	1.34E+02
· lb/hr	2.08E-02	2.25E-02	2.17E-02	2.17E-02
· lb/1000 lb steam	3.54E-04	3.82E-04	3.70E-04	3.69E-04

'<' denotes results calculated using the MDL for front half and/or back half results that were non-detect.

TABLE 2: Multi Metal Emissions continued

Parameter	Run 1	Run 2	Run 3	Average
Selenium Emissions:	--	--		--
· ug/dscm	<3.66E-01	<3.90E-01	3.19E-01	<3.58E-01
· lb/hr	<5.94E-05	<6.40E-05	5.07E-05	<5.80E-05
· lb/1000 lb steam	<1.01E-06	<1.09E-06	8.63E-07	<9.88E-07
Silver Emissions:	--	--		--
· ug/dscm	9.56E-02	1.75E-01	<9.50E-02	<1.22E-01
· lb/hr	1.55E-05	2.87E-05	<1.51E-05	<1.98E-05
· lb/1000 lb steam	2.65E-07	4.87E-07	<2.57E-07	<3.36E-07
Thallium Emissions:	--	--		--
· ug/dscm	<9.43E-02	<1.01E-01	<9.64E-02	<9.74E-02
· lb/hr	<1.53E-05	<1.66E-05	<1.53E-05	<1.58E-05
· lb/1000 lb steam	<2.62E-07	<2.82E-07	<2.61E-07	<2.68E-07
Vanadium Emissions:	--	--		--
· ug/dscm	<2.71E+00	<2.73E+00	<2.77E+00	<2.73E+00
· lb/hr	<4.40E-04	<4.48E-04	<4.40E-04	<4.43E-04
· lb/1000 lb steam	<7.51E-06	<7.61E-06	<7.50E-06	<7.54E-06
Zinc Emissions:	--	--		--
· ug/dscm	4.81E+01	5.12E+01	5.09E+01	5.01E+01
· lb/hr	7.81E-03	8.41E-03	8.09E-03	8.10E-03
· lb/1000 lb steam	1.33E-04	1.43E-04	1.38E-04	1.38E-04

'<' denotes results calculated using the MDL for front half and/or back half results that were non-detect.

VII) Concerns & Comments:

- 1) Molybdenum speciation analysis on the Method 26A particulate filters was completed as proposed in the source test plan and on bulk samples of baghouse fly ash. Analysis did not yield any results for molybdenum from the samples.
- 2) The Method 29 front half reagent blank exceeded the allowable amount for aluminum, iron, and potassium. The maximum blank correction allowed by the method was used.
- 3) The amount of LDI during the test runs was less than the proposed minimum rate of 225 gallons/hour in the approved source test plan.
- 4) The amount of RMW burned during the test runs was less than the proposed minimum rate of 1.5 tons/hour in the approved source test plan.

VIII) Overall Evaluation: As noted above, testing was not successfully completed for all of the conditions and operating parameters approved in the source test plan. The test methods conducted, and the data provided are sufficient to evaluate emissions of HCl, HF, and metals from the facility only at the operating conditions tested. Use of this data in a Cleaner Air Oregon risk assessment may result in source risk limits, as applicable, based on the conditions and operating parameters demonstrated during this source test.

cc: Terry Coble
Covanta Marion, Inc.
4850 Brooklake Road NE
Brooks, OR 97305