



State of Oregon
Department of
Environmental
Quality

Underground Storage Tank Public Record General Program Information for FFY 2022

Public record posted date: Oct. 1, 2022

Oregon Department of Environmental Quality
Underground Storage Tank Program
700 NE Multnomah St., Suite #600
Portland OR 97232
Contact: Diana Foss

Diana.Foss@deq.state.or.us
503-229-5733

General Information

Total number of UST facilities: 1,792

Total number of USTs: 5,444*

* This number reflects all tanks that are believed to be federally regulated and have not been permanently closed.

Summary Information for Inspections on Site

Number of UST facilities inspected: 424

Inspection period dates: 10/1/21 to 9/30/22

Percent compliance (combined measure): 42.69%

Note: Tank, facility, and on-site inspection information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in Title 40 of the Code of Federal Regulations 280.12, except for those identified in 40 CFR 280.10(b) and 280.10(c) as excluded or deferred USTs. Inspection information provided above includes emergency generator USTs. On-site inspections are comprehensive compliance inspections measuring technical compliance rate as defined by the U.S. Environmental Protection Agency.

Summary Information for Releases

Number of confirmed UST releases: 74

Release reporting period dates: 10/1/21 to 9/30/22

Summary Information for Release Sources and Causes

Source			Causes													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	28	38%	3	4%	2	3%	1	1%	5	7%	0	0%	1	1%	16	22%
Piping	5	7%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	5	7%
Dispenser	9	12%	0	0%	1	1%	1	1%	1	1%	0	0%	1	1%	5	7%
STP	1	1%	0	0%	0	0%	0	0%	1	1%	0	0%	0	0%	0	0%
Delivery Problem	2	3%	1	1%	1	1%	0	0%	0	0%	0	0%	0	0%	0	0%
Other	23	31%	0	0%	1	1%	0	0%	0	0%	0	0%	8	11%	14	19%
Unknown	6	8%	0	0%	1	1%	0	0%	0	0%	0	0%	0	0%	5	7%
Totals	74	100%	4	5%	6	8%	2	3%	7	9%	0	0%	10	14%	45	61%

= number, % = percent of total number

Notes:

- (1) Release, source and cause information is based on USTs regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those USTs identified in 40 CFR 280.10(b) as excluded USTs. USTs deferred in 40 CFR 280.10(c) and those used for emergency power generation are included as part of the public record.
- (2) Staff collected source and cause data at the time of reported release either by phone or on-line and verified by phone and entered it into the Leaking Underground Storage Tank Database. Project managers may update the data as additional information is available on the source and cause of the release.
- (3) Site-specific information on releases is on [DEQ's Leaking Underground Storage Tank Cleanup Site Database](#). DEQ regional tank staff can provide additional site-specific compliance and release information.
- (4) For more details or to obtain a paper or electronic copy of this report, contact Diana Foss.