

## Adult Foster Home Provider Alert

Policy updates, rule clarifications and announcements

---

**Date:** May 10, 2021  
**To:** APD Adult Foster Home Providers  
**From:** Safety, Oversight and Quality Unit  
**Topic:** **Kidde Smoke and Combination Smoke/Carbon Monoxide Alarm Recall**

---



### **Kidde Recalls TruSense Smoke and Combination Smoke/Carbon Monoxide Alarms Due to Risk of Failure to Alert Consumers to a Fire**

#### **Recall Summary**

**Brand Name, Model of Affected Product:** Kidde TruSense Smoke and Combination Smoke/ Carbon Monoxide Alarms – Models 2040, 2050, 2060, and 2070. Only alarms with the TruSense logo or “AMBER=FAULT” printed on the front of the alarm are included in this recall. The model number is printed on the back of the alarm.

**Recall Date:** May 6, 2021

**Hazard:** The Smoke and Combination Smoke/Carbon Monoxide Alarm outlined in the recall may not alert consumers to a fire.

**Remedy:** Consumers should immediately contact Kidde for a free replacement alarm. Consumers should keep using the recalled alarms until they install replacement alarms.

If you have an alarm that has been recalled, you may register for a replacement at <https://kiddetsalarmrecall.rsvpcomm.com/>.

---

To review the full CPSC press release, click [here](#).

An illustrated identification guide to help you identify if your alarms have been recalled is available at the web address provided above.