

# Baker City Fire

City of Baker City

Bake\_fir02A

Building Type Fire - City	County Baker	
Street 1616 2nd St		
City Baker City	State OR	Zip 97814
Latitude 44.77392	Longitude 117.83175	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	3.2	0	-0.5	0	0	0	-1	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Baker City Fire

## Final RVS Score

Final Type	Final Score
PC1	1.7

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# Baker City Fire

Bake\_fir02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1980	1980	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N	Field Verified Year Built	S	Elevation View



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries