

Pine Valley RFPD

Pine Valley RFPD

Bake_fir03A

Building Type Fire - RFPD	County Baker	
Street 125 W Record St		
City Halfway	State OR	Zip 97834
Latitude 44.87715	Longitude 117.11085	
Tracking Code RVS in 2006	Inspection Date 8/11/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Secondary	W1	5.2	0	-0.5	0	0	0	-0.6	0	4.1
Tertiary		0	0	0	0	0	0	0	0	0

Pine Valley RFPD

Final RVS Score

Final Type	Final Score
RM1	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



Oregon Geology

Pine Valley RFPD

Bake_fir03A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1960	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
7840	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	



SE Elevation View



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries