

Mosquito Flat North RFPD

Bake_fir14A

Mosquito Flat North RFPD

Building Type Fire - RFPD	County Baker	
Street 39744 Sumpter Valley Hwy		
City Sumpter	State OR	Zip 97877
Latitude 44.72047	Longitude 118.1708	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	0	0	0	0	0	0	3.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mosquito Flat North RFPD

Final RVS Score

Final Type	Final Score
S3	3.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mosquito Flat North RFPD

Bake_fir14A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries