

St. Elizabeth Hospital - Baker City

Catholic Health Initiatives NFP

Bake_hos01A

Building Type Hospital	County Baker	
Street 3325 Pocahontas Rd		
City Baker City	State OR	Zip 97814
Latitude 44.79541	Longitude 117.84743	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	3.2	0	-0.5	0	0	0	-1	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

St. Elizabeth Hospital - Baker City

Final RVS Score

Final Type	Final Score
PC1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

St. Elizabeth Hospital - Baker City

Bake_hos01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1987	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N	Elevation View	W	Elevation View
			
N	Primary Structural Type		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

St. Elizabeth Hospital - Baker City

Catholic Health Initiatives NFP

Bake_hos01B

Building Type	County	
Hospital	Baker	
Street		
3325 Pocahontas Rd		
City	State	Zip
Baker City	OR	97814
Latitude	Longitude	
44.79491	117.84732	
Tracking Code	Inspection Date	
RVS in 2006	8/10/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	1.6	0	-1.2	0	4.7
Secondary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Tertiary		0	0	0	0	0	0	0	0	0

St. Elizabeth Hospital - Baker City

Final RVS Score

Final Type	Final Score
RM1	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

St. Elizabeth Hospital - Baker City

Bake_hos01B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1987	1987	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		None	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE Elevation View		E Elevation View	
		E Elevation View	
			
S Elevation View		S Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries