

OSP - Baker City

Oregon State Police

Bake_pol01A

Building Type		County	
Police - State		Baker	
Street			
1050 S Bridge St			
City	State	Zip	
Baker City	OR	97814	
Latitude		Longitude	
44.76911		117.82366	
Tracking Code		Inspection Date	
RVS in 2006		8/11/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	0	-1.2	0	3.1
Secondary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Tertiary		0	0	0	0	0	0	0	0	0

OSP - Baker City

Final RVS Score

Final Type

Final Score

RM1

1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1930	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
435600	1	No	No

Plan Irregularities	Vertical Irregularities
Out of Plane Lateral-Force-Resistance Elements	None
None	None
None	None

Falling Hazards	Poor Conditions
Unreinforced Chimneys	None
None	None
None	None



SE Secondary Structural Type



SE Falling Hazard

