

# Baker County Sheriff's Office

Baker County

Bake\_pol02A

Building Type	County
EOC-Public Safety Answering P	Baker
Street	
3410 K Street	
City	State Zip
Baker City	OR 97814
Latitude	Longitude
44.79208	117.84868
Tracking Code	Inspection Date
RVS in 2006	8/10/2006



Seismicity Zone: Moderate

**FEMA 154 Rapid Visual Screening Score Card**

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

**Baker County Sheriff's Office**

**Final RVS Score**

Final Type	Final Score
RM1	1.9

**FEMA-154 Collapse Potential**

Moderate (>1%)
----------------



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Baker County Sheriff's Office

Bake\_pol02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1990	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:Other (Adjacent Build/Entity)		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SW Elevation View		E Plan Irregularity Primary	