

Baker City Police Dept

City of Baker City

Bake_pol03A

Building Type Fire - City	County Baker	
Street 1655 1st St		
City Baker City	State OR	Zip 97814
Latitude 44.77392	Longitude 117.83175	
Tracking Code RVS in 2006	Inspection Date 1/30/2007	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	-0.4	0	0	-1.2	0	1.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Baker City Police Dept

Final RVS Score

Final Type	Final Score
RM1	1.5

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Baker City Police Dept

Bake_pol03A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1910	1910
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: T Shaped		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Unreinforced Chimneys		None	
None		None	
None		None	
			
S	Primary Structural Type	N	General Site
			
S	General Site	S	General Site
			
S	General Site		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries