

# South Baker Elementary School

Baker SD 5J

Bake\_sch02A

Building Type School	County Baker	
Street 1285 Third St		
City Baker City	State OR	Zip 97814
Latitude 44.77064	Longitude 117.8339	
Tracking Code RVS in 2006	Inspection Date 8/11/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Secondary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1

South Baker Elementary School

Final RVS Score

Final Type	Final Score
C2	-0.1

FEMA-154 Collapse Potential

Very High (100%)
------------------



OregonGeology

# South Baker Elementary School

Bake\_sch02A

Enrollment 283	Year Built (Field Verified) 1953	Year Built (Alt. Source) 1953	Est. Decade Built 1950
Total Area (square ft) 34200	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards Other: Smokestack None None		Poor Conditions None None None	
			S Falling Hazard E Elevation View E Building Name
			E Field Verified Year Built N Elevation View W Vertical Irregularity Primary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# South Baker Elementary School

Baker SD 5J

Bake\_sch02B

Building Type School	County Baker	
Street 1285 Third St		
City Baker City	State OR	Zip 97814
Latitude 44.7704	Longitude 117.83363	
Tracking Code RVS in 2006	Inspection Date 8/11/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	0	-1.2	0	3.1
Secondary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Tertiary		0	0	0	0	0	0	0	0	0

South Baker Elementary School

Final RVS Score

Final Type	Final Score
RM1	1.9

FEMA-154 Collapse Potential

Moderate (>1%)
----------------



OregonGeology

# South Baker Elementary School

Bake\_sch02B

Enrollment 283	Year Built (Field Verified) 1953	Year Built (Alt. Source) 1953	Est. Decade Built 1970
Total Area (square ft) 34200	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
E Elevation View		N Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries