

Baker High School

Baker SD 5J

Bake_sch03A

Building Type School	County Baker	
Street 2500 E St		
City Baker City	State OR	Zip 97814
Latitude 44.78697	Longitude 117.83644	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	1.6	0	-1.2	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Baker High School

Final RVS Score

Final Type W2	Final Score 1.7
------------------	--------------------

FEMA-154 Collapse Potential

Moderate (>1%)



Baker High School

Bake_sch03A

Enrollment 647	Year Built (Field Verified) 1991	Year Built (Alt. Source) 1950	Est. Decade Built 1990
Total Area (square ft) 126904	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: Single Change Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	
 S Elevation View			

Baker High School

Baker SD 5J

Bake_sch03B

Building Type School	County Baker	
Street 2500 E St		
City Baker City	State OR	Zip 97814
Latitude 44.78729	Longitude 117.83634	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	1.6	0	-1.2	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Baker High School

Final RVS Score

Final Type	Final Score
W2	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



Baker High School

Bake_sch03B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
647		1950	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
126904	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	



E Elevation View

Baker High School

Baker SD 5J

Bake_sch03C

Building Type School	County Baker	
Street 2500 E St		
City Baker City	State OR	Zip 97814
Latitude 44.78679	Longitude 117.83733	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Baker High School

Final RVS Score

Final Type C2	Final Score -0.1
------------------	---------------------

FEMA-154 Collapse Potential

Very High (100%)



Baker High School

Bake_sch03C

Enrollment 647	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1960	Est. Decade Built 1960
Total Area (square ft) 126904	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) Steps in Elevation View: Single Change None	
Falling Hazards None None None		Poor Conditions None None None	
 W Vertical Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Baker High School

Baker SD 5J

Bake_sch03D

Building Type School	County Baker	
Street 2500 E St		
City Baker City	State OR	Zip 97814
Latitude 44.78721	Longitude 117.83736	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Baker High School

Final RVS Score

Final Type

C2

Final Score

-0.1

FEMA-154 Collapse Potential

Very High (100%)



Baker High School

Bake_sch03D

Enrollment 647	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 126904	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards Unreinforced Chimneys None None		Poor Conditions None None None	
 NW Falling Hazard			

Baker High School

Baker SD 5J

Bake_sch03E

Building Type School	County Baker	
Street 2500 E St		
City Baker City	State OR	Zip 97814
Latitude 44.78763	Longitude 117.83738	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Baker High School

Final RVS Score

Final Type	Final Score
C2	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Baker High School

Bake_sch03E

Enrollment 647	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 126904	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped Reentrant Corners: Other None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
NW Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Baker High School

Baker SD 5J

Bake_sch03F

Building Type School	County Baker	
Street 2500 E St		
City Baker City	State OR	Zip 97814
Latitude 44.78796	Longitude 117.83729	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Baker High School

Final RVS Score

Final Type	Final Score
C2	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Baker High School

Bake_sch03F

Enrollment 647	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1960
Total Area (square ft) 126904	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
N Elevation View		N Elevation View addition	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries