

Pine Eagle High School

Pine Eagle SD 61

Bake_sch05A

Building Type		County	
School		Baker	
Street			
375A N Main St			
City	State	Zip	
Halfway	OR	97834	
Latitude		Longitude	
44.88277		117.11643	
Tracking Code		Inspection Date	
RVS in 2006		8/11/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC2	3.2	-1.5	-0.5	0	0	0	-1.2	0	0
Secondary	C1	3	-2	-0.5	0	0	0	-1	0	-0.5
Tertiary		0	0	0	0	0	0	0	0	0

Pine Eagle High School

Final RVS Score

Final Type

Final Score

C1

-0.5

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
74		1967	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
38700	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Single Change
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Elevation View

N Primary Structural Type
bolt plates at column indicate precast frame

Pine Eagle High School

Pine Eagle SD 61

Bake_sch05B

Building Type		County	
School		Baker	
Street			
375A N Main St			
City	State	Zip	
Halfway	OR	97834	
Latitude		Longitude	
44.88352		117.11604	
Tracking Code		Inspection Date	
RVS in 2006		8/11/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC2	3.2	0	0	0	0	0	-1.2	0	2
Secondary	C1	3	0	0	0	0	0	-1	0	2
Tertiary	RM1	3.6	0	0	0	0	0	-1.2	0	2.4

Pine Eagle High School

Final RVS Score

Final Type

Final Score

PC2

2

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
74		1967	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
38700	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Elevation View

