

Alsea RFPD

Bent_fir03A

Alsea RFPD

Building Type		County	
Fire - RFPD		Benton	
Street			
216 Market St			
City	State	Zip	
Alsea	OR	97324	
Latitude		Longitude	
44.38098		123.59679	
Tracking Code		Inspection Date	
RVS in 2006		6/27/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Alsea RFPD

Final RVS Score

Final Type

Final Score

W1

1.4

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1976	1976	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



N Field Verified Year Built



SW Vertical Irregularity Primary



SE Vertical Irregularity Primary

