

# Hoskins - Kings Valley RFPD

Bent\_fir11A

Hoskins - Kings Valley RFPD

Building Type	County
Fire - RFPD	Benton
Street	
38811 Hwy 223	
City	State Zip
Philomath	OR 97370
Latitude	Longitude
44.67384	123.43433
Tracking Code	Inspection Date
RVS in 2006	6/27/2006



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	0	0	3.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hoskins - Kings Valley RFPD

## Final RVS Score

Final Type	Final Score
W2	3.7

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Hoskins - Kings Valley RFPD

Bent\_fir11A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SW General Site torsion - eccentric stiffness vertical irregularity - discontinuous diaphragm			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries