

# Monroe High School

Monroe SD 1J

Bent\_sch19A

Building Type School	County Benton	
Street 365 N 5th St		
City Monroe	State OR	Zip 97456
Latitude 44.31825	Longitude 123.29738	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	-0.4	0	0	-0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Monroe High School

## Final RVS Score

Final Type	Final Score
URM	-0.3

## FEMA-154 Collapse Potential

Very High (100%)

# Monroe High School

Bent\_sch19A

Enrollment 150	Year Built (Field Verified) 1928	Year Built (Alt. Source) 1928	Est. Decade Built
Total Area (square ft) 31527	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site		
			
S	General Site	E	General Site
			
S	General Site		
			
S	General Site		



# OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries