

# Streeter Hall

Clackamas CC

Clac\_coc06A

Building Type	County	
Community_College	Clackamas	
Street		
19600 S. Molalla Avenue		
City	State	Zip
Oregon City	OR	97045
Latitude	Longitude	
45.32317	122.5757	
Tracking Code	Inspection Date	
RVS in 2006	9/22/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	-2.4	-0.4	0	0	0.5
Secondary	RM1	2.8	0	-0.5	0	0	-0.4	0	0	1.9
Tertiary		0	0	0	0	0	0	0	0	0


Streeter Hall

## Final RVS Score

Final Type	Final Score
W2	0.5

## FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1991	2002	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
15757	1	No	Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Elevation View		NE Plan Irregularity Primary	
		E Elevation View	
			
S Elevation View		SW Pounding Potential	



# Streeter Hall

Clackamas CC

Clac\_coc06B

Building Type Community_College	County Clackamas	
Street 19600 S. Molalla Avenue		
City Oregon City	State OR	Zip 97045
Latitude 45.32317	Longitude 122.5757	
Tracking Code RVS in 2006	Inspection Date 9/22/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	2.8	-0.4	0	0	4.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


Streeter Hall

## Final RVS Score

Final Type	Final Score
RM1	4.7

## FEMA-154 Collapse Potential

Low (<1%)



P ..... Sci  
 L ..... Shi  
 M ..... Soc  
 N ..... Spe  
 RR ..... Stu  
 CC ..... Stu  
 CC ..... Stu  
 RR ..... Stu  
 RR ..... Sch  
 RR ..... Stu  
 B ..... Tel  
 B ..... Tel  
 RR ..... Tel  
 N ..... The  
 C ..... Tri  
 Pro  
 CC ..... Tut  
 RR ..... Vet  
 D ..... Vid  
 P ..... Wa  
 Tec  
 TC ..... We  
 CC ..... Wi  
 FRC ..... You  
 Op



Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Streeter Hall

Clac\_coc06B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	2002	2002	2000
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Plan Irregularity Primary		W Plan Irregularity Primary	
		SW Elevation View	
		SE Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries