

# Clackamas County - EOC

Clackamas County

Clac\_eoc02A

Building Type EOC-Public Safety Answering P	County Clackamas									
Street 2200 Kaen Rd										
City Oregon City	State OR	Zip 97045								
Latitude 45.33023	Longitude 122.59955									
Tracking Code Hasenberg 02	Inspection Date 9/15/2006									
Seismicity Zone: High										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	2.4	-0.4	0	0	5.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clackamas County - EOC

**Final RVS Score**

Final Type	Final Score
W2	5.8

**FEMA-154 Collapse Potential**

Low (<1%)
-----------



# Clackamas County - EOC

Clac\_eoc02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1985	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
9700	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries