

Lake Oswego Fire Department

City of Lake Oswego

Clac_fir06A

Building Type	County
Fire - City	Clackamas
Street	
300 B Avenue	
City	State Zip
Lake Oswego	OR 97034
Latitude	Longitude
45.4207	122.6669
Tracking Code	Inspection Date
New Building	9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	-0.4	0	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lake Oswego Fire Department

Final RVS Score

Final Type	Final Score
RM1	2.4

FEMA-154 Collapse Potential

Low (<1%)

Lake Oswego Fire Department

Clac_fir06A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1995	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
10000	2	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries



S General Site

